

SANTA FE, Argentina

WMO: 873710

Lat: 31.7078S

Lon: 60.8053W

Elev: 59

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.7	37.1	26.4	20.4	43.8	29.4	23.5	44.1	36.2	54.7	32.5	58.6	2.2	230	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.6	95.2	75.6	92.5	74.3	89.9	73.5	79.5	89.6	77.9	87.6	76.4	85.6	12.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	139.7	85.6	75.1	132.1	83.9	73.6	125.2	82.3	43.2	89.6	41.5	87.8	40.0	85.9	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.3	26.9	22.9	DB	27.8	101.5	3.1	2.5	25.6	103.4	23.8	104.8	22.1	106.3	19.8	108.1
			WB	26.8	82.4	2.9	1.7	24.7	83.6	23.0	84.6	21.3	85.6	19.2	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.5	78.5	76.2	72.7	66.5	60.7	55.2	54.0	57.5	61.6	67.0	72.1	76.1	(6)
	DBStd	10.60	4.89	5.33	5.61	6.63	7.12	7.20	8.05	8.51	7.48	6.37	5.63	5.32	(7)
	HDD50	93	0	0	0	0	4	24	43	18	4	0	0	0	(8)
	HDD65	1385	0	1	7	58	175	308	358	268	150	50	9	1	(9)
	CDD50	6100	884	735	702	496	336	180	167	251	352	527	662	808	(10)
	CDD65	1918	419	316	245	104	42	14	17	36	48	112	221	344	(11)
	CDH74	16927	4379	2855	1912	651	187	44	79	287	415	857	1911	3350	(12)
	CDH80	6396	1930	1102	626	161	35	5	17	90	128	256	664	1382	(13)
(14) Wind	WSAvg	7.7	6.6	6.4	6.3	6.6	6.5	7.6	8.0	9.1	9.1	9.1	8.9	7.8	(14)
(15) Precipitation	PrecAvg	39.0	4.3	4.2	5.6	4.0	1.9	1.2	1.1	1.3	2.1	3.9	4.6	4.2	(15)
	PrecMax	65.1	10.9	16.3	16.1	15.4	6.1	7.2	3.2	7.7	8.6	12.3	11.4	13.0	(16)
	PrecMin	19.5	0.2	0.1	0.8	0.2	0.0	0.0	0.0	0.0	0.2	1.1	0.6	0.4	(17)
	PrecStd	9.0	3.1	3.1	3.2	3.1	1.7	1.5	0.8	1.5	1.9	2.4	2.6	2.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.7	96.3	93.3	89.3	84.4	79.4	82.1	88.9	91.4	92.4	94.4	97.8	(19)
		MCWB	76.8	77.1	76.7	74.5	71.5	69.8	67.7	71.0	72.2	72.9	73.8	74.5	(20)
	2%	DB	95.2	92.7	89.4	84.5	78.8	73.3	74.8	81.4	83.1	86.2	90.0	93.8	(21)
		MCWB	75.9	75.8	74.2	71.3	68.2	66.3	65.5	67.3	67.8	70.6	71.1	74.3	(22)
	5%	DB	92.0	89.7	86.2	80.8	75.0	69.6	69.9	75.9	78.6	82.2	87.0	90.6	(23)
		MCWB	74.5	75.2	72.8	69.8	67.0	63.4	61.9	64.3	65.7	68.5	69.9	72.9	(24)
	10%	DB	89.4	86.8	83.3	77.4	71.3	66.1	66.1	71.2	74.5	78.7	83.7	87.5	(25)
		MCWB	73.8	74.0	71.4	68.0	64.4	60.8	59.7	61.5	62.7	66.4	68.9	72.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	81.3	80.2	76.9	73.1	71.0	69.9	72.2	74.0	77.1	77.4	80.3	(27)
		MCDB	92.8	90.6	88.5	85.7	81.0	76.9	78.6	84.1	86.0	88.7	88.9	92.2	(28)
	2%	WB	79.2	79.2	77.1	74.4	70.3	67.8	66.3	68.8	70.1	73.2	74.3	78.0	(29)
		MCDB	90.0	87.9	84.8	81.2	76.3	72.0	73.0	79.4	80.6	81.7	84.6	88.1	(30)
	5%	WB	77.5	77.3	74.9	71.9	68.1	64.9	63.6	66.2	67.1	70.7	72.5	75.9	(31)
		MCDB	87.9	85.6	82.3	77.4	73.3	68.7	68.9	74.6	75.5	78.8	82.2	85.4	(32)
	10%	WB	75.9	75.6	73.1	69.9	65.8	62.1	60.8	62.7	64.4	68.4	70.7	73.9	(33)
		MCDB	85.7	83.9	80.7	75.3	70.3	65.1	64.9	69.5	72.2	76.3	80.1	83.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.6	17.3	17.8	17.3	16.2	16.8	18.0	19.5	19.5	18.2	19.3	18.8	(35)
		MCDBR	22.7	21.2	20.8	21.5	19.3	18.7	20.9	24.2	25.1	23.2	24.0	23.8	(36)
	5% WB	MCWBR	8.7	8.7	9.0	10.6	10.1	11.2	11.7	12.5	12.3	11.0	9.9	9.7	(37)
		MCWBR	18.7	17.5	17.8	16.8	15.9	14.7	17.6	21.5	20.5	19.0	19.2	19.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.403	0.393	0.377	0.385	0.364	0.355	0.359	0.427	0.490	0.433	0.397	0.400	(40)
		taud	2.374	2.418	2.455	2.399	2.414	2.430	2.392	2.151	1.982	2.221	2.347	2.366	(41)
	Ebn at Noon		297	294	288	267	256	250	254	247	248	279	297	299	(42)
		Edh at Noon	41	38	35	33	29	27	29	41	55	46	42	42	(43)
(44) All-Sky Solar Radiation	RadAvg		2268	1950	1673	1232	917	795	885	1175	1524	1804	2193	2295	(44)
	RadStd		146	146	134	157	78	89	93	105	132	146	123	132	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)			N/A	N/A	N/A	+0.41	+0.88	+0.99	N/A	N/A	N/A

Nomenclature: See separate page