

MONTE CASEROS, Argentina

WMO: 873930

Lat: 30.2617S

Lon: 57.6389W

Elev: 54

StdP: 100.68

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.5	5.0	-1.0	3.5	7.9	0.6	4.0	8.1	11.7	16.8	10.4	14.8	1.1	270	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	35.3	23.9	33.8	23.6	32.4	23.3	26.1	31.7	25.5	30.8	24.8	29.9	3.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	19.7	29.1	24.0	19.0	28.6	23.4	18.3	27.9	81.5	31.8	78.6	30.9	76.0	29.9	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.1	7.5	0.5	38.2	1.0	0.7	-0.2	38.7	-0.8	39.1	-1.3	39.5	-2.0	40.1		
(5)			0.1	27.3	1.4	0.5	-0.8	27.7	-1.6	28.0	-2.4	28.2	-3.4	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	26.6	25.8	23.8	20.6	17.0	14.8	14.3	16.2	17.6	20.3	22.8	25.2
	DBStd	5.57	2.59	2.82	3.13	3.65	3.46	4.57	4.58	4.62	4.25	3.18	2.77	3.06
	HDD10.0	21	0	0	0	0	0	8	10	3	1	0	0	0
	HDD18.3	539	0	0	2	17	69	126	144	100	63	16	2	0
	CDD10.0	3809	516	444	427	318	216	153	142	196	228	318	383	470
	CDD18.3	1285	257	211	170	85	27	21	18	34	41	76	135	212
	CDH23.3	10349	2608	1851	1248	445	83	58	71	208	291	464	994	2028
CDH26.7	3927	1144	728	442	118	10	5	9	55	96	130	323	868	
Wind	WSAvg	2.6	2.2	2.2	2.2	2.3	2.1	2.4	2.7	3.2	3.3	3.1	2.7	2.5
Precipitation	PrecAvg	1466	141	154	157	154	110	77	80	66	98	143	144	136
	PrecMax	2067	430	433	356	488	310	201	278	218	316	353	392	379
	PrecMin	877	8	12	22	24	0	14	2	11	14	36	17	32
	PrecStd	292	93	103	79	119	73	49	64	45	57	83	78	85
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	36.4	35.1	32.3	28.0	27.5	27.8	31.0	33.2	32.8	34.2	37.0
		MCWB	24.5	24.3	24.5	24.4	22.0	21.7	20.4	21.1	22.7	22.5	22.9	24.3
	2%	DB	35.2	34.0	32.8	29.7	25.6	25.1	25.4	28.3	29.2	29.8	32.0	34.7
		MCWB	23.7	24.3	23.8	22.9	20.6	20.5	19.8	19.9	21.1	21.4	22.1	23.7
	5%	DB	33.5	32.3	30.9	27.7	23.8	23.1	22.9	25.6	26.5	27.7	30.2	32.9
		MCWB	23.5	23.7	23.2	22.0	19.8	19.9	18.8	19.0	19.8	20.5	21.3	23.2
	10%	DB	32.0	30.7	29.1	25.8	22.0	21.3	20.7	23.2	24.1	25.8	28.5	31.0
		MCWB	23.2	23.3	22.7	21.2	19.0	18.7	17.3	18.1	18.7	19.5	20.6	22.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	26.7	26.4	25.3	23.3	22.5	21.8	22.1	23.6	24.2	25.1	26.6
		MCDB	33.0	31.8	32.2	30.4	26.3	25.9	25.4	28.5	29.9	30.2	31.2	32.7
	2%	WB	25.9	25.8	25.4	24.1	21.9	21.4	20.2	20.7	22.0	22.9	23.6	25.7
		MCDB	31.5	31.3	30.2	28.1	24.2	24.1	24.3	26.5	27.6	27.7	29.0	31.3
	5%	WB	25.2	25.1	24.6	23.1	20.5	20.2	19.1	19.7	20.6	21.7	22.7	24.7
		MCDB	30.6	30.2	28.7	26.5	23.0	22.5	22.4	24.8	25.4	26.0	27.6	30.5
	10%	WB	24.5	24.4	23.8	22.0	19.4	19.0	17.8	18.5	19.3	20.6	21.8	23.8
		MCDB	29.7	29.0	27.6	24.6	21.6	21.2	20.6	22.6	23.5	24.4	26.3	29.3
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.4	9.6	8.4	8.2	8.4	8.9	10.1	9.8	9.5	10.3	10.3
		MCDBR	12.2	11.2	11.7	10.5	9.9	9.2	10.8	12.8	13.2	12.5	12.8	12.6
		MCWBR	3.7	3.6	4.4	4.5	5.2	5.0	5.5	5.7	5.9	5.5	5.0	4.3
	5% WB	MCDBR	9.2	9.6	9.5	8.5	7.7	8.2	9.5	11.3	11.2	10.3	9.8	10.3
		MCWBR	3.8	3.9	4.2	4.1	4.5	4.6	5.3	5.5	5.9	5.3	5.0	4.6
Clear-Sky Solar Irradiance	taub		0.407	0.401	0.392	0.391	0.370	0.376	0.384	0.465	0.513	0.460	0.401	0.414
	taud		2.374	2.398	2.406	2.364	2.401	2.376	2.317	2.046	1.934	2.154	2.345	2.332
	Ebn at Noon		935	921	896	840	808	773	781	749	766	856	934	931
	Edh at Noon		130	123	115	109	94	92	101	147	182	156	133	137
All-Sky Solar Radiation	RadAvg		6.92	6.18	5.34	4.02	2.95	2.51	2.83	3.61	4.49	5.49	6.70	7.03
	RadStd		0.64	0.43	0.45	0.54	0.29	0.25	0.30	0.32	0.49	0.65	0.75	0.49

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	+0.47	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page