

CONCORDIA, Argentina

WMO: 873950

Lat: 31.3022S

Lon: 58.0014W

Elev: 38

StdP: 100.87

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.2	3.0	-2.8	3.0	7.6	-1.0	3.5	7.5	11.5	14.6	10.1	15.1	0.2	230	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	35.2	23.2	33.8	23.0	32.3	22.6	26.0	31.5	25.1	30.6	24.4	29.4	4.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	19.4	28.9	23.6	18.5	28.1	22.9	17.7	27.2	80.7	31.5	77.1	30.7	73.9	29.4	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	9.4	8.2	-1.7	37.8	1.4	1.1	-2.8	38.6	-3.6	39.2	-4.4	39.8	-5.4	40.6
			-2.1	27.9	1.4	1.2	-3.2	28.7	-4.0	29.4	-4.8	30.1	-5.8	30.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	25.7	24.6	22.6	19.2	15.8	13.3	12.7	14.5	16.2	19.1	21.6	24.1
	DBStd	5.70	2.62	2.72	2.99	3.73	3.81	4.17	4.63	4.70	4.05	3.29	2.97	2.89
	HDD10.0	51	0	0	0	0	2	13	23	10	2	0	0	0
	HDD18.3	744	0	1	4	32	97	161	186	139	87	30	7	1
	CDD10.0	3367	487	409	389	277	182	112	106	150	188	281	348	437
	CDD18.3	1018	229	177	135	59	19	9	10	21	23	53	104	179
	CDH23.3	9123	2410	1608	1081	368	81	24	38	154	209	417	930	1803
Wind	WSAvg	2.8	2.8	2.7	2.4	2.3	2.1	2.4	2.6	3.1	3.6	3.5	3.3	3.1
	PrecAvg	1350	123	142	145	149	104	76	67	74	92	144	136	128
	PrecMax	2012	502	469	436	606	410	408	236	355	233	496	460	567
	PrecMin	530	7	7	25	15	1	2	4	0	7	12	4	21
	PrecStd	300	92	104	90	110	86	76	50	61	53	97	83	102
	DB	37.3	35.7	34.2	32.0	28.1	26.1	27.1	30.8	32.1	32.7	34.1	36.9	
	MCWB	23.6	24.1	24.4	23.3	21.1	21.0	19.9	20.8	22.3	23.2	22.0	23.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	35.5	33.8	32.1	29.2	25.4	23.2	24.0	27.5	28.0	29.7	31.9	34.7	
	2% MCWB	23.0	23.5	22.9	22.1	20.4	19.8	19.0	20.1	20.2	21.3	21.4	22.8	
	5% DB	33.8	32.2	30.3	27.2	23.5	21.3	21.6	24.8	25.5	27.4	30.1	32.9	
	5% MCWB	23.1	23.3	22.3	21.1	19.5	18.6	17.7	18.8	18.8	20.0	20.6	22.3	
	10% DB	32.1	30.7	28.8	25.2	21.6	19.8	19.6	22.2	23.1	25.5	28.3	31.0	
	10% MCWB	22.6	22.8	21.6	20.1	18.1	17.2	16.6	17.2	17.1	19.0	20.0	21.6	
	WB	26.7	26.8	26.5	24.8	23.1	21.9	21.1	22.0	23.2	24.6	25.1	26.7	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	32.4	32.1	31.9	29.7	26.7	24.8	25.2	28.1	29.0	31.2	30.7	33.1	
	2% WB	25.6	25.8	25.1	23.6	21.6	20.5	19.5	20.5	21.3	22.8	23.4	25.3	
	2% MCDB	31.5	31.0	29.8	27.6	24.2	22.6	23.0	26.2	26.7	27.1	28.7	31.0	
	5% WB	24.7	24.8	23.8	22.4	20.1	19.1	18.4	19.3	19.7	21.4	22.3	24.1	
	5% MCDB	30.3	29.8	27.9	25.6	22.6	21.1	21.3	24.1	24.2	25.6	27.0	29.6	
	10% WB	24.0	23.8	22.7	21.3	18.8	17.8	17.1	17.9	18.4	20.3	21.3	23.0	
	10% MCDB	29.3	28.3	26.8	23.9	21.0	19.6	19.3	21.5	21.8	24.1	25.8	28.2	
Mean Daily Temperature Range	MDBR	11.3	10.3	10.5	9.7	9.0	9.1	9.7	10.7	10.7	10.4	11.3	11.6	
	5% DB	13.6	12.5	12.6	11.8	10.8	9.3	10.6	13.1	13.9	13.2	14.1	14.5	
	5% MCWBR	4.8	4.8	5.4	5.6	6.0	6.1	6.0	6.5	6.8	6.3	5.7	5.6	
	5% WB	10.5	10.1	10.1	9.1	8.6	8.0	9.2	11.5	11.6	10.8	10.7	11.2	
	5% MCWBR	4.8	4.8	5.4	5.0	5.4	5.6	5.7	6.2	6.4	6.1	5.7	5.6	
	taub	0.415	0.404	0.388	0.384	0.365	0.376	0.374	0.449	0.498	0.445	0.401	0.409	
	taud	2.347	2.392	2.418	2.384	2.410	2.366	2.341	2.088	1.966	2.190	2.338	2.341	
Clear-Sky Solar Irradiance	Ebn at Noon	927	917	897	843	807	765	786	760	776	868	933	935	
	Edn at Noon	134	124	113	105	92	91	97	139	175	150	134	135	
	RadAvg	7.01	6.13	5.27	3.97	2.87	2.46	2.73	3.51	4.51	5.50	6.79	7.12	
All-Sky Solar Radiation	RadStd	0.61	0.43	0.46	0.51	0.27	0.25	0.28	0.32	0.45	0.64	0.63	0.49	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.47	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page