

MENDOZA, ArgentinaWMO: **874180**Lat: **32.8439S**Lon: **68.7964W**Elev: **2310**StdP: **13.51**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.5	33.8	12.1	11.1	56.9	17.1	14.2	55.4	18.7	57.0	15.9	55.1	1.4	270	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.8	96.6	67.6	93.6	67.4	91.5	66.8	73.0	88.3	71.4	87.1	70.0	85.2	8.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	113.2	81.1	66.4	105.9	79.8	64.7	99.6	78.3	38.4	88.6	36.8	86.5	35.5	85.6	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	14.6	12.6	DB	26.3	103.0	2.8	2.8	24.3	105.1	22.6	106.7	21.1	108.3	19.0	110.4	(4)
(5)			WB	24.5	76.1	2.3	2.1	22.8	77.6	21.5	78.8	20.2	80.0	18.5	81.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.7	78.7	75.6	70.7	62.5	55.0	49.0	47.9	52.5	58.3	65.7	72.0	76.9	(6)	
	DBStd	12.20	5.05	5.89	5.82	6.13	5.65	5.00	5.45	6.56	6.80	6.60	6.26	5.76	(7)	
	HDD50	260	0	0	0	3	19	74	104	46	13	1	0	0	(8)	
	HDD65	2157	1	4	18	117	310	481	531	389	215	71	16	4	(9)	
	CDD50	5255	889	718	643	377	175	44	37	125	264	489	661	833	(10)	
	CDD65	1677	425	302	196	41	1	0	0	3	15	94	228	372	(11)	
	CDH74	17912	4808	3110	1705	366	28	10	5	93	262	1009	2336	4180	(12)	
	CDH80	7633	2321	1378	586	64	1	1	0	22	56	318	934	1952	(13)	
(14) Wind	WSAvg	4.6	5.7	5.1	4.3	3.6	2.9	3.0	3.3	4.1	4.9	5.6	6.0	6.0	(14)	
(15) Precipitation	PrecAvg	8.0	1.6	1.4	1.2	0.5	0.3	0.2	0.2	0.2	0.4	0.4	0.7	1.1	(15)	
	PrecMax	16.3	5.5	5.6	5.8	3.5	1.5	1.2	1.7	1.3	1.4	3.1	3.1	7.5	(16)	
	PrecMin	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.2	1.4	1.5	1.2	0.7	0.4	0.3	0.3	0.3	0.4	0.6	0.7	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.6	98.4	93.0	85.8	77.2	74.4	72.8	82.8	85.9	92.1	95.9	99.6	(19)	
		MCWB	67.9	69.1	68.8	65.6	60.6	52.8	52.0	55.4	59.9	62.9	64.3	67.5	(20)	
	2%	DB	96.7	93.9	89.5	81.6	73.4	66.5	66.5	75.4	80.4	87.3	91.8	95.4	(21)	
		MCWB	68.5	68.7	67.7	62.7	58.4	51.2	50.3	54.2	56.7	61.8	64.5	66.8	(22)	
	5%	DB	93.5	91.3	86.2	78.5	70.0	63.1	63.4	70.4	76.7	83.2	89.0	93.0	(23)	
		MCWB	68.5	68.0	66.2	61.7	56.8	50.0	49.0	52.3	55.5	59.8	63.5	66.3	(24)	
	10%	DB	91.0	88.2	82.8	75.0	66.5	60.6	60.4	66.4	73.1	79.6	85.8	89.8	(25)	
		MCWB	67.7	67.5	65.5	60.2	55.0	48.9	47.4	50.4	54.3	58.3	62.1	65.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.8	75.6	72.8	68.1	63.4	55.7	55.3	58.6	62.3	67.3	70.1	73.7	(27)	
		MCDB	89.6	89.7	86.8	78.8	72.5	67.1	67.0	77.6	79.4	85.6	88.5	90.6	(28)	
	2%	WB	73.0	73.0	70.5	65.3	60.2	53.4	52.2	55.5	59.2	64.3	67.7	71.3	(29)	
		MCDB	89.0	86.8	83.4	76.8	70.0	62.8	63.9	72.4	75.9	82.2	85.1	88.7	(30)	
	5%	WB	71.3	71.1	68.6	63.4	58.3	51.6	50.0	53.2	57.0	61.9	65.8	69.5	(31)	
		MCDB	87.7	85.2	81.2	74.9	67.2	61.2	61.5	68.5	73.5	78.5	83.9	86.3	(32)	
	10%	WB	69.7	69.5	67.0	61.7	56.3	49.7	48.2	51.2	55.0	60.0	63.9	67.7	(33)	
		MCDB	85.7	83.6	79.8	72.6	64.8	58.7	58.8	64.9	70.3	76.3	81.5	84.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	21.1	20.1	20.0	19.5	21.3	22.3	23.1	22.7	22.1	22.3	22.2	(35)	
		MCDBR	26.1	26.0	25.4	25.7	25.3	26.2	27.7	30.0	30.3	28.1	27.7	26.7	(36)	
		MCWBR	9.3	9.5	10.0	11.5	12.9	14.1	14.6	14.4	13.5	11.7	11.1	10.1	(37)	
	5% WB	MCDBR	21.8	21.5	21.4	21.8	22.0	23.1	25.5	27.9	26.7	24.5	23.4	22.5	(38)	
		MCWBR	10.0	9.7	9.8	10.9	12.0	13.4	14.4	14.2	12.9	11.3	10.9	10.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.403	0.393	0.370	0.361	0.317	0.295	0.290	0.316	0.355	0.368	0.378	0.397	(40)	
	taud		2.331	2.365	2.426	2.409	2.494	2.556	2.526	2.444	2.331	2.322	2.319	2.308	(41)	
	Ebn at Noon		297	293	289	273	271	272	279	285	288	298	302	300	(42)	
	Edh at Noon		43	40	35	32	26	23	25	30	38	41	43	44	(43)	
(44) All-Sky Solar Radiation	RadAvg		2493	2206	1840	1397	992	870	946	1231	1627	2068	2451	2617	(44)	
	RadStd		142	134	112	128	113	75	73	102	129	174	150	142	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-3.64	+0.94	N/A	N/A	N/A	N/A	N/A	+113
(47) Regional (5 neighbors)	N/A	N/A	N/A	+0.95	N/A	N/A	N/A	N/A	+247	+167

Nomenclature: See separate page