

VILLA REYNOLDS, Argentina

WMO: 874480

Lat: 33.7181S

Lon: 65.3736W

Elev: 1594

StdP: 13.87

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.4	26.9	16.1	13.1	36.9	19.4	15.4	37.6	27.0	61.7	22.8	59.1	2.4	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	96.7	70.8	93.8	70.4	91.2	69.6	75.8	88.6	74.1	87.0	72.5	85.1	13.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.2	126.6	81.7	70.4	118.8	79.9	68.7	111.9	78.2	40.6	89.2	38.9	87.1	37.3	85.2	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.6	22.3	19.5	DB	17.2	103.1	3.1	2.8	14.9	105.1	13.1	106.8	11.3	108.3	9.1	110.4	(4)
(5)			WB	16.3	78.9	2.9	2.3	14.2	80.6	12.5	81.9	10.8	83.2	8.7	84.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	74.5	72.0	67.8	60.9	54.9	48.5	47.0	51.3	56.5	62.6	67.8	72.4
	DBStd	11.41	5.51	6.22	6.32	6.80	6.53	5.80	6.82	7.82	7.80	7.09	6.58	6.15
	HDD50	368	0	0	0	6	25	93	136	78	27	3	0	0
	HDD65	2482	4	14	45	155	322	495	558	431	271	132	44	11
	CDD50	4488	758	615	552	333	175	48	45	118	222	393	533	696
	CDD65	1125	297	209	132	32	7	0	1	6	16	57	126	242
	CDH74	14334	3413	2243	1482	499	133	13	35	200	487	1011	1803	3015
	CDH80	6324	1685	1027	592	128	27	0	5	64	157	387	788	1464
Wind	WSAvg	7.7	8.1	7.9	7.0	6.6	5.7	5.6	6.0	7.5	8.7	10.1	9.8	9.3
Precipitation	PrecAvg	27.9	4.3	3.9	3.5	2.2	1.1	0.5	0.6	0.7	1.3	2.6	3.5	4.4
	PrecMax	44.5	8.7	17.7	9.4	7.2	7.2	3.2	8.0	4.4	4.3	9.1	11.2	13.0
	PrecMin	16.1	1.4	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.8
	PrecStd	7.0	1.9	3.0	2.2	1.7	1.3	0.6	1.1	0.9	1.2	2.0	2.2	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.7	98.5	93.5	88.1	83.8	75.5	78.0	87.8	89.7	94.6	96.4	99.8
		MCWB	72.7	72.1	71.8	67.8	65.1	59.8	59.3	61.5	63.8	66.9	67.6	70.7
	2%	DB	96.2	94.0	90.0	83.7	77.4	70.0	72.2	79.1	84.5	89.1	92.4	96.2
		MCWB	72.1	72.5	70.1	65.5	62.8	56.1	55.6	58.8	60.5	64.4	67.5	70.3
	5%	DB	92.9	90.6	86.8	80.2	73.0	66.2	67.3	74.0	79.9	84.0	88.5	92.9
		MCWB	71.0	71.5	69.3	64.0	59.7	54.0	53.0	55.7	58.5	62.7	66.2	69.6
	10%	DB	89.3	86.6	83.2	75.9	68.4	62.1	62.4	68.7	74.9	79.6	84.5	88.6
		MCWB	70.6	70.7	68.1	62.9	58.0	51.6	50.4	53.7	56.8	61.1	64.8	68.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	78.7	76.2	71.9	66.9	61.7	62.7	65.2	66.4	71.0	72.3	76.5
		MCDB	89.9	89.7	88.7	80.6	77.2	72.0	74.4	83.1	85.1	85.2	88.0	90.6
	2%	WB	75.4	75.7	73.4	68.4	64.5	57.7	57.8	60.4	63.0	67.5	69.9	74.1
		MCDB	89.1	87.0	84.6	77.4	76.2	67.0	67.1	75.3	77.2	82.2	86.6	88.5
	5%	WB	73.6	73.7	71.1	66.4	61.8	55.2	54.6	57.4	60.3	65.2	68.0	71.9
		MCDB	87.7	85.2	81.8	74.8	69.9	63.2	63.5	70.7	75.3	79.2	83.4	86.0
	10%	WB	72.0	72.0	69.3	64.4	59.1	53.1	52.0	54.5	58.0	63.0	66.2	70.0
		MCDB	85.2	83.0	79.7	73.4	65.4	60.0	60.6	66.6	71.9	75.6	80.7	84.3
Mean Daily Temperature Range	5% DB	MDBR	25.4	24.7	24.5	24.2	24.1	26.2	27.8	29.0	29.7	26.3	26.5	26.3
		MCDBR	32.1	31.7	31.4	32.9	31.5	33.7	37.3	38.1	38.9	35.8	33.9	33.5
		MCWBR	12.6	13.2	13.9	16.6	17.6	20.5	22.0	20.3	19.2	16.1	14.5	13.3
	5% WB	MCDBR	26.2	25.6	25.4	24.1	26.3	29.5	31.2	33.6	32.1	29.1	28.8	26.7
		MCWBR	12.3	12.6	12.6	13.5	15.3	18.6	19.6	19.0	17.3	14.6	13.9	12.9
Clear-Sky Solar Irradiance	taub	0.381	0.377	0.363	0.352	0.327	0.310	0.319	0.349	0.397	0.383	0.375	0.380	
	taud	2.394	2.408	2.447	2.448	2.464	2.515	2.444	2.345	2.204	2.307	2.361	2.377	
	Ebn at Noon	303	298	290	275	265	263	265	271	274	292	303	305	
	Edh at Noon	40	38	34	30	27	23	27	33	43	42	41	41	
All-Sky Solar Radiation	RadAvg	2371	2057	1692	1241	905	850	913	1204	1571	1899	2264	2437	
	RadStd	133	149	151	141	105	82	68	98	134	181	143	149	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+1.01	+1.12	+1.40	N/A	N/A	N/A	N/A

Nomenclature: See separate page