

VILLA REYNOLDS, Argentina

WMO: 874480

Lat: 33.7181S

Lon: 65.3736W

Elev: 486

StdP: 95.62

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-4.8	-2.8	-8.8	1.9	2.7	-7.0	2.2	3.1	12.1	16.5	10.2	15.1	1.1	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	35.9	21.6	34.3	21.3	32.9	20.9	24.3	31.5	23.4	30.6	22.5	29.5	6.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	18.1	27.6	21.3	17.0	26.6	20.4	16.0	25.7	76.6	31.8	72.6	30.6	69.0	29.6	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	10.0	8.7	-8.2	39.5	1.7	1.6	-9.5	40.6	-10.5	41.5	-11.5	42.4	-12.7	43.6		
			-8.7	26.1	1.6	1.3	-9.9	27.0	-10.8	27.7	-11.8	28.5	-12.9	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	23.6	22.2	19.9	16.1	12.7	9.2	8.4	10.7	13.6	17.0	19.9	22.5	
	DBStd	6.34	3.06	3.46	3.51	3.78	3.63	3.22	3.79	4.35	4.34	3.94	3.66	3.42	
	HDD10.0	204	0	0	0	3	14	52	76	43	15	2	0	0	
	HDD18.3	1379	2	8	25	86	179	275	310	239	151	73	24	6	
	CDD10.0	2493	421	342	307	185	97	27	25	66	123	218	296	387	
	CDD18.3	625	165	116	73	18	4	0	1	3	9	32	70	134	
	CDH23.3	7963	1896	1246	823	277	74	7	19	111	271	562	1002	1675	
	CDH26.7	3513	936	571	329	71	15	0	3	36	87	215	438	813	
Wind	WSAvg	3.4	3.6	3.5	3.1	2.9	2.6	2.5	2.7	3.3	3.9	4.5	4.4	4.1	
Precipitation	PrecAvg	708	110	100	90	56	29	12	14	17	33	66	89	111	
	PrecMax	1130	222	450	239	184	184	81	202	111	109	230	285	331	
	PrecMin	410	35	14	0	0	0	0	0	0	0	1	8	20	
	PrecStd	179	48	76	57	42	33	16	28	23	30	50	55	64	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	36.9	34.2	31.2	28.8	24.2	25.6	31.0	32.1	34.8	35.8	37.6	
		MCWB	22.6	22.3	22.1	19.9	18.4	15.5	15.2	16.4	17.6	19.4	19.8	21.5	
	2%	DB	35.7	34.4	32.2	28.7	25.2	21.1	22.3	26.2	29.2	31.7	33.5	35.7	
		MCWB	22.3	22.5	21.2	18.6	17.1	13.4	13.1	14.9	15.8	18.0	19.7	21.3	
	5%	DB	33.8	32.5	30.5	26.8	22.8	19.0	19.6	23.4	26.6	28.9	31.4	33.8	
		MCWB	21.7	21.9	20.7	17.8	15.4	12.2	11.7	13.2	14.7	17.0	19.0	20.9	
	10%	DB	31.8	30.3	28.5	24.4	20.2	16.7	16.9	20.4	23.8	26.4	29.2	31.5	
		MCWB	21.4	21.5	20.0	17.2	14.4	10.9	10.2	12.0	13.8	16.2	18.2	20.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	25.9	24.6	22.2	19.4	16.5	17.1	18.4	19.1	21.7	22.4	24.7
			MCDB	32.2	32.0	31.5	27.0	25.1	22.2	23.5	28.4	29.5	29.5	31.1	32.5
2%		WB	24.1	24.3	23.0	20.2	18.1	14.3	14.3	15.8	17.2	19.7	21.1	23.4	
		MCDB	31.7	30.6	29.2	25.2	24.5	19.5	19.5	24.1	25.1	27.9	30.3	31.4	
5%		WB	23.1	23.2	21.7	19.1	16.6	12.9	12.5	14.1	15.7	18.5	20.0	22.2	
		MCDB	30.9	29.6	27.6	23.8	21.1	17.3	17.5	21.5	24.1	26.2	28.6	30.0	
10%		WB	22.2	22.2	20.7	18.0	15.0	11.7	11.1	12.5	14.5	17.2	19.0	21.1	
		MCDB	29.6	28.4	26.5	23.0	18.6	15.6	15.9	19.2	22.2	24.2	27.1	29.1	
Mean Daily Temperature Range		5% DB	MDBR	14.1	13.7	13.6	13.4	13.4	14.5	15.5	16.1	16.5	14.6	14.7	14.6
			MCDBR	17.8	17.6	17.4	18.3	17.5	18.7	20.7	21.1	21.6	19.9	18.9	18.6
	MCWBR		7.0	7.3	7.7	9.2	9.8	11.4	12.2	11.3	10.6	8.9	8.1	7.4	
	5% WB	MCDBR	14.6	14.2	14.1	13.4	14.6	16.4	17.3	18.7	17.9	16.2	16.0	14.8	
		MCWBR	6.9	7.0	7.0	7.5	8.5	10.3	10.9	10.5	9.6	8.1	7.7	7.2	
Clear-Sky Solar Irradiance	taub	0.381	0.377	0.363	0.352	0.327	0.310	0.319	0.349	0.397	0.383	0.375	0.380		
	taud	2.394	2.408	2.447	2.448	2.464	2.515	2.444	2.345	2.204	2.307	2.361	2.377		
	Ebn at Noon	956	939	915	867	836	830	835	854	863	922	956	961		
	Edh at Noon	127	121	108	96	84	74	84	104	135	132	130	130		
All-Sky Solar Radiation	RadAvg	7.48	6.49	5.33	3.91	2.85	2.68	2.88	3.80	4.95	5.99	7.14	7.68		
	RadStd	0.42	0.47	0.48	0.45	0.33	0.26	0.21	0.31	0.42	0.57	0.45	0.47		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)		N/A	N/A	N/A	+0.56	+0.62	+0.78	N/A	N/A	N/A	N/A

Nomenclature: See separate page