

LABOULAYE, Argentina

WMO: 875340

Lat: 34.1278S

Lon: 63.3675W

Elev: 449

StdP: 14.46

Time Zone: -3.00 (W03)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.2	32.1	16.9	13.1	47.9	20.3	15.5	45.0	29.9	55.6	26.4	59.6	1.3	230	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	94.3	71.2	91.5	70.6	88.8	70.1	77.0	86.5	75.2	84.7	73.5	83.0	12.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.2	129.9	82.5	72.3	121.5	80.4	70.6	114.7	78.5	40.8	86.2	39.1	84.4	37.5	82.9	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.3	24.7	21.6	DB	23.8	100.5	3.3	3.6	21.4	103.1	19.4	105.3	17.6	107.3	15.2	109.9	(4)
(5)			WB	22.7	80.3	2.9	1.9	20.7	81.7	19.0	82.8	17.4	83.9	15.3	85.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	74.7	72.8	68.8	62.9	55.9	49.9	48.9	52.2	57.4	62.9	69.1	73.0	(6)
(7)		DBStd	10.84	5.31	5.57	5.92	6.78	6.50	5.08	6.12	6.85	6.69	6.09	6.10	5.60	(7)
(8)		HDD50	244	0	0	0	3	19	62	94	52	13	1	0	0	(8)
(9)		HDD65	2189	3	7	30	117	292	452	499	401	240	111	30	7	(9)
(10)		CDD50	4739	766	638	583	389	200	59	60	121	236	402	573	712	(10)
(11)		CDD65	1212	304	224	148	53	9	0	1	5	14	47	153	254	(11)
(12)		CDH74	11697	2994	1909	1188	458	51	2	8	85	241	579	1582	2600	(12)
(13)		CDH80	4565	1314	735	390	101	3	0	1	26	58	175	618	1144	(13)
(14)	Wind	WSAvg	6.6	6.9	5.4	5.5	5.3	5.0	4.7	5.4	7.2	8.2	8.9	8.5	7.6	(14)
(15)	Precipitation	PrecAvg	33.7	4.7	4.1	5.2	3.1	1.3	0.7	0.6	0.7	1.7	3.5	4.3	4.8	(15)
(16)		PrecMax	54.6	13.0	14.0	16.4	10.2	6.9	3.6	4.3	4.2	6.6	9.1	9.7	14.8	(16)
(17)		PrecMin	21.3	0.2	0.7	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.3	1.0	0.4	(17)
(18)		PrecStd	7.6	2.6	2.8	3.1	2.2	1.3	0.9	0.7	1.0	1.4	2.3	2.2	2.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.8	95.1	91.9	87.0	79.3	71.0	72.0	83.3	86.2	90.6	95.0	98.1	(19)
MCWB			70.7	73.9	72.2	67.6	65.4	58.2	60.1	63.3	63.3	67.0	68.7	70.7	(20)	
2%		DB	94.1	90.9	87.6	82.8	74.2	66.5	66.8	74.3	80.3	85.1	90.7	93.5	(21)	
		MCWB	72.6	73.5	72.1	66.6	62.8	56.4	55.1	59.0	61.3	65.5	67.0	69.8	(22)	
5%		DB	90.7	87.9	84.4	79.6	70.1	63.5	63.2	69.0	75.9	80.0	86.9	90.1	(23)	
		MCWB	71.9	72.6	69.7	65.4	60.5	54.2	53.5	54.9	58.6	62.7	66.1	69.0	(24)	
10%		DB	87.6	84.4	81.0	75.7	66.4	60.5	60.0	64.8	72.0	76.1	82.9	86.4	(25)	
		MCWB	71.2	71.1	68.4	64.2	59.0	52.1	52.3	53.0	56.8	60.9	64.7	67.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	79.1	77.4	73.8	68.3	63.8	62.7	66.2	68.0	71.5	72.9	77.7	(27)
MCD B			88.7	89.0	86.5	79.9	74.3	67.3	69.0	74.5	80.0	85.6	85.0	89.0	(28)	
2%		WB	76.9	76.6	74.5	70.6	65.5	59.6	59.3	62.1	63.8	68.1	70.3	74.4	(29)	
		MCD B	86.8	85.3	82.3	77.8	71.1	63.0	63.0	69.7	74.7	79.2	83.0	85.3	(30)	
5%		WB	75.0	74.7	72.3	68.0	62.8	56.3	56.7	58.9	61.1	65.8	68.6	72.4	(31)	
		MCD B	86.0	83.2	80.4	74.4	68.1	61.0	60.7	64.9	70.6	75.3	81.1	83.7	(32)	
10%		WB	73.1	73.2	70.3	65.8	60.2	53.7	53.8	55.2	58.8	63.5	66.8	70.5	(33)	
		MCD B	83.1	81.6	77.4	73.4	65.0	58.8	58.2	63.5	68.8	72.9	78.7	81.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.7	20.2	20.6	20.6	19.2	20.7	20.4	22.9	23.8	21.7	23.2	23.0	(35)
MCDBR			27.3	24.8	25.4	27.0	24.1	25.1	25.3	29.4	31.3	29.3	30.1	29.1	(36)	
MCWBR			10.1	9.9	11.0	12.8	13.1	15.0	15.3	15.5	15.3	13.5	11.3	10.3	(37)	
5% WB		MCDBR	21.5	20.4	20.8	20.7	17.3	20.0	19.0	23.7	25.1	23.6	24.3	22.6	(38)	
		MCWBR	10.5	9.6	10.5	11.3	10.3	13.7	13.2	14.1	13.8	12.8	10.7	10.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.403	0.390	0.377	0.365	0.347	0.324	0.335	0.375	0.423	0.403	0.393	0.395	(40)	
taud		2.342	2.382	2.417	2.422	2.422	2.484	2.422	2.281	2.147	2.267	2.326	2.343	(41)		
Ebn at Noon		297	293	285	270	257	257	258	261	265	286	298	300	(42)		
Edh at Noon		43	39	35	31	28	24	27	35	45	43	43	43	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2337	2013	1670	1205	851	773	823	1118	1485	1803	2198	2392	(44)	
(45)		RadStd	147	160	135	146	94	93	80	109	127	166	131	160	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	+0.90	+1.31	N/A	N/A	N/A	N/A

Nomenclature: See separate page