

JUNIN, Argentina

WMO: 875480

Lat: 34.5525S

Lon: 60.9314W

Elev: 266

StdP: 14.56

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	32.6	21.4	16.2	44.5	24.2	18.5	41.6	29.6	57.7	26.9	57.6	1.8	0	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	92.3	71.5	89.9	71.0	87.5	70.2	76.6	86.2	74.7	84.5	73.0	82.5	12.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.7	126.6	82.1	71.7	118.4	79.7	70.1	111.7	78.0	40.3	86.0	38.5	84.7	36.9	82.6	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.0	23.8	21.1	DB	24.4	97.8	2.4	3.0	22.6	99.9	21.2	101.6	19.9	103.3	18.2	105.5	(4)
(5)			WB	23.3	79.9	2.4	2.2	21.6	81.5	20.2	82.8	18.9	84.0	17.1	85.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	73.6	71.6	68.0	62.3	56.2	50.3	49.1	52.6	56.5	61.7	67.5	71.8		
	DBStd	10.34	4.84	5.32	5.64	6.30	6.62	6.13	6.59	7.38	6.43	5.67	5.85	5.50		
	HDD50	247	0	0	0	2	16	67	95	52	14	1	0	0		
	HDD65	2236	3	9	35	124	286	442	493	394	265	135	40	10		
	CDD50	4519	730	605	559	369	207	77	69	132	209	362	524	676		
	CDD65	1034	268	194	129	41	12	2	2	9	10	31	115	221		
	CDH74	9843	2584	1630	1090	345	59	2	9	80	138	356	1236	2314		
	CDH80	3545	1041	580	328	69	6	0	1	20	34	86	432	948		
(14) Wind	WSAvg	8.2	7.6	6.8	7.1	6.9	7.1	7.4	8.0	9.1	9.8	9.8	9.8	9.0		
(15) Precipitation	PrecAvg	40.2	5.0	4.4	5.7	3.9	2.4	1.1	1.3	1.5	2.2	4.7	4.3	4.3		
	PrecMax	61.1	11.0	13.3	15.2	13.6	12.1	4.4	5.0	7.8	6.1	13.4	9.4	12.2		
	PrecMin	27.4	1.1	0.7	0.5	0.0	0.0	0.0	0.0	0.0	0.3	1.0	0.3	0.0		
	PrecStd	8.3	2.6	2.9	3.9	2.7	2.1	1.0	1.1	1.6	1.5	2.6	2.3	2.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.0	92.8	90.7	86.4	79.3	72.3	73.8	82.3	84.5	88.1	92.9	95.6		
		MCWB	72.4	74.4	71.0	71.0	66.7	65.6	63.7	66.7	66.1	67.5	69.1	71.7		
	2%	DB	91.7	89.7	86.8	81.5	75.0	67.4	67.6	74.6	77.4	81.8	88.5	92.0		
		MCWB	72.6	74.2	71.1	67.0	63.9	61.2	58.7	61.7	61.4	65.7	67.3	70.1		
	5%	DB	88.9	86.8	83.6	78.0	70.7	63.9	63.9	69.4	73.3	77.7	85.2	89.1		
		MCWB	72.0	72.4	69.6	65.2	62.0	57.5	56.6	58.6	59.0	63.3	65.7	69.2		
	10%	DB	86.0	83.6	80.4	74.3	67.0	60.8	60.7	65.3	69.5	73.9	81.4	85.7		
		MCWB	70.9	70.8	67.8	63.6	59.9	54.9	54.4	55.5	57.0	61.1	64.6	68.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	79.0	77.0	73.8	69.5	67.0	64.8	68.5	69.6	71.9	73.2	77.2		
		MCDB	87.2	88.8	84.7	81.7	75.8	70.7	70.8	77.0	81.3	82.1	84.6	87.2		
	2%	WB	76.4	76.4	73.7	70.7	66.6	63.5	61.6	64.5	64.5	68.0	70.2	74.2		
		MCDB	86.8	85.6	82.0	77.6	72.1	66.5	65.9	72.8	72.9	76.9	82.3	86.0		
	5%	WB	74.5	74.3	71.3	68.0	63.9	59.8	58.8	61.0	61.5	65.6	68.4	72.1		
		MCDB	84.8	83.0	80.3	74.2	68.8	62.2	62.0	66.8	69.2	73.9	79.7	82.9		
	10%	WB	72.8	72.4	69.3	65.5	61.4	56.4	55.5	57.5	59.0	63.5	66.6	70.2		
		MCDB	82.4	80.3	77.4	71.6	65.6	59.6	59.1	63.3	66.9	71.1	76.9	80.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	20.0	20.8	19.8	18.1	18.3	18.8	20.6	21.2	19.8	22.2	22.8		
		MCDBR	26.3	24.3	25.2	25.7	22.5	20.9	23.1	26.0	28.1	27.1	28.8	28.3		
	5% WB	MCWBR	11.1	10.7	11.5	12.4	12.2	13.4	14.4	14.3	14.1	13.1	11.2	10.6		
		MCWBR	22.3	20.3	21.3	19.5	17.1	14.6	16.6	20.9	21.7	21.5	23.0	22.1		
(40) Clear-Sky Solar Irradiance	taub		0.421	0.398	0.375	0.370	0.354	0.344	0.345	0.399	0.453	0.413	0.394	0.405		
		taud	2.285	2.362	2.424	2.401	2.410	2.426	2.408	2.216	2.061	2.246	2.328	2.313		
	Ebn at Noon		291	291	285	267	253	247	253	252	256	283	297	297		
		Edh at Noon	45	40	35	32	28	26	27	37	49	44	43	44		
(44) All-Sky Solar Radiation	RadAvg		2283	1998	1652	1203	851	730	777	1068	1435	1765	2154	2370		
	RadStd		146	174	131	133	79	83	79	108	112	163	126	134		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.22	+1.01	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	+0.79	+1.04	+1.01	N/A	N/A	N/A	N/A

Nomenclature: See separate page