

JUNIN, Argentina

WMO: 875480

Lat: 34.5525S

Lon: 60.9314W

Elev: 81

StdP: 100.36

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.2	0.3	-5.9	2.3	6.9	-4.3	2.6	5.3	13.2	14.3	12.0	14.2	0.8	0	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	33.5	21.9	32.1	21.7	30.8	21.2	24.8	30.1	23.7	29.2	22.8	28.0	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.1	27.9	22.1	16.9	26.5	21.1	16.0	25.5	75.9	30.0	71.6	29.3	68.0	28.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.7	9.4	-4.2	36.5	1.3	1.7	-5.2	37.7	-6.0	38.7	-6.7	39.6	-7.7	40.8		
(5)			-4.8	26.6	1.3	1.2	-5.8	27.5	-6.6	28.2	-7.3	28.9	-8.3	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	23.1	22.0	20.0	16.8	13.4	10.2	9.5	11.4	13.6	16.5	19.7	22.1		
	DBStd	5.75	2.69	2.95	3.13	3.50	3.68	3.40	3.66	4.10	3.57	3.15	3.25	3.06		
	HDD10.0	137	0	0	0	1	9	37	53	29	8	1	0	0		
	HDD18.3	1242	2	5	19	69	159	246	274	219	147	75	22	6		
	CDD10.0	2511	406	336	311	205	115	43	38	73	116	201	291	376		
	CDD18.3	574	149	108	72	23	7	1	1	5	6	17	64	123		
	CDH23.3	5468	1436	906	606	192	33	1	5	44	77	198	687	1286		
	CDH26.7	1969	578	322	182	38	3	0	1	11	19	48	240	527		
(14) Wind	WSAvg	3.7	3.4	3.1	3.2	3.1	3.2	3.3	3.6	4.1	4.4	4.4	4.4	4.0		
(15) Precipitation	PrecAvg	1021	127	111	145	99	61	29	34	38	55	119	108	109		
	PrecMax	1551	279	337	387	345	307	111	127	199	156	340	240	311		
	PrecMin	695	28	19	12	0	0	0	0	0	7	25	8	1		
	PrecStd	210	67	73	99	69	53	26	29	41	38	67	59	74		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	33.8	32.6	30.2	26.3	22.4	23.2	28.0	29.2	31.2	33.8	35.3		
		MCWB	22.4	23.6	21.7	21.7	19.3	18.7	17.6	19.3	18.9	19.7	20.6	22.1		
	2%	DB	33.2	32.1	30.5	27.5	23.9	19.7	19.8	23.7	25.2	27.7	31.4	33.3		
		MCWB	22.6	23.4	21.7	19.5	17.7	16.2	14.8	16.5	16.3	18.7	19.6	21.2		
	5%	DB	31.6	30.4	28.7	25.6	21.5	17.7	17.7	20.8	22.9	25.4	29.5	31.7		
		MCWB	22.2	22.5	20.9	18.4	16.7	14.1	13.7	14.8	15.0	17.4	18.7	20.7		
	10%	DB	30.0	28.7	26.9	23.5	19.5	16.0	16.0	18.5	20.8	23.3	27.4	29.8		
		MCWB	21.6	21.6	19.9	17.5	15.5	12.7	12.5	13.1	13.9	16.2	18.1	20.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.1	25.0	23.2	20.8	19.5	18.2	20.3	20.9	22.1	22.9	25.1		
		MCDB	30.6	31.6	29.3	27.6	24.3	21.5	21.6	25.0	27.4	27.8	29.2	30.7		
	2%	WB	24.7	24.7	23.1	21.5	19.2	17.5	16.4	18.1	18.1	20.0	21.2	23.5		
		MCDB	30.5	29.8	27.8	25.3	22.3	19.2	18.8	22.6	22.7	24.9	28.0	30.0		
	5%	WB	23.6	23.5	21.8	20.0	17.7	15.4	14.9	16.1	16.4	18.7	20.2	22.3		
		MCDB	29.4	28.3	26.9	23.4	20.4	16.8	16.6	19.3	20.7	23.3	26.5	28.3		
	10%	WB	22.6	22.4	20.7	18.6	16.3	13.5	13.1	14.2	15.0	17.5	19.2	21.2		
		MCDB	28.0	26.9	25.2	22.0	18.7	15.3	15.1	17.4	19.4	21.7	24.9	27.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	11.1	11.5	11.0	10.0	10.2	10.5	11.4	11.8	11.0	12.3	12.7		
		MCDBR	14.6	13.5	14.0	14.3	12.5	11.6	12.8	14.4	15.6	15.0	16.0	15.7		
		MCWBR	6.2	5.9	6.4	6.9	6.8	7.4	8.0	8.0	7.8	7.3	6.2	5.9		
	5% WB	MCDBR	12.4	11.3	11.8	10.9	9.5	8.1	9.2	11.6	12.0	12.0	12.8	12.3		
		MCWBR	6.4	5.9	6.3	6.4	5.9	6.7	6.9	7.3	7.1	6.9	6.4	5.9		
(40) Clear-Sky Solar Irradiance	taub		0.421	0.398	0.375	0.370	0.354	0.344	0.345	0.399	0.453	0.413	0.394	0.405		
	taud		2.285	2.362	2.424	2.401	2.410	2.426	2.408	2.216	2.061	2.246	2.328	2.313		
	Ebn at Noon		917	917	900	842	799	779	799	795	806	891	936	936		
	Edh at Noon		141	126	110	100	87	81	86	118	156	140	134	138		
(44) All-Sky Solar Radiation	RadAvg		7.20	6.30	5.21	3.79	2.68	2.30	2.45	3.37	4.52	5.57	6.79	7.47		
	RadStd		0.46	0.55	0.41	0.42	0.25	0.26	0.25	0.34	0.35	0.52	0.40	0.42		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.68	+0.56	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.44	+0.58	+0.56	N/A	N/A	N/A	N/A

Nomenclature: See separate page