

BUENOS AIRES SAN FERNANDO, Argentina

WMO: 875530

Lat: 34.4550S

Lon: 58.5844W

Elev: 33

StdP: 14.68

Time Zone: -3.00 (W03)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.2	37.4	26.7	20.7	44.1	29.9	24.0	45.5	20.4	52.5	18.5	52.1	2.5	230	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.8	91.6	73.8	89.4	73.4	86.9	72.5	77.5	86.5	76.1	84.8	74.8	83.2	10.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.1	131.8	82.8	73.4	124.5	81.0	71.9	118.0	79.5	41.0	87.9	39.5	84.4	38.2	83.6	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.0	16.8	15.1	DB	30.0	97.1	1.8	2.4	28.7	98.8	27.6	100.2	26.6	101.5	25.4	103.2
			WB	28.6	80.8	1.3	1.5	27.6	81.9	26.9	82.8	26.2	83.7	25.3	84.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	76.3	74.3	70.1	64.6	58.5	52.6	51.5	54.7	58.1	63.2	69.3	73.3	(6)
(7)		DBStd	10.20	4.74	5.04	5.63	6.23	5.63	5.91	6.23	7.14	5.83	5.63	5.25	5.74	(7)
(8)		HDD50	129	0	0	0	1	3	36	55	28	6	0	0	0	(8)
(9)		HDD65	1788	1	2	20	80	212	375	422	331	218	102	19	6	(9)
(10)		CDD50	5172	816	680	623	438	267	113	101	175	249	410	578	722	(10)
(11)		CDD65	1355	351	262	178	67	12	3	3	13	10	46	147	263	(11)
(12)		CDH74	10665	3234	2049	1165	294	30	5	10	105	85	276	1063	2349	(12)
(13)		CDH80	3377	1161	647	259	55	0	0	0	28	17	55	299	856	(13)
(14)	Wind	WSAvg	7.1	7.8	7.3	6.8	5.9	5.7	5.8	6.4	7.0	8.0	8.0	8.3	7.9	(14)
(15)	Precipitation	PrecAvg	44.4	4.7	5.0	4.4	4.3	3.0	2.2	2.4	2.5	2.6	4.6	4.6	4.1	(15)
(16)		PrecMax	70.0	9.6	11.7	13.2	7.8	11.7	4.7	6.2	8.6	7.0	10.7	9.4	10.5	(16)
(17)		PrecMin	26.8	1.3	1.4	0.9	0.6	0.1	0.2	0.4	0.1	0.7	1.2	0.7	1.0	(17)
(18)		PrecStd	9.4	2.2	3.0	2.8	2.2	2.4	1.4	1.4	2.2	1.7	2.5	2.3	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.3	92.9	89.2	86.2	77.3	73.5	75.0	84.3	80.9	86.1	91.1	95.4	(19)
(20)			MCWB	76.2	75.9	73.5	73.1	67.2	66.3	65.5	69.9	67.5	70.0	72.3	72.9	(20)
(21)		2%	DB	91.5	89.6	85.8	80.5	73.4	68.3	68.2	75.6	75.5	80.6	86.4	91.4	(21)
(22)			MCWB	74.5	75.2	72.5	68.6	64.6	61.4	60.2	65.3	62.9	67.3	70.9	72.4	(22)
(23)		5%	DB	89.3	87.3	82.6	77.1	70.1	65.9	64.3	69.9	71.6	76.9	83.8	88.0	(23)
(24)			MCWB	73.8	73.9	70.4	67.8	63.5	60.0	58.3	61.3	60.6	64.9	68.8	71.3	(24)
(25)		10%	DB	86.2	84.2	80.2	73.8	67.8	62.6	61.0	66.1	68.2	73.4	80.4	84.5	(25)
(26)			MCWB	72.7	72.9	70.8	66.1	62.2	57.2	55.8	58.8	58.4	63.3	67.6	70.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	79.4	77.4	74.4	69.2	67.3	65.0	70.4	69.8	74.1	75.3	78.3	(27)
(28)			MCDWB	90.0	87.9	84.0	83.8	74.3	70.8	70.9	81.7	77.7	83.8	85.4	87.0	(28)
(29)		2%	WB	77.6	77.2	75.2	71.8	66.8	64.1	62.5	66.9	65.5	69.9	73.0	76.0	(29)
(30)			MCDWB	87.6	85.6	81.4	77.2	71.0	67.6	66.9	75.2	72.3	77.3	82.3	85.8	(30)
(31)		5%	WB	75.9	75.6	73.4	69.9	64.9	61.2	59.5	63.5	63.2	67.3	71.1	74.4	(31)
(32)			MCDWB	85.3	83.6	79.5	74.6	68.9	64.1	63.1	68.1	68.8	73.4	80.5	83.7	(32)
(33)		10%	WB	74.5	74.2	71.8	68.1	63.2	58.3	57.2	60.2	60.9	65.3	69.3	72.6	(33)
(34)			MCDWB	83.2	81.4	78.1	72.9	67.0	61.9	60.6	64.4	66.5	71.6	77.4	81.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.8	15.8	16.5	15.8	14.4	16.2	15.3	16.7	15.8	15.5	17.4	17.9	(35)
(36)			MCDBR	21.1	19.5	19.0	19.8	17.4	18.1	19.3	20.8	21.4	20.8	22.9	23.2	(36)
(37)			MCWBR	9.6	9.3	9.4	10.6	10.2	12.2	12.4	12.5	12.3	11.1	11.0	10.6	(37)
(38)		5% WB	MCDBR	17.8	16.8	16.0	15.4	13.5	13.5	14.9	17.9	16.5	16.8	18.6	18.3	(38)
(39)			MCWBR	9.7	9.2	9.0	9.4	9.1	11.4	11.1	12.5	11.3	10.6	10.7	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.412	0.396	0.375	0.378	0.368	0.370	0.364	0.434	0.461	0.420	0.398	0.400	(40)	
(41)		taud	2.360	2.424	2.469	2.410	2.405	2.382	2.384	2.138	2.077	2.261	2.353	2.371	(41)	
(42)		Ebn at Noon	294	292	286	265	248	237	247	241	253	281	296	298	(42)	
(43)		Edh at Noon	42	37	34	32	28	27	28	41	49	44	42	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2283	1995	1675	1211	851	716	750	1019	1389	1758	2129	2375	(44)	
(45)		RadStd	131	178	152	143	74	76	87	104	96	162	141	118	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.49	N/A	N/A	+1.08	+0.72	+0.72	N/A	N/A	+148	+76

Nomenclature: See separate page