

BUENOS AIRES EZEIZA, Argentina

WMO: 875760

Lat: 34.8186S

Lon: 58.5422W

Elev: 20

StdP: 101.08

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.0	1.7	-3.9	2.7	5.3	-2.2	3.1	5.9	10.0	12.6	9.0	12.3	1.6	270	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	33.9	22.5	32.3	22.1	31.1	21.7	24.7	30.4	23.9	29.4	23.1	28.3	4.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	17.9	27.5	22.1	16.9	26.4	21.5	16.2	25.8	75.2	30.4	71.8	29.4	68.9	28.5	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.2	7.3		-2.8	37.0	1.2	1.4	-3.7	38.0	-4.4	38.8	-5.0	39.6	-5.9	40.6	
			DB	-3.4	26.6	1.2	0.9	-4.3	27.2	-5.0	27.8	-5.7	28.3	-6.5	28.9	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	24.0	22.9	20.8	17.2	13.9	11.0	10.3	12.0	13.7	16.7	19.8	22.6
	DBStd	5.92	3.13	3.24	3.38	3.60	3.84	3.66	3.92	4.23	3.68	3.40	3.64	3.49
	HDD10.0	116	0	0	0	1	8	29	44	25	9	1	0	0
	HDD18.3	1155	2	4	16	62	147	222	251	203	145	73	25	7
	CDD10.0	2688	433	363	334	218	128	59	54	87	120	207	294	390
	CDD18.3	684	177	133	91	29	8	2	2	6	6	21	70	138
	CDH23.3	6263	1808	1211	709	175	32	3	8	51	47	168	636	1416
	CDH26.7	2232	746	441	199	30	3	0	1	11	7	34	196	564
(14) Wind	WSAvg	3.5	3.7	3.5	3.2	3.1	2.9	3.1	3.3	3.5	3.9	3.8	3.8	3.7
(15) Precipitation	PrecAvg	978	95	103	103	89	72	47	60	56	62	103	98	96
	PrecMax	1495	257	325	458	211	305	128	171	195	184	362	214	287
	PrecMin	630	4	18	5	2	1	0	8	0	5	14	7	15
	PrecStd	197	62	66	78	55	65	35	36	48	41	67	59	59
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.0	34.5	32.7	30.0	26.6	23.1	24.1	28.1	27.2	30.1	33.1	35.7
		MCWB	23.4	23.5	22.5	21.9	20.0	19.5	18.4	20.4	19.1	20.0	21.5	22.6
	2%	DB	34.0	32.8	30.8	27.1	23.8	20.6	20.5	24.1	24.3	27.1	30.8	33.5
		MCWB	22.6	23.2	21.9	19.9	18.4	17.0	16.3	17.7	17.0	18.7	20.5	21.7
	5%	DB	32.3	31.1	28.9	25.2	21.8	18.8	18.2	21.1	22.2	25.0	29.0	31.8
		MCWB	22.2	22.6	21.3	19.4	17.6	15.4	14.5	15.7	15.6	17.9	19.4	21.1
	10%	DB	30.8	29.4	27.2	23.6	20.0	17.0	16.6	18.9	20.2	23.1	27.1	30.0
		MCWB	21.8	21.8	20.8	18.4	16.3	13.8	13.3	14.2	14.6	16.8	18.8	20.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	25.7	25.0	23.3	21.1	20.4	18.8	20.7	21.2	22.3	23.3	25.1
		MCDB	31.7	31.8	28.9	27.6	24.6	22.7	23.0	26.9	26.2	27.6	29.7	31.0
	2%	WB	24.6	24.6	23.6	21.7	19.5	18.1	17.3	18.6	18.7	20.2	21.9	23.7
		MCDB	31.0	30.1	27.8	25.0	22.5	20.1	19.9	23.1	22.4	24.3	28.0	29.9
	5%	WB	23.7	23.7	22.6	20.5	18.3	16.3	15.6	16.8	17.0	19.0	20.8	22.8
		MCDB	29.7	28.8	26.7	23.5	20.9	18.0	17.6	19.9	20.4	23.1	26.4	28.6
	10%	WB	22.9	22.9	21.7	19.4	17.1	14.5	14.1	15.1	15.6	17.9	19.9	21.8
		MCDB	28.4	27.4	25.7	22.5	19.4	16.2	16.0	17.9	19.0	21.9	25.1	27.4
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.9	10.8	10.3	9.5	9.2	9.2	10.1	10.3	10.3	11.4	12.1
		MCDBR	13.3	12.3	12.2	11.9	10.3	9.5	10.2	12.2	12.4	12.6	13.3	13.9
		MCWBR	5.4	5.0	5.4	6.3	5.9	6.5	6.5	6.9	6.8	6.4	5.7	5.7
	5% WB	MCDBR	11.5	10.8	10.2	9.5	8.4	7.6	8.3	10.4	10.1	10.4	11.3	11.8
		MCWBR	5.6	5.4	5.4	5.8	5.3	6.2	6.2	6.6	6.4	6.2	6.0	5.8
(40) Clear-Sky Solar Irradiance	taub		0.412	0.396	0.373	0.372	0.370	0.367	0.361	0.427	0.455	0.417	0.399	0.398
	taud		2.343	2.405	2.459	2.409	2.378	2.374	2.377	2.144	2.080	2.252	2.331	2.361
	Ebn at Noon		925	918	902	840	778	749	779	763	803	887	931	943
	Edh at Noon		133	121	106	99	90	85	89	127	153	139	134	132
(44) All-Sky Solar Radiation	RadAvg		7.18	6.26	5.22	3.79	2.65	2.23	2.33	3.16	4.33	5.50	6.70	7.50
	RadStd		0.41	0.56	0.46	0.43	0.22	0.22	0.26	0.32	0.30	0.52	0.43	0.36

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.28	N/A	N/A	+0.56	N/A	+0.37	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.23	N/A	N/A	+0.60	N/A	N/A	N/A	N/A	+82	+42

Nomenclature: See separate page