

BUENOS AIRES OBSERVATORIO, Argentina

WMO: 875850

Lat: 34.5903S

Lon: 58.4839W

Elev: 82

StdP: 14.65

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.7	40.4	26.9	20.9	46.0	29.3	23.4	47.1	17.5	58.7	15.2	54.7	3.3	180	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.7	92.9	74.1	90.4	73.4	87.9	72.7	77.3	88.4	75.8	86.3	74.6	84.2	6.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.2	128.2	83.0	72.7	121.5	81.1	71.5	116.6	80.1	40.8	88.6	39.4	86.8	38.2	84.5	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	14.1	12.2	33.9	98.7	1.0	1.1	33.1	99.5	32.5	100.2	32.0	100.8	31.2	101.6
			31.4	80.3	2.2	1.7	29.8	81.5	28.5	82.5	27.3	83.5	25.7	84.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	77.6	75.6	71.2	66.0	60.1	54.3	53.0	56.8	59.1	63.9	70.4	75.5	(6)
(7)		DBStd	10.25	5.27	5.57	5.74	6.27	6.00	6.28	6.22	6.58	5.91	5.73	5.88	6.01	(7)
(8)		HDD50	79	0	0	0	1	1	25	35	13	4	0	0	0	(8)
(9)		HDD65	1526	1	1	14	61	176	326	379	268	192	87	18	3	(9)
(10)		CDD50	5638	856	716	656	481	314	154	127	223	277	432	612	790	(10)
(11)		CDD65	1614	392	298	205	92	24	5	7	13	15	54	180	329	(11)
(12)		CDH74	12675	3680	2482	1274	345	51	2	29	55	89	261	1328	3079	(12)
(13)		CDH80	4252	1392	840	315	56	2	0	5	8	19	45	381	1189	(13)
(14)	Wind	WSAvg	5.6	6.1	5.6	5.5	4.7	4.5	5.0	5.0	5.8	6.1	6.2	6.3	6.0	(14)
(15)	Precipitation	PrecAvg	46.1	5.0	4.5	5.3	4.3	3.2	2.5	2.6	2.8	2.8	4.7	4.2	4.1	(15)
(16)		PrecMax	69.0	13.3	15.9	18.8	8.9	14.3	7.0	7.2	8.6	8.2	14.4	9.7	11.8	(16)
(17)		PrecMin	33.9	0.4	1.2	0.9	0.2	0.0	0.0	0.4	0.0	0.1	0.7	0.7	1.0	(17)
(18)		PrecStd	9.6	3.0	3.1	3.5	2.4	3.2	1.7	1.5	2.0	1.6	2.8	2.1	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.7	94.2	89.6	86.0	78.8	73.1	77.8	80.1	82.5	85.0	91.5	96.9	(19)
(20)			MCWB	76.6	75.9	73.8	72.2	68.4	66.4	66.5	67.3	66.2	68.4	71.3	74.6	(20)
(21)		2%	DB	92.7	90.7	86.7	80.8	75.0	69.7	69.3	74.6	76.3	79.8	87.4	92.6	(21)
(22)			MCWB	74.7	75.5	72.1	68.9	66.1	63.3	62.2	63.5	63.5	65.4	70.0	73.2	(22)
(23)		5%	DB	89.9	88.0	83.7	77.9	71.8	66.9	65.0	70.6	72.3	76.7	84.4	89.8	(23)
(24)			MCWB	73.3	74.3	70.8	67.4	64.6	60.8	58.3	61.5	60.3	64.4	67.7	72.2	(24)
(25)		10%	DB	87.2	85.3	80.6	75.1	68.8	63.8	61.8	66.8	69.0	73.7	81.2	86.4	(25)
(26)			MCWB	72.7	72.7	69.8	66.4	62.9	58.5	56.2	59.1	59.1	62.7	66.5	71.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.8	79.1	75.8	73.6	69.3	68.3	66.6	69.5	69.8	71.1	73.5	79.4	(27)
(28)			MCDWB	89.8	89.7	85.4	81.9	76.2	71.1	76.4	78.5	78.8	80.5	85.8	89.8	(28)
(29)		2%	WB	77.3	77.1	73.8	71.8	67.4	65.0	63.4	66.0	66.0	68.4	71.7	76.1	(29)
(30)			MCDWB	88.2	88.0	82.5	77.3	73.1	69.1	68.5	72.1	73.0	76.1	83.8	87.9	(30)
(31)		5%	WB	75.8	75.6	72.5	70.5	65.9	62.5	60.7	63.4	63.0	66.7	70.1	74.4	(31)
(32)			MCDWB	86.3	85.2	80.6	74.8	69.8	65.9	64.3	68.8	68.6	73.5	80.9	84.9	(32)
(33)		10%	WB	74.5	74.2	71.2	68.9	64.4	59.6	57.4	60.6	61.0	64.7	68.6	73.1	(33)
(34)			MCDWB	84.1	82.6	78.9	73.1	68.1	63.1	60.2	65.3	66.8	71.3	78.1	83.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.7	15.2	15.0	13.9	12.3	13.2	12.4	14.0	14.1	14.1	16.4	17.1	(35)
(36)			MCDBR	19.0	17.8	17.7	17.6	14.9	15.3	16.1	18.3	19.1	18.4	20.2	20.7	(36)
(37)			MCWBR	7.7	7.0	7.6	8.0	8.1	9.9	9.3	9.9	9.3	8.4	8.2	8.5	(37)
(38)		5% WB	MCDBR	15.8	16.2	15.4	12.0	11.5	12.4	13.6	15.7	14.3	14.8	17.4	16.4	(38)
(39)			MCWBR	7.6	7.5	7.9	7.0	7.1	9.6	9.5	10.2	9.6	8.1	8.3	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.410	0.395	0.374	0.376	0.370	0.368	0.362	0.432	0.458	0.418	0.397	0.399	(40)	
(41)		taud	2.368	2.428	2.475	2.420	2.402	2.394	2.392	2.147	2.087	2.269	2.358	2.376	(41)	
(42)		Ebn at Noon	294	292	286	266	248	238	247	241	254	281	296	299	(42)	
(43)		Edh at Noon	41	37	33	31	28	27	28	40	48	43	41	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2281	1993	1669	1208	846	711	744	1010	1380	1753	2126	2378	(44)	
(45)		RadStd	130	178	150	141	73	74	86	103	95	164	140	117	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (6 neighbors)	+0.49	N/A	N/A	+1.08	+0.72	+0.72	N/A	N/A	+148	+76	(47)

Nomenclature: See separate page