

LA PLATA, Argentina

WMO: 875930

Lat: 34.9661S

Lon: 57.8961W

Elev: 62

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.7	36.1	28.3	22.3	41.0	30.8	25.1	41.1	27.0	47.6	22.9	52.7	3.7	270	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.5	89.3	73.1	86.9	72.4	84.6	71.7	76.6	84.4	75.2	82.5	73.9	81.1	8.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	128.4	80.8	72.9	122.2	79.5	71.6	116.9	78.2	40.2	84.7	38.8	82.4	37.5	81.4	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.7	16.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	73.6	72.3	68.1	63.0	56.1	52.0	50.5	52.9	55.3	60.4	65.1	71.0
	DBStd	10.04	5.34	5.76	5.76	6.64	6.31	6.04	6.54	6.42	5.81	6.11	6.08	6.26
	HDD50	197	0	0	0	2	14	44	73	42	19	3	0	0
	HDD65	2218	4	8	35	112	284	393	451	376	294	167	73	21
	CDD50	4449	733	625	560	393	204	104	90	133	177	326	454	650
	CDD65	994	271	214	130	53	9	2	2	3	3	25	76	206
	CDH74	6965	2105	1544	724	183	14	1	3	12	9	136	511	1723
	CDH80	1978	641	449	155	34	0	0	0	2	0	24	100	573
Wind	WSAvg	7.2	7.4	7.3	6.8	6.4	6.2	6.5	7.2	7.5	8.4	8.3	7.6	7.2
Precipitation	PrecAvg	39.5	4.0	4.0	4.4	3.0	3.0	2.4	2.3	2.7	2.8	4.5	3.8	3.3
	PrecMax	62.0	10.2	11.6	11.8	7.1	10.1	6.0	7.3	8.3	8.1	12.8	13.2	7.6
	PrecMin	22.9	0.7	0.7	0.6	0.2	0.0	0.0	0.3	0.0	0.2	0.5	0.6	0.6
	PrecStd	9.5	2.5	3.1	2.7	1.9	2.8	1.9	1.3	2.0	2.0	2.8	2.7	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.0	91.0	87.7	84.3	76.5	71.7	72.5	75.4	74.9	82.9	86.8	92.5
		MCWB	74.4	75.8	72.9	73.4	66.3	66.8	64.7	66.1	64.0	68.6	69.3	69.5
	2%	DB	89.1	87.9	84.3	79.1	71.9	67.5	67.2	70.2	70.8	77.5	82.6	88.8
		MCWB	74.0	74.5	71.4	70.0	64.7	63.4	62.0	62.6	60.8	66.2	68.2	70.7
	5%	DB	86.2	85.4	81.0	75.3	68.4	64.4	63.1	66.4	67.9	73.6	79.6	85.9
		MCWB	72.6	73.8	69.7	67.8	63.3	60.4	59.3	59.5	59.3	63.4	66.5	70.2
	10%	DB	83.7	82.8	78.0	72.8	65.6	61.2	60.2	63.1	64.9	70.6	76.7	82.9
		MCWB	72.1	72.5	69.2	66.8	61.7	57.3	56.6	57.4	57.6	62.6	65.5	69.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	78.8	77.5	74.8	68.1	68.1	65.0	67.2	67.2	71.0	72.4	76.5
		MCDB	87.0	87.2	83.2	83.2	74.2	70.9	70.8	73.2	72.0	79.9	81.0	84.7
	2%	WB	76.4	76.8	74.0	71.7	66.2	64.9	62.6	64.1	63.4	67.9	70.2	74.4
		MCDB	84.5	84.6	79.6	76.8	70.5	67.1	66.4	69.2	67.8	74.5	79.5	83.0
	5%	WB	75.0	75.2	72.2	69.9	64.3	61.4	60.4	61.5	61.2	65.8	68.6	72.6
		MCDB	82.7	82.2	77.9	73.7	67.4	63.6	62.9	64.7	65.1	71.0	76.5	81.3
	10%	WB	73.8	73.6	70.5	68.2	62.5	58.8	57.4	58.8	59.2	64.0	67.2	71.1
		MCDB	81.3	80.3	76.3	71.9	65.3	60.5	59.5	62.1	63.3	69.1	74.2	79.2
Mean Daily Temperature Range	5% DB	MDBR	17.5	16.9	17.3	15.8	14.7	14.2	13.5	15.3	15.8	16.2	17.9	19.4
		MCDBR	20.3	18.4	19.7	17.3	15.9	14.6	14.6	18.5	18.7	19.9	21.4	22.2
		MCWBR	8.9	7.9	8.2	8.9	8.9	10.2	10.1	11.0	10.8	10.3	9.8	8.9
	5% WB	MCDBR	17.5	16.8	16.4	14.3	13.1	12.5	13.5	16.9	15.1	16.4	18.3	19.5
		MCWBR	8.9	8.6	8.8	8.2	8.2	10.4	10.4	11.9	10.2	9.9	9.8	9.5
Clear-Sky Solar Irradiance	taub	0.410	0.398	0.380	0.377	0.371	0.360	0.358	0.428	0.451	0.422	0.399	0.396	
	taud	2.360	2.411	2.445	2.395	2.377	2.412	2.392	2.147	2.095	2.244	2.339	2.373	
	Ebn at Noon	294	291	284	264	246	240	248	242	256	280	295	299	
	Edh at Noon	42	38	34	32	29	26	28	40	48	44	42	41	
All-Sky Solar Radiation	RadAvg	2278	1981	1646	1202	836	705	734	989	1363	1746	2126	2376	
	RadStd	127	179	144	128	68	66	80	100	94	165	146	113	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.58	N/A	N/A	N/A	+1.17	+0.68	N/A	N/A	N/A	+191	+103

Nomenclature: See separate page