

LA PLATA, Argentina

WMO: 875930

Lat: 34.9661S

Lon: 57.8961W

Elev: 19

StdP: 101.10

Time Zone: -3.00 (W03)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.9	2.3	-2.1	3.2	5.0	-0.6	3.6	5.0	12.1	8.7	10.2	11.5	1.6	270	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	31.9	22.8	30.5	22.4	29.2	22.1	24.8	29.1	24.0	28.1	23.3	27.3	3.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.3	27.1	22.7	17.5	26.4	22.0	16.7	25.7	75.5	29.3	72.3	28.0	69.4	27.5	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.4	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	23.1	22.4	20.0	17.2	13.4	11.1	10.3	11.6	12.9	15.8	18.4	21.6
	DBStd	5.58	2.97	3.20	3.20	3.69	3.51	3.36	3.63	3.56	3.23	3.39	3.38	3.48
	HDD10.0	109	0	0	0	1	8	24	41	23	11	2	0	0
	HDD18.3	1232	2	4	19	62	158	218	251	209	163	93	41	12
	CDD10.0	2472	407	347	311	218	113	58	50	74	98	181	252	361
	CDD18.3	552	151	119	72	29	5	1	1	2	2	14	42	114
	CDH23.3	3869	1169	858	402	102	8	1	2	7	5	76	284	957
	CDH26.7	1099	356	249	86	19	0	0	0	1	0	13	56	318
Wind	WSAvg	3.2	3.3	3.3	3.0	2.9	2.8	2.9	3.2	3.3	3.7	3.7	3.4	3.2
Precipitation	PrecAvg	1003	101	102	113	77	77	61	58	69	71	114	96	85
	PrecMax	1575	260	295	300	180	257	153	186	212	205	326	336	194
	PrecMin	582	19	17	14	4	0	1	8	0	4	13	14	15
	PrecStd	241	64	79	68	49	70	47	32	51	50	70	69	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	32.8	30.9	29.1	24.7	22.0	22.5	24.1	23.8	28.3	30.4	33.6
		MCWB	23.5	24.3	22.7	23.0	19.0	19.3	18.2	18.9	17.8	20.3	20.7	20.9
	2%	DB	31.7	31.1	29.0	26.2	22.2	19.7	19.5	21.2	21.5	25.3	28.1	31.6
		MCWB	23.3	23.6	21.9	21.1	18.2	17.4	16.7	17.0	16.0	19.0	20.1	21.5
	5%	DB	30.1	29.7	27.2	24.1	20.2	18.0	17.3	19.1	19.9	23.1	26.4	30.0
		MCWB	22.6	23.2	21.0	19.9	17.4	15.8	15.2	15.3	15.2	17.4	19.1	21.2
	10%	DB	28.7	28.2	25.5	22.7	18.7	16.2	15.6	17.3	18.3	21.4	24.8	28.3
		MCWB	22.3	22.5	20.7	19.4	16.5	14.1	13.7	14.1	14.2	17.0	18.6	20.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	26.0	25.3	23.8	20.1	20.0	18.3	19.6	19.6	21.6	22.4	24.7
		MCDB	30.5	30.7	28.5	28.5	23.4	21.6	21.6	22.9	22.2	26.6	27.2	29.3
	2%	WB	24.6	24.9	23.3	22.1	19.0	18.3	17.0	17.9	17.4	19.9	21.2	23.6
		MCDB	29.2	29.2	26.4	24.9	21.4	19.5	19.1	20.7	19.9	23.6	26.4	28.3
	5%	WB	23.9	24.0	22.3	21.0	18.0	16.3	15.8	16.4	16.2	18.8	20.3	22.5
		MCDB	28.2	27.9	25.5	23.2	19.7	17.6	17.2	18.2	18.4	21.7	24.7	27.4
	10%	WB	23.2	23.1	21.4	20.1	17.0	14.9	14.1	14.9	15.1	17.8	19.5	21.7
		MCDB	27.4	26.8	24.6	22.1	18.5	15.8	15.3	16.7	17.4	20.6	23.4	26.2
Mean Daily Temperature Range	5% DB	MDBR	9.7	9.4	9.6	8.8	8.2	7.9	7.5	8.5	8.8	9.0	9.9	10.8
		MCDBR	11.3	10.2	10.9	9.6	8.8	8.1	8.1	10.3	10.4	11.0	11.9	12.4
		MCWBR	4.9	4.4	4.5	4.9	5.0	5.7	5.6	6.1	6.0	5.7	5.5	4.9
	5% WB	MCDBR	9.7	9.4	9.1	8.0	7.3	7.0	7.5	9.4	8.4	9.1	10.2	10.8
MCWBR		4.9	4.8	4.9	4.5	4.6	5.8	5.8	6.6	5.7	5.5	5.5	5.3	
Clear-Sky Solar Irradiance	taub	0.410	0.398	0.380	0.377	0.371	0.360	0.358	0.428	0.451	0.422	0.399	0.396	
	taud	2.360	2.411	2.445	2.395	2.377	2.412	2.392	2.147	2.095	2.244	2.339	2.373	
	Ebn at Noon	927	916	895	833	775	757	782	762	806	883	931	944	
	Edh at Noon	131	120	108	101	90	82	87	127	150	140	133	130	
All-Sky Solar Radiation	RadAvg	7.18	6.25	5.19	3.79	2.64	2.22	2.31	3.12	4.30	5.50	6.70	7.49	
	RadStd	0.40	0.56	0.46	0.41	0.21	0.21	0.25	0.31	0.29	0.52	0.46	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	+0.32	N/A	N/A	+0.65	+0.38	N/A	N/A	N/A	+106	+57

Nomenclature: See separate page