

SANTA ROSA, Argentina

WMO: 876230

Lat: 36.5931S

Lon: 64.2800W

Elev: 191

StdP: 99.05

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.3	-0.6	-9.5	1.7	7.7	-7.8	2.0	7.1	10.7	11.1	9.5	11.2	1.2	290	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	35.4	21.1	33.7	20.5	32.1	20.2	23.8	30.8	22.8	29.9	21.9	29.1	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.0	27.1	20.7	15.7	25.9	19.7	14.7	25.1	72.5	30.9	68.6	29.7	65.1	29.2	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.3	8.3	DB	-5.7	38.8	2.0	1.9	-7.2	40.2	-8.4	41.3	-9.5	42.4	-10.9	43.8	(4)
(5)			WB	-6.4	25.5	1.8	1.1	-7.7	26.3	-8.7	26.9	-9.7	27.5	-11.0	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	24.0	22.6	20.1	15.9	12.0	8.8	8.3	10.4	13.0	16.1	19.7	22.7	(6)	
	DBStd	6.44	3.19	3.62	3.67	3.71	3.58	2.96	3.29	3.75	3.72	3.46	3.49	3.46	(7)	
	HDD10.0	204	0	0	0	3	18	56	73	40	14	1	0	0	(8)	
	HDD18.3	1446	1	7	24	89	199	286	312	248	163	88	24	6	(9)	
	CDD10.0	2431	436	353	312	180	81	20	19	52	104	189	292	393	(10)	
	CDD18.3	631	178	127	77	17	3	0	0	1	3	17	67	141	(11)	
	CDH23.3	6887	1968	1283	733	176	23	0	1	23	70	235	759	1616	(12)	
	CDH26.7	2874	934	554	266	38	2	0	0	4	12	57	269	737	(13)	
(14) Wind	WSAvg	3.5	3.8	3.6	3.6	3.1	2.9	2.7	3.0	3.6	3.9	4.0	4.1	4.0	(14)	
(15) Precipitation	PrecAvg	708	82	82	95	58	33	14	18	25	43	81	88	93	(15)	
	PrecMax	1173	202	216	331	171	137	59	176	145	132	246	285	378	(16)	
	PrecMin	357	9	6	9	0	0	0	0	0	0	5	7	10	(17)	
	PrecStd	198	48	52	66	46	32	14	28	32	35	62	53	67	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	36.6	34.5	30.0	26.2	20.6	21.4	26.8	28.1	31.2	34.4	37.3	(19)	
		MCWB	22.1	22.4	21.7	19.5	18.1	12.7	13.6	15.4	15.7	18.5	19.0	21.1	(20)	
	2%	DB	35.3	34.1	31.8	27.6	22.7	18.1	18.4	22.4	25.2	28.1	31.8	35.0	(21)	
		MCWB	21.2	21.4	21.1	18.2	15.8	11.3	11.2	12.8	14.9	17.2	18.7	20.3	(22)	
	5%	DB	33.5	32.2	29.8	25.3	20.2	16.2	16.3	19.8	23.0	25.9	29.9	33.0	(23)	
		MCWB	20.6	21.0	20.1	16.9	14.2	10.3	10.2	11.9	13.4	16.2	17.8	19.9	(24)	
	10%	DB	31.7	30.2	27.6	23.1	18.2	14.6	14.6	17.5	20.7	23.9	27.8	30.9	(25)	
		MCWB	20.3	20.3	19.2	15.7	13.4	9.9	9.6	10.3	12.2	15.0	16.9	19.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.9	25.2	24.3	21.8	19.5	15.0	15.7	17.7	18.0	21.0	22.0	24.3	(27)	
		MCDB	31.6	31.0	30.3	25.6	24.0	17.1	17.6	22.7	25.3	27.7	29.8	31.6	(28)	
	2%	WB	23.6	23.7	22.7	19.9	17.4	13.2	13.5	14.5	16.1	19.0	20.4	22.6	(29)	
		MCDB	31.2	30.5	28.5	23.9	21.1	15.6	15.9	19.3	22.9	25.6	27.7	30.6	(30)	
	5%	WB	22.6	22.7	21.3	18.6	15.8	11.8	11.7	12.9	14.6	17.5	19.3	21.4	(31)	
		MCDB	30.3	29.4	27.6	23.2	18.7	14.6	14.7	18.2	20.5	23.4	26.8	29.6	(32)	
	10%	WB	21.6	21.6	20.2	17.2	14.2	10.6	10.2	11.4	13.3	16.2	18.2	20.5	(33)	
		MCDB	29.1	28.0	26.3	21.9	17.2	13.4	13.5	16.2	18.8	22.0	25.2	28.4	(34)	
(35) Mean Daily Temperature Range	MDBR		13.5	12.9	12.3	11.7	10.7	11.1	11.4	12.1	12.6	12.2	13.3	13.8	(35)	
	5% DB	MCDBR	16.1	15.5	15.1	15.3	13.7	13.9	14.4	15.5	16.5	16.1	16.3	16.7	(36)	
		MCWBR	5.9	5.9	6.4	7.6	7.4	8.1	8.3	8.2	8.1	7.7	6.9	6.4	(37)	
	5% WB	MCDBR	13.4	13.2	13.2	11.8	11.1	11.4	11.3	13.2	13.9	13.9	13.9	14.1	(38)	
		MCWBR	6.2	6.0	6.6	6.7	6.6	7.5	7.4	7.9	7.5	7.6	6.8	6.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.399	0.383	0.365	0.356	0.334	0.318	0.325	0.352	0.404	0.388	0.376	0.391	(40)	
	taud		2.330	2.379	2.432	2.421	2.454	2.494	2.448	2.362	2.193	2.300	2.347	2.330	(41)	
	Ebn at Noon		935	927	904	848	809	797	809	838	846	911	951	948	(42)	
	Edh at Noon		134	123	108	96	81	72	80	100	134	131	131	135	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.75	6.74	5.34	3.77	2.52	2.19	2.34	3.23	4.45	5.67	7.29	8.00	(44)	
	RadStd		0.38	0.32	0.35	0.48	0.27	0.27	0.23	0.32	0.34	0.46	0.38	0.48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.70	N/A	N/A	-44	-132	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page