

AZUL, Argentina

WMO: 876410

Lat: 36.8322S

Lon: 59.8864W

Elev: 147

StdP: 99.57

Time Zone: -3.00 (W03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.0	-1.4	-5.9	2.3	4.0	-4.6	2.6	3.3	13.5	8.9	12.1	9.4	0.7	270	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	32.8	20.5	31.2	20.2	29.7	19.8	23.1	28.8	22.1	27.8	21.3	26.8	5.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	16.4	25.5	20.4	15.4	24.5	19.6	14.6	23.7	69.5	28.9	65.6	27.7	62.6	27.0	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.5	9.8	-5.9	36.1	1.5	1.5	-7.0	37.2	-7.9	38.0	-8.7	38.8	-9.8	39.9		
(5)			-5.9	25.1	1.4	1.2	-6.9	25.9	-7.8	26.6	-8.6	27.2	-9.6	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	21.7	20.7	18.0	14.4	11.0	8.1	7.3	9.2	11.0	13.8	17.1	20.2
	DBStd	5.96	3.26	3.34	3.51	3.62	3.47	2.96	3.32	3.63	3.32	3.27	3.50	3.56
	HDD10.0	297	0	0	0	6	29	73	96	59	27	7	1	0
	HDD18.3	1814	9	15	51	126	228	308	341	284	221	146	64	22
	CDD10.0	1878	362	300	247	137	60	14	13	33	57	124	213	317
	CDD18.3	353	113	82	39	7	1	0	0	1	1	4	26	81
	CDH23.3	3719	1224	760	318	54	3	0	0	8	9	54	335	953
	CDH26.7	1282	481	265	74	4	0	0	0	2	1	8	82	364
Wind	WSAvg	3.6	4.0	3.3	3.2	2.9	2.9	3.2	3.2	3.7	4.2	4.2	4.3	4.1
Precipitation	PrecAvg	936	107	109	116	82	58	37	44	56	59	86	89	88
	PrecMax	1381	238	421	297	214	137	97	107	292	135	184	197	218
	PrecMin	620	54	18	26	4	7	6	0	0	3	20	15	24
	PrecStd	232	56	92	67	56	39	27	28	67	40	41	51	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	33.8	31.4	27.1	23.4	18.9	19.0	23.7	24.3	27.8	31.1	34.7
		MCWB	21.0	20.8	20.9	18.6	17.4	14.9	14.7	16.6	16.4	18.2	19.9	20.3
	2%	DB	33.0	31.6	28.7	25.0	20.7	16.8	16.4	20.0	21.5	24.7	28.9	32.3
		MCWB	20.6	21.5	19.9	18.0	15.9	13.0	12.6	14.3	14.3	16.8	18.4	19.8
	5%	DB	31.2	29.9	26.6	23.2	18.6	15.1	14.8	17.3	19.8	22.7	27.1	30.6
		MCWB	20.0	20.6	19.2	17.0	14.4	11.7	11.6	12.2	13.1	15.6	17.9	19.4
	10%	DB	29.5	28.1	24.9	21.5	16.9	13.6	13.1	15.5	17.8	20.9	25.1	28.5
		MCWB	19.7	20.3	18.5	16.4	13.8	10.6	10.3	11.4	12.2	14.8	16.8	18.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.7	23.2	22.0	19.1	17.2	16.2	18.4	18.9	19.6	21.4	23.5
		MCDB	30.5	29.8	27.7	25.8	22.0	18.2	18.2	22.6	21.9	24.6	28.2	30.2
	2%	WB	22.8	23.2	21.7	20.1	17.3	14.7	14.2	15.7	16.0	17.9	19.9	22.1
		MCDB	29.2	28.0	26.2	22.3	19.4	15.6	15.5	17.8	19.8	22.5	26.4	28.4
	5%	WB	21.7	22.0	20.5	18.6	15.8	12.5	12.3	13.8	14.4	16.8	18.8	21.0
		MCDB	28.1	27.2	24.8	21.5	17.6	13.9	13.7	16.0	17.8	21.1	24.9	27.6
	10%	WB	21.0	21.1	19.5	17.2	14.4	11.0	10.8	12.2	13.2	15.8	17.8	19.9
		MCDB	27.0	25.9	23.4	20.6	16.2	13.1	12.5	14.9	16.4	19.7	23.2	26.2
Mean Daily Temperature Range	5% DB	MDBR	13.9	12.6	12.1	11.9	10.5	10.4	9.9	10.7	11.3	11.6	13.3	13.9
		MCDBR	16.0	14.8	13.9	14.2	12.4	11.8	11.7	13.2	14.5	14.7	15.8	16.4
		MCWBR	6.2	5.9	6.4	7.7	7.3	7.8	7.7	8.0	8.1	7.9	7.1	6.4
	5% WB	MCDBR	13.2	12.2	11.4	10.6	9.2	8.7	8.7	10.3	11.3	12.2	13.6	14.0
		MCWBR	6.5	6.1	5.9	6.7	6.1	7.1	6.9	7.2	7.2	7.2	7.1	6.8
Clear-Sky Solar Irradiance	taub	0.403	0.388	0.373	0.362	0.353	0.335	0.338	0.390	0.431	0.404	0.390	0.392	
	taud	2.315	2.365	2.400	2.382	2.372	2.432	2.397	2.222	2.100	2.239	2.307	2.319	
	Ebn at Noon	931	921	895	839	781	771	790	791	818	895	938	946	
	Edh at Noon	136	124	111	99	87	77	84	114	147	139	136	137	
All-Sky Solar Radiation	RadAvg	7.40	6.42	5.13	3.71	2.52	2.10	2.21	3.07	4.22	5.48	6.87	7.78	
	RadStd	0.36	0.46	0.35	0.37	0.20	0.21	0.23	0.33	0.30	0.54	0.38	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.75	N/A	N/A	N/A	N/A	N/A	+37

Nomenclature: See separate page