

TANDIL, Argentina

WMO: 876450

Lat: 37.2411S

Lon: 59.2333W

Elev: 574

StdP: 14.39

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.2	28.6	19.4	14.9	38.9	22.5	17.3	37.9	28.1	46.6	24.6	46.8	2.7	230	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	89.3	68.2	86.4	67.5	83.8	66.5	72.4	82.2	70.7	80.2	69.3	78.6	12.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	110.9	76.1	67.9	104.8	74.2	66.4	99.3	73.0	36.5	82.4	35.0	80.4	33.8	79.1	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	22.0	19.5	DB	20.7	94.6	3.3	2.6	18.3	96.5	16.4	98.0	14.6	99.5	12.2	101.4	(4)
(5)			WB	20.4	76.1	2.5	1.9	18.5	77.5	17.0	78.6	15.6	79.7	13.8	81.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	69.2	67.4	63.3	56.8	51.1	45.8	44.3	47.6	50.6	55.8	61.3	66.7	(6)	
	DBStd	10.32	5.61	5.88	6.08	6.00	6.02	5.35	5.97	6.27	5.74	5.79	5.93	6.14	(7)	
	HDD50	609	0	0	0	10	57	147	195	121	61	16	2	0	(8)	
	HDD65	3529	25	41	105	252	431	577	641	540	434	289	140	54	(9)	
	CDD50	3025	594	487	414	216	92	20	20	47	78	196	342	519	(10)	
	CDD65	469	154	109	54	7	1	0	0	1	1	4	30	108	(11)	
	CDH74	5170	1734	1038	464	75	8	0	0	7	10	70	419	1345	(12)	
	CDH80	1590	612	315	94	8	0	0	0	1	1	8	88	463	(13)	
(14) Wind	WSAvg	8.4	8.7	8.0	7.6	7.3	6.9	7.7	8.0	8.9	9.6	9.6	9.3	9.3	(14)	
(15) Precipitation	PrecAvg	38.1	4.7	3.5	4.2	3.2	3.0	1.9	1.7	1.7	2.3	4.1	3.6	3.7	(15)	
	PrecMax	49.8	8.5	8.1	11.9	17.4	8.5	5.5	5.4	6.1	6.7	8.0	8.7	6.9	(16)	
	PrecMin	23.1	1.5	0.7	1.0	0.0	0.1	0.0	0.0	0.0	0.4	1.6	0.8	0.6	(17)	
	PrecStd	6.8	2.2	1.7	2.6	3.7	2.4	1.4	1.4	1.4	1.7	1.8	2.1	1.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.7	91.5	86.6	80.2	74.3	64.9	66.2	73.1	74.4	80.2	86.3	92.7	(19)	
		MCWB	69.0	69.4	68.9	63.6	62.8	58.3	57.8	61.4	59.8	63.7	65.9	68.5	(20)	
	2%	DB	89.5	87.1	82.7	75.8	68.1	61.2	60.9	66.6	69.7	75.3	82.5	88.5	(21)	
		MCWB	68.9	68.9	67.3	63.4	59.2	54.3	53.6	56.3	56.5	61.5	64.0	66.5	(22)	
	5%	DB	86.4	84.0	79.1	72.3	64.5	58.3	57.7	62.4	66.3	72.0	78.9	85.2	(23)	
		MCWB	67.7	68.1	66.0	61.1	57.2	52.2	51.8	53.4	54.8	59.7	62.7	65.9	(24)	
	10%	DB	83.1	80.6	76.0	68.9	61.6	55.7	54.7	59.1	62.9	68.5	75.3	81.7	(25)	
		MCWB	66.4	66.7	64.7	60.2	56.1	50.8	49.9	51.4	53.0	57.9	61.4	64.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.0	74.7	72.7	70.1	65.7	62.2	61.1	64.8	64.5	67.4	69.0	73.1	(27)	
		MCDB	86.6	83.4	79.7	74.9	70.6	63.4	64.2	70.6	69.7	75.3	80.1	84.6	(28)	
	2%	WB	72.1	72.1	70.3	66.7	62.3	57.5	57.0	59.5	59.9	64.0	66.8	70.6	(29)	
		MCDB	83.2	80.7	77.7	70.7	65.1	59.0	58.5	63.2	65.7	71.5	77.6	82.0	(30)	
	5%	WB	70.4	70.3	68.4	64.0	59.8	54.2	53.5	55.9	57.1	61.7	64.8	68.6	(31)	
		MCDB	81.0	79.0	75.9	68.9	62.8	56.1	55.7	59.9	62.4	69.1	75.0	79.6	(32)	
	10%	WB	68.8	68.8	66.6	61.8	57.3	51.5	50.8	53.0	54.8	59.7	63.1	66.6	(33)	
		MCDB	78.7	77.0	73.5	67.3	60.3	54.4	53.6	57.9	60.4	65.7	72.1	77.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	25.2	23.1	21.8	21.2	19.0	18.4	18.5	19.8	21.1	21.0	23.4	25.3	(35)	
		MCDBR	29.5	27.7	25.7	26.5	22.7	21.4	22.0	25.4	27.5	27.2	28.8	30.2	(36)	
	5% WB	MCWBR	12.0	11.8	12.6	14.3	13.6	13.8	14.2	15.1	15.5	14.7	13.0	12.0	(37)	
		MCWBR	23.9	21.9	20.6	19.4	17.1	14.6	15.6	19.5	21.2	22.4	24.4	24.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.406	0.391	0.372	0.355	0.351	0.332	0.335	0.385	0.425	0.400	0.385	0.392	(40)	
		taud	2.298	2.353	2.396	2.401	2.370	2.435	2.405	2.233	2.116	2.245	2.317	2.317	(41)	
	Ebn at Noon		294	291	284	268	247	245	251	252	261	285	299	300	(42)	
		Edh at Noon	44	40	35	31	28	24	26	36	46	44	43	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		2335	2016	1603	1166	789	652	687	949	1314	1722	2158	2451	(44)	
	RadStd		110	144	102	116	66	63	68	105	98	175	117	119	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	+1.35	N/A	N/A	N/A	N/A	N/A	+67
	N/A	N/A	N/A	+1.26	N/A	N/A	N/A	N/A	N/A	+59

Nomenclature: See separate page