

DOLORES, Argentina

WMO: 876480

Lat: 36.3169S

Lon: 57.7169W

Elev: 30

StdP: 14.68

Time Zone: -3.00 (W03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	32.4	25.6	19.6	35.9	28.4	22.3	38.1	26.7	49.7	23.5	51.0	2.3	270	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.9	90.1	71.2	87.3	70.8	84.5	70.0	75.1	84.3	73.6	82.3	72.2	80.3	10.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.5	120.3	78.9	71.0	114.4	77.3	69.7	109.5	75.8	38.6	84.3	37.2	82.3	36.0	80.9	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.6	20.6	17.7	DB	26.0	95.9	3.3	2.2	23.6	97.5	21.7	98.8	19.9	100.1	17.5	101.7
			WB	25.3	78.5	3.1	1.9	23.1	79.8	21.3	80.9	19.5	81.9	17.2	83.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.5	71.6	70.5	66.2	60.1	54.0	48.8	47.6	50.9	53.6	58.9	63.9	68.6
	DBStd	10.15	5.68	5.88	6.17	6.28	6.01	5.50	5.94	6.40	5.82	5.76	5.91	6.34
	HDD50	338	0	0	0	4	27	86	120	65	31	5	0	0
	HDD65	2741	13	19	62	170	342	485	540	439	344	201	88	38
	CDD50	3807	669	573	502	307	152	51	45	94	138	282	418	576
	CDD65	739	217	172	100	24	3	0	0	2	1	14	56	150
	CDH74	6090	1958	1344	649	119	12	0	1	15	13	112	480	1387
	CDH80	1884	696	419	142	13	1	0	0	2	1	14	108	488
(14) Wind	WSAvg	7.0	6.9	6.1	5.9	5.8	5.8	6.6	7.1	7.7	7.9	8.0	8.0	7.6
(15) Precipitation	PrecAvg	37.0	4.1	3.5	3.6	3.3	2.5	2.0	2.4	2.6	2.6	3.5	3.4	3.4
	PrecMax	56.9	10.8	11.4	12.8	14.8	7.4	6.1	6.3	10.4	8.0	8.3	7.3	11.1
	PrecMin	22.2	0.0	0.4	0.2	0.3	0.3	0.0	0.2	0.0	0.0	0.4	0.8	0.1
	PrecStd	7.6	2.5	2.2	2.3	2.7	1.7	1.5	1.4	2.1	1.8	1.9	1.7	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.8	92.0	87.8	81.5	75.4	68.1	67.7	75.1	75.1	82.6	87.4	93.5
		MCWB	71.8	72.6	71.4	68.9	65.3	64.2	61.1	63.2	63.0	68.5	68.1	70.6
	2%	DB	90.3	88.0	83.8	77.3	70.0	64.3	62.9	68.5	70.8	77.3	83.0	89.3
		MCWB	71.9	72.6	70.3	65.8	62.3	59.2	57.1	60.5	59.8	64.7	67.1	69.7
	5%	DB	87.2	85.1	80.7	74.1	66.5	61.2	59.7	64.1	67.4	73.5	79.4	85.7
		MCWB	71.1	71.5	68.8	64.4	60.3	56.9	54.8	57.1	58.0	63.0	65.8	69.0
	10%	DB	83.8	81.9	77.5	71.1	64.0	58.5	57.0	60.8	64.0	70.0	76.0	81.8
		MCWB	70.0	70.3	67.4	63.9	59.2	54.6	53.3	55.3	56.2	60.8	64.7	67.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.1	76.9	75.4	72.6	67.7	66.2	62.7	66.6	66.6	70.9	72.3	75.2
		MCDB	88.2	86.0	81.6	78.4	72.7	66.9	66.8	73.3	72.0	77.7	81.9	85.7
	2%	WB	74.9	75.1	72.7	69.3	64.6	61.5	59.1	62.1	62.3	67.0	69.8	72.9
		MCDB	85.1	83.4	79.8	72.6	67.8	63.1	61.3	66.1	67.3	73.7	78.9	83.3
	5%	WB	73.4	73.5	70.8	67.1	62.3	58.4	56.5	59.0	59.7	64.5	67.9	71.2
		MCDB	82.5	81.2	77.0	71.3	65.1	60.0	58.5	62.3	64.4	70.8	75.9	80.6
	10%	WB	71.9	71.9	69.3	65.1	60.1	55.3	54.0	56.5	57.7	62.6	66.0	69.4
		MCDB	80.1	79.2	75.0	69.6	62.7	57.6	56.3	59.9	62.2	68.1	73.4	78.0
(35) Mean Daily Temperature Range	5% DB	MDBR	21.9	20.4	19.8	19.4	17.7	17.1	16.3	16.6	17.6	18.2	20.1	21.9
		MCDBR	26.3	23.8	22.7	22.9	20.5	18.9	18.6	21.2	22.5	23.5	24.7	27.2
		MCWBR	10.6	10.0	10.4	12.1	12.0	12.8	12.0	12.5	12.6	12.5	11.4	10.8
	5% WB	MCDBR	21.8	19.6	18.8	16.6	15.5	14.2	14.4	16.4	17.8	18.8	20.9	21.4
		MCWBR	10.8	10.1	10.1	10.1	10.5	12.0	10.8	11.3	11.7	11.3	11.6	10.5
(40) Clear-Sky Solar Irradiance	taub		0.413	0.406	0.380	0.370	0.365	0.359	0.355	0.411	0.451	0.407	0.390	0.396
	taud		2.312	2.344	2.406	2.383	2.355	2.367	2.367	2.180	2.061	2.260	2.335	2.337
	Ebn at Noon		293	287	282	264	245	236	246	245	254	283	298	299
	Edh at Noon		43	40	35	32	29	26	28	38	49	43	42	43
(44) All-Sky Solar Radiation	RadAvg		2275	1967	1597	1177	810	671	709	948	1329	1712	2115	2407
	RadStd		107	157	124	118	66	60	69	97	94	172	122	104

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.24	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	N/A	+58

Nomenclature: See separate page