

DOLORES, Argentina

WMO: 876480

Lat: 36.3169S

Lon: 57.7169W

Elev: 9

StdP: 101.22

Time Zone: -3.00 (W03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.2	0.2	-3.6	2.8	2.2	-2.0	3.2	3.4	11.9	9.8	10.5	10.6	1.0	270	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	32.3	21.8	30.7	21.6	29.1	21.1	24.0	29.0	23.1	28.0	22.3	26.8	4.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	17.2	26.0	21.7	16.3	25.1	21.0	15.6	24.3	72.0	29.0	68.7	27.9	65.8	27.2	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.6	9.2	7.9	DB	-3.3	35.5	1.8	1.2	-4.6	36.4	-5.7	37.1	-6.7	37.8	-8.0	38.7	
			WB	-3.7	25.8	1.7	1.0	-4.9	26.6	-6.0	27.2	-6.9	27.7	-8.2	28.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	22.0	21.4	19.0	15.6	12.2	9.4	8.7	10.5	12.0	15.0	17.7	20.3
	DBStd	5.64	3.16	3.27	3.43	3.49	3.34	3.06	3.30	3.56	3.23	3.20	3.28	3.52
	HDD10.0	188	0	0	0	2	15	48	67	36	17	3	0	0
	HDD18.3	1523	7	11	34	94	190	269	300	244	191	112	49	21
	CDD10.0	2115	372	318	279	171	84	28	25	52	77	157	232	320
	CDD18.3	411	121	96	56	13	2	0	0	1	1	8	31	83
	CDH23.3	3383	1088	747	361	66	7	0	1	8	7	62	267	771
	CDH26.7	1047	387	233	79	7	1	0	0	1	1	8	60	271
Wind	WSAvg	3.1	3.1	2.7	2.7	2.6	2.6	2.9	3.2	3.5	3.5	3.6	3.6	3.4
Precipitation	PrecAvg	941	105	90	92	83	63	50	61	66	65	89	87	87
	PrecMax	1446	275	289	325	377	188	155	161	264	204	212	186	283
	PrecMin	563	1	11	4	8	7	1	5	0	0	9	20	2
	PrecStd	194	63	55	59	68	43	37	36	54	46	48	43	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	33.3	31.0	27.5	24.1	20.1	19.9	24.0	23.9	28.1	30.8	34.2
		MCWB	22.1	22.6	21.9	20.5	18.5	17.9	16.1	17.3	17.2	20.3	20.1	21.4
	2%	DB	32.4	31.1	28.8	25.2	21.1	17.9	17.2	20.3	21.5	25.1	28.3	31.8
		MCWB	22.1	22.6	21.3	18.8	16.8	15.1	13.9	15.8	15.4	18.2	19.5	21.0
	5%	DB	30.6	29.5	27.0	23.4	19.2	16.2	15.4	17.8	19.6	23.1	26.3	29.8
		MCWB	21.7	21.9	20.5	18.0	15.7	13.8	12.7	13.9	14.4	17.2	18.8	20.5
	10%	DB	28.8	27.7	25.3	21.7	17.8	14.7	13.9	16.0	17.8	21.1	24.5	27.6
		MCWB	21.1	21.3	19.6	17.7	15.1	12.5	11.8	13.0	13.5	16.0	18.2	19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	25.0	24.1	22.5	19.8	19.0	17.1	19.2	19.2	21.6	22.4	24.0
		MCDB	31.2	30.0	27.6	25.8	22.6	19.4	19.3	22.9	22.2	25.4	27.7	29.8
	2%	WB	23.9	23.9	22.6	20.7	18.1	16.4	15.0	16.7	16.8	19.4	21.0	22.7
		MCDB	29.5	28.6	26.6	22.5	19.9	17.3	16.3	18.9	19.6	23.2	26.1	28.5
	5%	WB	23.0	23.1	21.6	19.5	16.8	14.7	13.6	15.0	15.4	18.1	19.9	21.8
		MCDB	28.1	27.3	25.0	21.8	18.4	15.6	14.7	16.8	18.0	21.6	24.4	27.0
	10%	WB	22.2	22.2	20.7	18.4	15.6	13.0	12.2	13.6	14.3	17.0	18.9	20.8
		MCDB	26.7	26.2	23.9	20.9	17.1	14.2	13.5	15.5	16.8	20.1	23.0	25.6
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.3	11.0	10.8	9.8	9.5	9.0	9.2	9.8	10.1	11.1	12.2
		MCDBR	14.6	13.2	12.6	12.7	11.4	10.5	10.3	11.8	12.5	13.1	13.7	15.1
		MCWBR	5.9	5.5	5.8	6.7	6.7	7.1	6.7	7.0	7.0	6.9	6.3	6.0
	5% WB	MCDBR	12.1	10.9	10.4	9.2	8.6	7.9	8.0	9.1	9.9	10.4	11.6	11.9
		MCWBR	6.0	5.6	5.6	5.6	5.8	6.7	6.0	6.3	6.5	6.3	6.4	5.8
Clear-Sky Solar Irradiance	taub	0.413	0.406	0.380	0.370	0.365	0.359	0.355	0.411	0.451	0.407	0.390	0.396	
	taud	2.312	2.344	2.406	2.383	2.355	2.367	2.367	2.180	2.061	2.260	2.335	2.337	
	Ebn at Noon	923	905	890	833	771	744	774	772	801	893	938	943	
	Edh at Noon	137	127	111	100	90	83	87	120	154	137	133	135	
All-Sky Solar Radiation	RadAvg	7.17	6.20	5.03	3.71	2.55	2.12	2.24	2.99	4.19	5.40	6.67	7.59	
	RadStd	0.34	0.49	0.39	0.37	0.21	0.19	0.22	0.31	0.30	0.54	0.38	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.69	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	N/A	+32

Nomenclature: See separate page