

VIEDMA, Argentina

WMO: 877910

Lat: 40.8633S

Lon: 63.0069W

Elev: 23

StdP: 14.68

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.2	29.7	17.4	13.2	49.8	20.6	15.5	47.8	35.9	53.0	31.1	50.2	5.7	320	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	94.0	66.3	90.3	65.0	87.0	64.0	70.6	83.9	68.9	82.0	67.3	80.0	17.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.7	98.4	75.0	64.8	91.8	73.2	62.9	85.9	72.1	34.6	84.0	33.1	81.4	31.8	80.3	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.6	28.0	25.0	22.6	101.0	2.4	2.2	20.9	102.6	19.5	103.9	18.2	105.1	16.5	106.8
			21.6	74.4	2.4	2.8	19.9	76.5	18.5	78.1	17.1	79.7	15.3	81.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	71.1	69.5	65.7	57.9	51.3	46.6	45.5	48.3	51.5	57.4	63.0	68.0
	DBStd	11.03	6.36	7.18	7.20	6.46	5.83	5.15	5.79	6.05	6.49	6.89	7.19	6.85
	HDD50	529	0	0	0	6	54	128	164	107	56	13	1	0
	HDD65	3291	16	34	82	230	427	553	603	519	408	253	120	46
	CDD50	3423	655	546	487	243	93	25	26	54	101	243	392	558
	CDD65	709	207	160	104	17	2	0	0	3	17	60	139	
	CDH74	7848	2265	1648	975	161	9	0	0	2	47	266	838	1637
	CDH80	3068	968	692	343	29	1	0	0	6	72	309	648	
Wind	WSAvg	11.7	13.6	12.7	11.7	10.6	9.7	10.6	10.9	11.7	12.2	12.5	13.1	
Precipitation	PrecAvg	14.3	0.9	1.7	1.9	1.4	1.3	0.9	1.1	1.0	1.0	1.2	0.9	1.0
	PrecMax	23.9	4.5	7.4	7.0	4.1	3.8	6.5	4.7	4.6	4.0	3.1	3.3	3.6
	PrecMin	7.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.1	0.9	1.5	1.7	1.0	0.8	1.0	1.0	1.1	0.9	0.9	0.7	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.0	97.5	93.2	83.8	74.4	65.6	67.1	72.3	80.1	87.6	94.5	96.7
		MCWB	67.2	66.8	67.3	63.3	59.9	52.0	53.6	54.8	58.4	62.4	64.9	66.1
	2%	DB	93.5	92.1	88.0	78.2	69.3	61.5	62.6	66.9	73.2	80.6	87.5	91.5
		MCWB	66.1	66.8	66.3	60.5	57.4	51.1	51.4	52.7	55.4	58.3	62.1	64.7
	5%	DB	89.5	87.9	83.7	74.4	65.1	58.5	59.2	63.2	68.6	75.7	82.8	87.4
		MCWB	64.7	65.2	64.4	58.7	54.9	49.8	49.3	50.5	52.6	56.3	59.9	63.1
	10%	DB	85.4	84.0	79.2	70.3	61.9	55.8	56.3	60.0	64.7	71.4	78.4	83.1
		MCWB	63.3	64.3	62.7	57.1	53.3	49.0	47.8	48.8	51.2	54.9	58.1	61.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	73.4	71.9	67.1	63.1	55.8	57.1	58.4	61.4	64.7	68.4	70.6
		MCDB	87.7	86.4	84.9	76.0	70.3	60.4	62.5	67.3	74.0	77.9	86.0	88.2
	2%	WB	70.0	70.8	69.0	63.8	59.4	53.7	53.4	54.5	57.5	61.0	64.8	67.7
		MCDB	83.7	82.3	81.8	73.8	65.2	57.3	59.0	63.3	68.0	73.6	79.9	83.8
	5%	WB	68.0	69.0	67.0	60.9	56.8	51.8	51.1	52.1	54.8	58.6	62.4	65.7
		MCDB	81.4	80.5	78.2	70.8	63.3	56.5	57.4	60.2	65.1	71.4	77.2	80.5
	10%	WB	66.1	67.1	65.0	58.7	54.5	50.0	48.8	50.2	52.5	56.5	60.0	63.6
		MCDB	79.7	78.8	75.1	67.7	60.6	55.0	55.2	57.9	62.4	68.3	74.1	78.9
Mean Daily Temperature Range	5% DB	MDBR	24.3	23.0	22.2	21.7	18.8	17.9	19.2	20.3	21.8	22.8	24.2	24.7
		MCDBR	31.4	29.6	27.5	26.9	23.0	21.4	22.6	24.7	28.4	30.3	31.4	31.6
		MCWBR	10.9	10.8	11.3	13.1	13.2	13.1	13.7	13.6	14.1	13.6	11.9	11.4
	5% WB	MCDBR	24.6	23.0	23.4	22.2	18.8	16.9	19.2	21.0	23.9	25.6	26.5	26.7
		MCWBR	11.0	10.2	11.6	12.8	11.9	11.7	12.9	12.6	13.4	13.4	12.0	11.3
Clear-Sky Solar Irradiance	taub	0.388	0.376	0.358	0.342	0.327	0.314	0.320	0.342	0.371	0.360	0.367	0.380	
	taud	2.354	2.400	2.455	2.470	2.479	2.505	2.474	2.407	2.316	2.384	2.383	2.367	
	Ebn at Noon	298	293	285	267	249	242	248	262	275	295	303	302	
	Edh at Noon	41	37	32	27	23	21	23	29	36	37	40	41	
All-Sky Solar Radiation	RadAvg	2489	2101	1622	1111	692	553	619	881	1318	1807	2278	2540	
	RadStd	102	90	75	69	49	37	51	84	95	113	107	138	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.50	N/A	N/A	+1.08	+1.19	+1.01	N/A	N/A	N/A	N/A
Regional (1 neighbor)		+0.50	N/A	N/A	+1.08	+1.19	+1.01	N/A	N/A	N/A	N/A

Nomenclature: See separate page