

TRELEW, Argentina

WMO: 878280

Lat: 43.2089S

Lon: 65.2822W

Elev: 43

StdP: 100.81

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.6	-2.0	-10.6	1.5	12.5	-9.0	1.8	10.6	17.5	11.8	14.7	11.7	2.4	320	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	34.0	17.8	31.9	17.0	30.0	16.3	19.6	29.3	18.5	27.7	17.5	26.6	8.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.0	21.4	15.4	11.0	20.5	14.2	10.1	20.0	56.3	28.8	52.6	27.9	49.5	26.5	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.9	12.6	DB	-7.1	38.0	2.0	1.3	-8.5	38.9	-9.7	39.7	-10.8	40.4	-12.3	41.3	(4)
(5)			WB	-7.6	21.9	2.0	1.2	-9.0	22.8	-10.2	23.6	-11.3	24.3	-12.8	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	21.2	20.1	18.0	14.1	10.1	7.0	6.7	8.5	10.8	14.1	17.0	19.6	(6)	
	DBStd	6.17	3.38	3.88	3.90	3.69	3.51	3.51	3.57	3.40	3.50	3.62	3.61	3.36	(7)	
	HDD10.0	373	0	0	1	6	42	100	114	69	31	8	1	0	(8)	
	HDD18.3	1938	12	23	54	134	254	339	361	304	228	138	66	24	(9)	
	CDD10.0	1801	347	283	249	131	47	11	12	24	54	134	211	299	(10)	
	CDD18.3	326	101	73	44	8	1	0	0	0	1	6	27	66	(11)	
	CDH23.3	3807	1124	837	482	94	5	0	0	0	21	109	363	771	(12)	
	CDH26.7	1431	472	358	170	19	0	0	0	0	4	22	111	275	(13)	
(14) Wind	WSAvg	5.8	7.0	6.6	5.9	5.2	4.5	4.6	5.0	5.4	5.7	6.4	6.9	6.7	(14)	
(15) Precipitation	PrecAvg	184	11	20	20	16	20	17	19	13	13	17	14	14	(15)	
	PrecMax	323	59	141	83	136	72	107	64	54	48	99	51	102	(16)	
	PrecMin	87	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	58	11	24	20	22	17	18	16	12	13	20	13	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.2	36.5	34.4	29.1	24.0	19.0	19.1	21.8	26.3	29.3	33.2	34.7	(19)	
		MCWB	18.4	19.0	18.4	16.3	13.4	10.4	10.9	11.1	12.5	14.8	16.6	17.4	(20)	
	2%	DB	33.7	33.5	30.7	26.0	20.8	16.4	16.7	19.0	22.3	26.1	29.6	31.9	(21)	
		MCWB	17.7	18.2	16.8	14.3	12.0	9.1	9.3	10.3	11.2	13.4	15.4	16.7	(22)	
	5%	DB	31.4	31.1	28.2	23.6	18.7	14.8	14.9	17.1	20.0	23.9	27.2	29.7	(23)	
		MCWB	16.8	17.1	15.9	13.4	10.9	8.5	8.4	9.1	10.1	12.6	14.3	15.7	(24)	
	10%	DB	29.3	28.6	25.9	21.2	16.8	13.1	13.1	15.1	17.9	21.7	25.1	27.8	(25)	
		MCWB	16.0	16.3	15.1	12.3	10.1	7.7	7.5	8.0	9.3	11.6	13.3	15.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.2	20.6	17.2	14.7	11.8	11.7	12.7	13.7	16.6	18.1	19.6	(27)	
		MCDB	31.2	30.9	30.3	26.1	21.1	16.3	16.8	19.0	22.5	26.4	29.1	29.4	(28)	
	2%	WB	19.2	19.6	18.6	15.6	13.3	10.4	10.3	11.1	12.0	14.8	16.5	18.0	(29)	
		MCDB	29.7	28.9	25.9	22.1	18.3	14.1	15.3	17.0	19.9	23.6	26.5	28.2	(30)	
	5%	WB	18.0	18.5	17.2	14.6	12.1	9.4	9.1	9.9	10.9	13.3	15.2	16.8	(31)	
		MCDB	27.6	27.5	25.0	20.8	16.9	13.2	13.9	15.4	18.1	21.5	25.1	27.2	(32)	
	10%	WB	17.0	17.4	16.1	13.5	11.0	8.4	7.9	8.9	10.0	12.2	14.1	15.7	(33)	
		MCDB	26.4	25.9	23.8	19.6	15.3	12.2	12.2	14.0	16.3	20.0	23.5	25.7	(34)	
(35) Mean Daily Temperature Range	MDBR		13.5	13.3	12.7	12.3	11.1	10.3	10.6	11.3	11.8	12.6	13.2	13.4	(35)	
	5% DB	MCDBR	17.6	17.9	16.6	15.2	13.4	11.8	12.3	13.9	15.2	16.3	16.8	17.1	(36)	
		MCWBR	6.6	6.5	6.9	7.3	7.5	6.9	7.1	7.6	7.5	7.5	7.1	6.7	(37)	
	5% WB	MCDBR	15.4	15.3	14.3	12.9	11.5	10.4	11.3	12.1	13.4	14.6	15.4	15.6	(38)	
		MCWBR	6.6	6.5	6.6	6.7	7.1	6.7	7.0	7.3	7.1	7.2	7.1	6.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.369	0.366	0.344	0.330	0.314	0.297	0.301	0.317	0.340	0.342	0.352	0.367	(40)	
	taud		2.413	2.430	2.485	2.510	2.532	2.564	2.550	2.512	2.431	2.445	2.428	2.408	(41)	
	Ebn at Noon		954	928	903	842	783	766	791	845	891	943	965	963	(42)	
	Edh at Noon		121	113	97	80	66	58	63	78	100	110	118	123	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.79	6.60	5.01	3.34	1.98	1.52	1.75	2.61	4.06	5.66	7.10	7.87	(44)	
	RadStd		0.25	0.29	0.22	0.18	0.16	0.10	0.13	0.19	0.29	0.25	0.26	0.42	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+0.71	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+34
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page