

COMODORO RIVADAVIA, Argentina

WMO: 878600

Lat: 45.7922S

Lon: 67.4619W

Elev: 151

StdP: 14.62

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	32.1	8.5	8.5	58.5	12.4	10.4	55.2	40.3	52.4	36.2	52.2	8.3	270	0.698

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.1	87.8	61.1	84.1	59.7	80.7	58.3	64.1	80.9	62.0	77.9	60.4	75.3	18.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.6	73.9	67.4	55.9	66.9	65.6	53.8	61.8	64.3	29.4	80.7	27.9	78.2	26.7	75.6	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.6	32.1	29.0	25.2	95.8	2.8	3.7	23.2	98.4	21.6	100.6	20.0	102.7	18.0	105.4		
(5)			23.3	67.8	2.4	2.7	21.6	69.7	20.2	71.3	18.8	72.9	17.1	74.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.9	67.1	65.6	62.0	56.6	50.5	45.7	44.9	47.2	50.6	55.5	60.3	64.9		
	DBStd	9.95	6.02	6.79	6.45	6.32	6.31	6.35	6.30	5.90	6.34	6.21	6.20	6.17		
	HDD50	638	0	0	2	13	70	158	180	124	68	21	2	0		
	HDD65	3698	46	69	136	263	450	580	623	551	434	300	167	79		
	CDD50	2775	531	436	373	210	86	28	22	38	86	191	311	463		
	CDD65	358	112	85	42	10	1	0	0	0	1	5	26	76		
	CDH74	3118	984	778	346	62	2	0	0	0	9	43	238	656		
	CDH80	894	306	265	85	8	0	0	0	0	0	4	51	175		
(14) Wind	WSAvg	13.4	15.4	13.4	12.6	12.9	11.6	12.6	12.3	12.4	12.4	13.7	15.3	15.6		
(15) Precipitation	PrecAvg	9.3	0.6	0.6	0.7	1.1	1.3	1.3	0.9	0.9	0.6	0.5	0.4	0.5		
	PrecMax	17.4	2.9	3.5	3.8	6.1	5.9	6.7	5.2	3.3	3.6	2.3	2.1	4.4		
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.0	0.7	0.7	0.8	1.3	1.3	1.3	0.9	0.9	0.6	0.5	0.5	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.5	93.4	87.4	80.5	71.3	64.8	64.2	67.2	74.9	79.0	86.0	89.8		
		MCWB	62.9	64.9	61.0	57.5	54.2	49.4	49.6	50.5	52.7	55.8	59.6	61.1		
	2%	DB	87.4	87.3	82.0	75.0	66.7	60.6	60.3	62.8	68.2	73.6	80.1	84.4		
		MCWB	61.1	61.4	59.2	56.5	52.2	48.2	47.7	48.2	50.4	53.2	56.8	59.5		
	5%	DB	82.8	82.5	77.3	70.6	64.2	57.5	57.2	59.4	64.5	69.9	76.2	80.7		
		MCWB	59.0	60.4	57.4	54.1	51.3	46.5	46.1	46.5	48.4	51.3	55.2	58.0		
	10%	DB	79.2	78.6	73.7	67.6	60.9	55.3	54.6	57.0	61.5	66.6	72.6	77.2		
		MCWB	57.4	58.3	55.9	52.6	49.2	45.2	44.4	45.2	46.8	49.8	53.4	56.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.8	67.3	63.9	60.4	56.6	51.4	51.2	52.5	54.5	58.3	61.5	64.7		
		MCDB	84.9	86.4	80.7	74.6	67.4	61.4	61.2	64.3	70.0	73.4	78.6	84.4		
	2%	WB	63.8	64.2	61.2	58.0	54.1	49.3	49.0	49.9	51.7	55.1	58.6	61.4		
		MCDB	79.6	80.8	75.0	70.4	64.2	58.1	58.1	60.4	64.7	69.4	75.8	79.5		
	5%	WB	61.5	62.0	59.5	55.8	52.2	47.7	46.9	48.0	49.9	53.0	56.5	59.3		
		MCDB	76.9	77.4	72.7	66.9	61.7	56.1	55.2	57.7	61.8	66.5	72.8	76.6		
	10%	WB	59.6	60.1	57.7	53.9	50.4	45.9	45.1	46.1	48.2	51.2	54.5	57.7		
		MCDB	75.5	74.1	70.6	64.8	58.7	53.5	53.1	54.5	59.0	64.1	69.6	74.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.1	19.5	18.6	16.7	14.2	12.7	13.1	14.6	16.3	18.4	19.7	20.1		
		MCDBR	25.8	26.7	24.4	21.0	17.4	14.1	15.2	17.2	20.6	22.6	25.1	25.4		
		MCWBR	10.6	10.9	11.1	10.8	10.1	8.9	8.9	9.6	10.4	10.6	11.5	10.9		
	5% WB	MCDBR	23.5	23.6	21.6	19.2	16.2	13.7	14.7	16.1	19.3	21.2	23.7	23.8		
		MCWBR	11.4	11.0	11.2	11.5	10.4	9.4	9.4	9.9	10.9	11.3	12.2	11.3		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.339	0.317	0.309	0.293	0.282	0.282	0.297	0.314	0.318	0.322	0.335		
	taud		2.537	2.525	2.583	2.595	2.594	2.579	2.592	2.579	2.527	2.528	2.536	2.512		
	Ebn at Noon		313	301	293	271	250	240	252	271	289	305	315	315		
	Edh at Noon		33	32	27	23	18	16	18	22	28	31	33	35		
(44) All-Sky Solar Radiation	RadAvg		2380	1981	1440	938	549	408	475	745	1200	1747	2204	2430		
	RadStd		79	108	66	46	36	26	30	60	69	78	66	120		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.63	N/A	+4.48	+0.86	+1.66	+2.03	N/A	-189	+130	+43
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page