

RIO GALLEGOS, Argentina

WMO: 879250

Lat: 51.6117S

Lon: 69.3081W

Elev: 62

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	23.0	13.7	11.0	35.4	16.2	12.5	39.8	37.9	39.3	33.3	39.7	5.7	270	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.0	75.6	56.7	72.0	54.6	69.5	53.2	58.5	71.8	56.5	68.9	54.7	65.8	18.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
52.2	58.2	60.1	50.4	54.3	58.8	48.6	50.8	57.4	25.5	71.6	24.2	69.0	23.1	66.0	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
40.8	35.1	31.3	DB	12.8	84.4	5.7	3.5	8.7	86.9	5.3	88.9	2.1	90.9	-2.1	93.4	
			WB	11.9	63.0	5.7	2.0	7.8	64.4	4.5	65.5	1.3	66.7	-2.8	68.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	56.4	55.7	52.3	46.5	40.2	35.1	35.2	38.1	42.8	47.2	51.1	54.4
	DBStd	9.16	5.04	5.92	5.69	5.27	5.26	5.75	5.36	4.68	4.81	4.88	5.16	5.01
	HDD50	2159	5	12	40	129	304	446	460	368	221	114	46	14
	HDD65	6873	272	267	395	555	768	896	924	833	666	551	417	329
	CDD50	774	202	170	111	25	2	0	0	0	5	28	79	152
	CDD65	12	4	6	1	0	0	0	0	0	0	0	0	1
	CDH74	204	56	92	18	1	0	0	0	0	0	0	8	29
	CDH80	30	5	18	3	0	0	0	0	0	0	0	1	3
Wind	WSAvg	14.2	16.7	15.3	14.2	13.5	11.7	11.7	11.9	12.8	13.5	15.4	16.9	16.9
Precipitation	PrecAvg	10.1	1.1	1.0	0.9	0.9	0.9	0.8	0.7	0.6	0.5	0.6	0.8	1.1
	PrecMax	16.4	3.6	2.8	3.0	3.7	3.1	3.7	2.5	1.6	1.5	2.2	3.9	3.1
	PrecMin	5.0	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	2.6	0.7	0.6	0.7	0.7	0.6	0.7	0.5	0.4	0.4	0.6	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.4	82.5	75.9	66.6	58.5	53.6	52.1	55.4	63.2	69.6	74.3	77.4
		MCWB	58.0	60.6	57.7	52.6	48.6	44.4	44.1	44.6	48.1	51.5	54.4	57.2
	2%	DB	74.9	76.6	70.2	62.7	54.0	48.5	47.6	51.3	59.0	64.8	69.6	72.0
		MCWB	55.8	58.2	54.4	50.4	46.1	42.6	41.2	42.3	46.0	48.9	52.3	53.9
	5%	DB	71.3	71.5	66.4	59.1	51.5	45.1	44.7	48.3	55.4	61.2	65.9	68.4
		MCWB	54.0	55.5	52.2	48.7	44.6	40.6	39.6	40.9	44.0	47.2	50.1	52.2
	10%	DB	67.7	67.4	62.8	55.8	48.5	43.1	42.6	46.0	52.1	58.6	62.5	65.1
		MCWB	52.1	53.0	50.5	47.0	43.2	39.3	38.1	39.6	42.5	45.7	48.5	50.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	62.2	59.0	54.9	50.2	45.8	44.7	45.8	49.4	52.7	56.0	59.0
		MCDB	75.8	79.0	72.4	64.1	55.9	51.0	49.5	53.0	61.0	66.4	70.3	73.1
	2%	WB	57.4	59.1	55.8	51.7	47.6	43.4	41.9	43.2	46.9	50.3	53.5	56.0
		MCDB	71.2	72.9	66.6	59.6	51.8	46.8	45.8	48.8	56.3	62.7	66.4	68.5
	5%	WB	55.3	56.8	53.9	50.0	45.6	41.4	40.3	41.6	45.1	48.4	51.4	54.0
		MCDB	67.3	68.9	63.6	56.8	49.3	44.3	43.7	46.5	53.3	59.5	63.0	65.3
	10%	WB	53.4	54.4	52.0	48.3	44.0	39.7	38.6	40.0	43.4	46.5	49.7	52.0
		MCDB	64.6	64.6	60.7	54.8	47.7	42.8	42.0	44.4	50.3	56.3	60.0	63.1
Mean Daily Temperature Range	5% DB	MDBR	20.0	20.2	18.9	17.2	13.9	11.6	11.7	13.3	17.2	20.6	20.3	19.8
		MCDBR	25.2	26.5	23.6	21.1	17.1	12.6	12.9	16.5	21.7	25.3	25.5	24.6
		MCWBR	11.8	13.0	11.9	12.6	11.3	9.2	9.2	10.3	12.1	13.5	12.6	11.9
	5% WB	MCDBR	22.7	25.3	21.6	19.5	14.8	11.5	12.2	14.7	20.1	24.0	23.1	22.5
		MCWBR	12.0	13.1	11.9	12.6	11.2	9.1	9.5	10.3	12.1	13.6	12.4	12.4
Clear-Sky Solar Irradiance	taub	0.321	0.317	0.307	0.299	0.280	0.274	0.280	0.295	0.305	0.313	0.313	0.317	
	taud	2.544	2.561	2.586	2.578	2.553	2.476	2.515	2.543	2.528	2.517	2.537	2.544	
	Ebn at Noon	313	303	288	259	231	209	226	256	283	301	314	317	
	Edh at Noon	32	30	25	20	16	14	16	20	26	30	32	33	
All-Sky Solar Radiation	RadAvg	1884	1583	1101	661	358	245	304	550	964	1462	1805	1957	
	RadStd	118	78	67	31	24	21	19	32	60	47	101	126	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	-158	N/A	N/A	N/A
Regional (1 neighbor)	N/A	+1.35	N/A	N/A	N/A	-0.72	-151	N/A	N/A	N/A

Nomenclature: See separate page