

USHUAIA, Argentina

WMO: 879380

Lat: 54.8400S

Lon: 68.3033W

Elev: 57

StdP: 100.64

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-4.2	-2.9	-7.5	2.0	1.1	-6.2	2.3	1.8	20.0	3.1	18.1	3.2	3.8	230	0.853

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.5	18.2	11.8	16.6	10.7	15.1	9.9	12.7	16.8	11.5	15.4	10.5	14.1	5.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.4	7.9	13.9	9.2	7.3	12.5	8.3	6.9	11.6	36.2	17.0	33.2	15.4	30.9	14.2	17.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	16.0	14.3	DB	-5.2	22.7	1.5	2.1	-6.3	24.2	-7.2	25.5	-8.1	26.7	-9.2	28.2	(4)
(5)			WB	-5.9	15.1	1.6	1.0	-7.1	15.8	-8.0	16.4	-8.9	17.0	-10.0	17.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	9.5	9.7	8.5	6.4	4.3	2.3	2.2	3.0	4.5	6.3	7.5	8.7		
	DBStd	3.70	2.45	2.72	2.71	2.67	2.48	2.58	2.64	2.31	2.64	2.67	2.77	2.46		
	HDD10.0	1541	39	36	62	112	176	232	243	218	167	117	84	55		
	HDD18.3	4485	274	243	305	357	434	482	501	476	416	372	327	298		
	CDD10.0	96	24	26	16	4	1	0	0	0	1	3	8	15		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	2	0	2	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.9	6.9	6.5	5.9	5.5	4.8	4.8	5.1	5.2	5.6	6.4	6.8	6.9		
(15) Precipitation	PrecAvg	492	43	43	46	51	45	50	38	40	34	32	36	43		
	PrecMax	768	121	138	172	118	171	181	124	145	95	82	77	110		
	PrecMin	216	13	5	9	10	2	6	4	4	1	7	1	4		
	PrecStd	136	20	30	29	29	29	36	21	27	18	17	18	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	21.8	19.1	16.8	13.1	10.5	10.8	11.0	14.1	16.2	18.3	19.2		
		MCWB	13.6	13.9	12.9	10.7	7.9	6.5	5.2	5.9	7.9	9.1	11.5	12.1		
	2%	DB	17.2	17.9	16.2	13.5	10.9	8.9	8.3	9.0	11.8	13.9	15.2	16.4		
		MCWB	11.0	12.0	11.0	8.9	7.0	5.7	4.5	5.0	6.8	8.0	9.5	10.2		
	5%	DB	15.5	15.9	14.2	11.8	9.1	7.2	7.0	7.7	10.0	12.1	13.7	14.7		
		MCWB	10.2	10.9	9.7	8.0	6.1	4.5	4.0	4.3	5.7	7.0	8.4	9.2		
	10%	DB	14.0	14.1	12.8	10.4	7.9	6.0	5.9	6.3	8.6	10.8	12.1	13.0		
		MCWB	9.4	9.9	9.0	7.4	5.5	3.8	3.4	3.6	5.0	6.4	7.6	8.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	14.6	13.6	11.2	9.0	7.5	6.4	6.6	8.8	10.0	11.9	12.8		
		MCDB	19.3	19.5	17.9	15.1	12.3	10.1	9.5	9.9	13.1	14.7	16.7	18.0		
	2%	WB	12.0	12.8	11.6	9.6	7.6	5.9	5.1	5.4	7.2	8.5	10.1	10.9		
		MCDB	16.2	16.4	15.2	12.6	9.8	8.0	7.3	7.8	10.7	12.6	14.2	15.4		
	5%	WB	10.8	11.5	10.3	8.5	6.6	4.9	4.2	4.7	6.1	7.6	9.0	9.7		
		MCDB	14.5	14.9	13.4	11.1	8.4	6.5	6.2	6.7	8.9	11.2	12.9	13.5		
	10%	WB	9.8	10.4	9.5	7.6	5.7	4.0	3.6	4.0	5.3	6.7	8.1	8.8		
		MCDB	13.3	13.4	12.3	9.9	7.4	5.6	5.3	5.9	7.8	10.0	11.4	12.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.5	6.2	5.3	4.4	3.9	4.1	4.8	5.7	6.5	6.7	6.7		
		MCDBR	9.6	9.8	8.7	7.7	6.3	5.7	5.8	6.4	8.0	8.7	9.4	9.6		
	5% WB	MCWBR	5.2	5.7	5.3	4.7	4.0	3.6	3.5	4.0	4.6	4.9	5.2	5.3		
		MCWBR	9.1	8.9	8.0	6.8	5.4	4.9	4.8	5.6	7.1	8.1	8.7	8.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.323	0.321	0.312	0.307	0.284	0.264	0.278	0.296	0.309	0.315	0.317	0.323		
		taud	2.530	2.541	2.560	2.519	2.400	2.235	2.244	2.383	2.490	2.502	2.513	2.514		
	Ebn at Noon	Ebn at Noon	976	939	883	769	641	553	612	757	869	936	976	986		
		Edh at Noon	101	92	78	62	48	43	53	68	81	94	102	105		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.83	3.92	2.55	1.38	0.71	0.42	0.54	1.10	2.20	3.55	4.59	5.12		
	RadStd	RadStd	0.23	0.26	0.19	0.10	0.07	0.04	0.05	0.07	0.16	0.22	0.30	0.32		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page