

WEDDELL ISLAND, Falkland Islands (Malvinas)

WMO: 888830

Lat: **51.891S**Lon: **60.912W**Elev: **56**StdP: **14.67**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.5	31.1	20.4	15.3	35.7	23.3	17.6	34.2	38.5	38.3	34.2	37.5	11.4	210	0.889

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	62.1	53.6	60.0	52.2	58.0	51.3	55.4	59.7	54.0	57.6	52.7	56.1	15.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.4	60.8	56.3	52.1	57.9	55.1	50.8	55.2	54.0	23.6	59.7	22.7	57.4	22.0	56.3	61.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.8	29.9	27.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	50.4	49.7	47.9	44.5	41.5	39.4	38.1	38.6	39.8	43.0	45.6	48.8	(6)
(7)		DBStd	5.66	3.81	3.66	4.22	3.72	3.34	3.56	3.42	3.05	3.31	3.56	3.89	4.07	(7)
(8)		HDD50	2386	43	45	90	165	263	319	370	353	307	220	140	71	(8)
(9)		HDD65	7699	454	427	531	614	728	769	835	818	757	683	582	501	(9)
(10)		CDD50	162	54	38	24	2	0	0	0	0	0	1	8	35	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	14.7	15.8	15.4	14.8	14.2	13.8	13.5	14.8	14.2	13.9	15.1	16.1	15.3	(14)
(15)	Precipitation	PrecAvg	33.4	2.7	2.4	3.5	3.3	3.0	2.8	2.8	2.6	2.6	2.5	2.5	2.5	(15)
(16)		PrecMax	42.2	3.6	3.1	4.6	4.8	4.9	4.6	4.7	4.7	5.4	5.2	3.8	4.1	(16)
(17)		PrecMin	27.8	1.7	1.7	1.9	1.7	1.3	1.4	0.9	1.7	1.2	1.6	1.7	1.6	(17)
(18)		PrecStd	3.3	0.5	0.5	0.6	0.8	0.7	0.8	0.8	0.6	0.8	0.7	0.5	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.3	64.4	62.8	56.2	51.8	50.1	48.3	47.8	51.9	57.6	60.2	64.8	(19)
(20)			MCWB	55.9	55.8	55.2	51.2	47.3	45.9	44.3	43.2	45.0	48.4	51.0	53.8	(20)
(21)		2%	DB	61.9	60.8	58.5	53.7	49.2	47.3	45.9	45.9	49.1	53.9	57.2	61.1	(21)
(22)			MCWB	53.8	53.5	52.5	49.8	46.0	44.9	43.3	42.4	44.0	46.8	49.3	51.7	(22)
(23)		5%	DB	59.5	58.2	56.0	51.9	47.8	45.8	44.4	44.6	46.8	51.2	54.7	58.9	(23)
(24)			MCWB	52.5	52.0	51.5	48.9	45.1	44.0	42.3	41.8	42.7	45.1	47.9	51.1	(24)
(25)		10%	DB	57.2	56.1	54.2	50.3	46.7	44.6	43.2	43.4	44.9	49.3	52.7	56.5	(25)
(26)			MCWB	51.4	51.4	50.7	47.8	44.5	43.0	41.5	41.0	41.7	44.1	46.9	49.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.8	57.2	56.0	52.4	48.7	46.7	45.0	44.3	46.1	49.8	52.3	55.6	(27)
(28)			MCD B	63.7	62.3	59.6	54.7	50.3	48.7	47.0	46.3	50.3	56.2	57.8	62.6	(28)
(29)		2%	WB	55.3	55.1	54.2	51.0	47.1	45.5	43.9	43.2	44.5	47.4	50.3	53.3	(29)
(30)			MCD B	60.1	58.2	56.6	52.7	48.3	47.1	45.3	45.0	47.7	52.2	55.6	59.0	(30)
(31)		5%	WB	53.7	53.6	52.8	49.5	46.0	44.4	42.9	42.2	43.3	45.9	48.8	51.9	(31)
(32)			MCD B	57.8	56.2	55.0	51.1	47.2	45.8	44.1	43.9	45.7	50.1	53.6	56.8	(32)
(33)		10%	WB	52.1	52.1	51.3	48.3	45.0	43.3	41.9	41.3	42.2	44.7	47.4	50.5	(33)
(34)			MCD B	56.0	55.0	53.4	49.9	46.4	44.4	43.1	43.0	44.3	48.2	51.5	55.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.6	10.3	9.8	8.5	7.1	6.0	6.3	7.2	8.7	11.3	11.8	12.8	(35)
(36)			MCDBR	14.7	13.6	12.2	10.5	8.4	7.0	7.3	8.6	11.8	14.4	14.9	16.5	(36)
(37)			MCWBR	9.2	9.0	8.5	8.3	7.3	6.0	6.3	6.8	8.5	9.2	9.5	10.2	(37)
(38)		5% WB	MCD BR	13.5	12.2	10.9	9.8	8.0	6.8	7.3	8.3	10.8	13.1	14.4	15.6	(38)
(39)			MCWBR	9.4	9.2	8.3	8.3	7.5	6.1	6.5	7.0	8.2	9.1	9.9	10.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.333	0.325	0.322	0.307	0.300	0.306	0.318	0.321	0.322	0.329	0.338	(40)	
(41)		taud	2.521	2.539	2.549	2.491	2.393	2.313	2.359	2.440	2.496	2.511	2.510	2.502	(41)	
(42)		Ebn at Noon	307	297	280	247	211	187	206	244	277	298	308	310	(42)	
(43)		Edh at Noon	33	30	26	22	18	16	18	23	27	30	33	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1957	1569	1065	594	299	188	229	465	879	1440	1916	2166	(44)	
(45)		RadStd	79	100	86	35	18	12	16	41	70	68	115	151	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page