

SEA LION ISLAND, Falkland Islands (Malvinas)

WMO: 888970

Lat: 52.426S

Lon: 59.076W

Elev: 15

StdP: 101.14

Time Zone: -3.00 (W03)

Period: 91-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-1.5	-0.4	-6.5	2.2	0.2	-5.2	2.4	0.7	17.5	3.0	15.7	3.4	7.7	190	0.932

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.5	15.6	12.5	14.5	11.7	13.5	11.1	13.2	14.7	12.3	13.9	11.5	13.0	6.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.0	13.7	11.5	8.5	13.0	10.7	8.0	12.2	37.5	14.9	35.2	13.9	33.3	13.1	16.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	14.4	13.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	9.7	9.7	9.3	7.1	5.4	3.7	3.4	3.5	4.7	6.1	7.6	8.8
	DBStd	3.04	1.83	2.12	2.10	2.12	1.86	1.65	1.84	1.87	1.80	1.93	1.95	2.18
	HDD10.0	1325	27	28	39	90	143	188	203	203	158	121	76	49
	HDD18.3	4293	267	242	281	338	401	438	462	461	408	379	322	295
	CDD10.0	74	19	20	17	2	0	0	0	0	0	1	3	13
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.2	7.2	6.6	6.8	7.6	7.1	7.3	7.5	7.7	7.0	7.1	7.7	7.0
Precipitation	PrecAvg	800	69	63	80	75	73	69	65	67	59	60	57	64
	PrecMax	1075	97	93	122	126	114	138	137	120	139	162	94	122
	PrecMin	646	42	37	44	32	38	30	33	38	29	33	32	34
	PrecStd	99	15	14	19	24	18	23	23	17	23	22	13	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.8	16.9	16.0	12.7	10.7	7.9	8.5	8.0	10.7	13.1	15.2	17.0
		MCWB	13.2	14.2	13.0	10.7	8.7	6.8	6.9	6.1	7.9	9.8	10.9	12.9
	2%	DB	15.1	15.3	14.4	11.6	9.5	7.2	7.5	7.1	9.3	11.4	13.2	14.9
		MCWB	12.3	12.7	12.0	9.9	8.2	6.4	6.1	5.6	7.1	8.8	10.1	11.4
	5%	DB	13.9	14.0	13.4	10.7	8.8	6.6	6.7	6.5	8.1	10.1	11.8	13.4
		MCWB	11.3	11.7	11.4	9.4	7.8	5.8	5.4	5.2	6.3	7.8	9.1	10.5
	10%	DB	12.7	12.8	12.3	10.0	8.1	6.0	6.0	5.9	7.2	9.1	10.7	12.1
		MCWB	10.5	10.9	10.7	8.9	7.2	5.3	4.9	4.7	5.8	7.1	8.4	9.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	14.6	13.8	11.2	9.3	7.2	7.1	6.5	8.2	10.7	11.7	13.5
		MCDB	15.9	16.9	15.1	12.1	10.1	7.5	8.2	7.3	10.3	12.5	14.2	16.1
	2%	WB	12.8	13.1	12.6	10.3	8.6	6.5	6.3	5.8	7.2	9.2	10.5	12.1
		MCDB	14.5	14.5	13.7	11.1	9.2	6.9	7.1	6.8	8.9	10.9	12.8	14.4
	5%	WB	11.8	12.1	11.7	9.6	8.0	6.0	5.6	5.4	6.6	8.1	9.4	10.9
		MCDB	13.4	13.5	12.9	10.5	8.6	6.5	6.4	6.2	7.9	9.7	11.3	12.8
	10%	WB	10.8	11.3	10.9	8.9	7.3	5.4	5.1	4.9	6.0	7.2	8.6	9.9
		MCDB	12.2	12.5	12.1	9.9	8.0	5.9	5.8	5.7	7.0	8.8	10.3	11.8
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.5	4.0	3.6	2.8	2.6	2.7	3.0	4.1	4.7	5.1	5.4
		MCDBR	6.6	6.1	5.4	4.4	3.4	2.9	3.2	3.6	5.3	5.9	7.1	7.5
		MCWBR	4.4	4.4	4.0	3.6	3.0	2.9	3.0	3.0	3.8	3.9	4.7	4.9
	5% WB	MCDBR	6.3	6.2	5.3	4.2	3.2	2.9	2.9	3.4	5.1	5.6	6.6	7.1
		MCWBR	4.5	4.7	4.3	3.7	3.1	3.0	2.8	3.1	3.9	4.0	4.8	5.0
Clear-Sky Solar Irradiance	taub	0.342	0.335	0.327	0.324	0.307	0.300	0.306	0.318	0.322	0.325	0.330	0.339	
	taud	2.505	2.532	2.539	2.475	2.374	2.285	2.336	2.425	2.491	2.499	2.507	2.499	
	Ebn at Noon	962	933	879	771	652	574	636	760	868	934	970	975	
	Edh at Noon	105	95	83	69	56	51	57	71	85	97	104	108	
All-Sky Solar Radiation	RadAvg	5.96	4.71	3.21	1.76	0.88	0.54	0.66	1.37	2.63	4.38	5.78	6.61	
	RadStd	0.25	0.32	0.25	0.13	0.05	0.03	0.04	0.10	0.21	0.26	0.40	0.56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page