

NORDENSKIOLD BASE, Antarctica

WMO: 890140

Lat: 73.050S

Lon: 13.383W

Elev: 497

StdP: 95.50

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -34.6	(c) -32.2	(d) -42.4	(e) 0.1	(f) -24.8	(g) -40.2	(h) 0.1	(i) -26.8	(j) 36.4	(k) -15.1	(l) 33.9	(m) -15.3	(n) 6.8	(o) 30	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 4.2	(c) -0.2	(d) -2.9	(e) -1.4	(f) -3.7	(g) -2.5	(h) -4.4	(i) -2.6	(j) -0.9	(k) -3.4	(l) -1.9	(m) -4.1	(n) -2.7	(o) 5.6	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
-4.0	2.9	-2.9	-5.0	2.6	-3.5	-5.9	2.4	-4.1	5.8	-0.8	4.4	-1.8	3.2	-2.6	0.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 35.2	(b) 30.3	(c) 25.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 35.2	(b) 30.3	(c) 25.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-15.2	-5.5	-9.0	-13.6	-17.1	-18.3	-20.3	-22.0	-21.9	-20.9	-17.4	-10.2	-6.0
	DBStd	7.20	2.16	3.11	3.60	4.54	5.08	4.83	4.82	5.64	4.80	4.46	3.12	2.21
	HDD10.0	9206	482	532	732	812	878	910	992	990	926	848	607	497
	HDD18.3	12248	741	765	990	1062	1136	1160	1251	1248	1176	1106	857	756
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.9	6.8	7.7	9.1	8.9	11.0	9.5	9.1	8.4	10.5	8.2	9.9	7.4
Precipitation	PrecAvg	462	29	26	33	33	44	36	36	43	44	48	55	35
	PrecMax	730	75	77	106	77	100	100	93	87	119	100	134	80
	PrecMin	218	6	2	7	6	10	6	6	8	6	4	12	7
	PrecStd	144	18	17	21	21	24	24	22	21	28	26	31	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.2	0.9	-4.8	-6.2	-6.5	-8.0	-10.4	-6.4	-10.2	-6.7	-2.5	1.2
		MCWB	-1.6	-2.3	-5.6	-7.4	-7.0	-9.4	-11.8	-7.6	-12.0	-8.4	-4.6	-2.6
	2%	DB	-0.1	-2.5	-6.3	-8.3	-8.0	-10.5	-12.2	-8.9	-11.8	-8.4	-4.0	-0.3
		MCWB	-2.4	-4.7	-7.1	-9.0	-8.6	-11.3	-13.1	-9.9	-13.1	-9.7	-6.0	-3.2
	5%	DB	-1.3	-3.7	-7.3	-9.5	-9.5	-11.8	-13.5	-11.5	-12.8	-9.9	-5.4	-1.5
		MCWB	-3.3	-5.3	-8.2	-10.3	-10.3	-12.8	-14.2	-12.7	-13.7	-11.2	-6.7	-3.9
	10%	DB	-2.2	-4.7	-8.4	-10.7	-11.0	-13.1	-14.9	-14.3	-14.0	-11.3	-6.2	-2.6
		MCWB	-4.1	-6.1	-9.2	-11.5	-11.9	-14.0	-15.8	-15.3	-14.6	-12.4	-7.4	-4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.1	-2.9	-5.2	-6.8	-6.6	-9.5	-12.0	-6.8	-11.5	-7.6	-3.8	-1.5
		MCDB	0.6	-2.0	-5.1	-6.6	-6.6	-8.8	-11.1	-6.2	-10.4	-7.0	-2.6	0.5
	2%	WB	-2.2	-4.3	-6.9	-8.6	-8.2	-11.3	-13.2	-9.7	-12.9	-9.5	-5.4	-2.9
		MCDB	-0.5	-3.3	-6.4	-8.2	-7.9	-10.8	-12.6	-8.8	-12.1	-8.4	-4.6	-0.9
	5%	WB	-3.1	-5.2	-8.0	-10.2	-9.9	-13.0	-14.6	-12.4	-13.8	-11.0	-6.3	-3.6
		MCDB	-1.7	-4.2	-7.4	-9.6	-9.4	-12.4	-14.1	-11.3	-13.0	-10.0	-5.5	-1.8
	10%	WB	-3.8	-6.0	-9.1	-11.4	-11.7	-14.4	-16.4	-14.7	-14.8	-12.2	-7.1	-4.3
		MCDB	-2.5	-5.0	-8.4	-10.7	-10.8	-13.5	-15.7	-14.0	-14.1	-11.3	-6.2	-2.6
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.3	4.4	5.0	5.2	5.4	5.8	5.6	5.2	4.9	4.4	4.2
		MCDBR	5.0	4.9	4.1	5.2	4.8	5.4	6.0	6.1	5.0	5.2	5.0	5.3
		MCWBR	3.9	4.1	4.1	4.8	4.5	4.9	6.2	5.6	4.7	4.6	4.4	4.1
	5% WB	MCDBR	4.7	4.5	4.0	4.9	4.3	4.9	6.3	6.1	4.8	5.0	4.6	4.9
		MCWBR	3.9	4.0	4.0	4.8	4.3	4.7	6.1	5.7	4.4	4.5	4.1	3.9
Clear-Sky Solar Irradiance	taub	0.231	0.215	0.187	0.115	N/A	N/A	N/A	0.112	0.174	0.197	0.214	0.230	
	taud	2.203	2.225	2.211	1.910	N/A	N/A	N/A	1.876	2.152	2.182	2.200	2.190	
	Ebn at Noon	1001	951	848	554	0	0	0	537	850	970	1020	1022	
	Edh at Noon	111	90	60	22	0	0	0	22	62	93	111	119	
All-Sky Solar Radiation	RadAvg	8.20	5.24	2.23	0.42	0.00	0.00	0.00	0.14	1.42	4.08	7.42	9.41	
	RadStd	0.21	0.15	0.08	0.03	0.00	0.00	0.00	0.01	0.08	0.16	0.20	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page