

SKY-BLU, Antarctica

WMO: 892720

Lat: 74.792S

Lon: 71.490W

Elev: 5213

StdP: 12.13

Time Zone: -3.00 (W03)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-47.6	-43.3	-56.3	0.2	-47.8	-51.6	0.3	-43.4	98.6	-5.1	81.8	3.4	11.3	50	1.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.0	27.8	24.1	24.1	21.4	21.2	18.8	21.9	24.0	18.8	20.7	16.9	18.6	7.9	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	17.1	22.4	15.8	14.8	19.7	13.8	13.5	17.6	8.5	24.0	7.3	21.0	6.6	18.7	41.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 67.7	56.5	47.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.3	11.8	5.6	-1.5	-8.2	-8.2	-13.6	-16.5	-15.1	-11.7	-6.2	1.9	10.8		
	DBStd	14.49	6.48	7.80	11.02	12.31	12.02	12.84	13.51	13.30	13.70	10.39	7.82	6.15		
	HDD50	19812	1185	1243	1595	1745	1805	1907	2063	2019	1850	1742	1443	1215		
	HDD65	25287	1650	1663	2060	2195	2270	2357	2528	2484	2300	2207	1893	1680		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.3	13.1	15.6	16.9	18.2	21.0	18.9	24.0	19.9	22.4	18.7	16.0	14.7		
	PrecAvg	21.5	1.1	1.3	1.7	1.7	2.1	1.7	2.0	2.4	2.6	2.2	1.7	1.1		
(15) Precipitation	PrecMax	28.0	2.5	2.5	2.8	2.7	3.6	3.3	5.2	3.4	4.7	4.2	3.0	3.6		
	PrecMin	16.9	0.3	0.4	0.6	0.7	1.1	0.6	0.8	0.7	1.1	0.7	0.1	0.1		
	PrecStd	3.0	0.6	0.6	0.6	0.5	0.6	0.7	0.9	0.6	0.8	0.9	0.7	0.7		
	PrecStd	3.0	0.6	0.6	0.6	0.5	0.6	0.7	0.9	0.6	0.8	0.9	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.6	26.2	21.8	17.5	18.6	15.0	12.1	12.0	15.8	17.1	24.8	35.1		
		MCWB	33.2	25.2	21.2	17.0	18.1	13.6	11.8	11.2	14.6	16.4	22.1	33.4		
	2%	DB	28.5	22.2	17.6	14.2	14.5	11.9	8.8	9.2	12.7	14.7	20.0	27.9		
		MCWB	24.4	20.3	16.2	13.6	13.7	11.1	8.0	8.3	12.0	14.0	18.0	23.6		
	5%	DB	24.9	19.2	15.3	11.8	11.6	8.9	6.3	6.5	10.4	12.2	16.9	23.6		
		MCWB	21.3	17.9	14.4	10.9	10.9	8.3	5.6	5.8	9.8	11.4	15.2	20.4		
	10%	DB	21.5	16.6	13.2	9.1	8.3	4.8	3.4	3.7	7.6	9.1	14.3	20.5		
		MCWB	18.8	15.2	12.3	8.3	7.6	4.1	2.7	2.9	6.9	8.2	12.8	17.7		
	0.4%	WB	32.6	21.9	21.3	16.8	18.8	12.5	11.3	10.8	14.4	16.8	21.7	35.0		
		MCDB	34.0	23.1	22.0	17.2	19.1	12.8	11.7	11.1	14.9	17.2	23.6	37.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.4	18.4	16.4	12.9	12.6	10.3	8.0	8.8	11.6	13.8	16.2	22.0		
		MCDB	22.8	19.7	17.3	13.3	13.1	11.0	8.6	9.5	12.0	14.4	17.7	24.8		
	5%	WB	18.0	15.6	14.3	10.7	9.4	6.9	5.5	6.7	9.8	10.9	13.9	18.7		
		MCDB	19.8	16.7	15.1	11.4	10.0	7.5	6.1	7.2	10.3	11.7	15.3	21.2		
	10%	WB	16.2	13.8	12.3	7.7	6.2	3.2	2.8	4.3	7.4	7.6	11.4	16.4		
		MCDB	17.8	14.7	13.1	8.4	6.8	3.9	3.4	5.0	8.1	8.4	12.7	18.5		
	5% DB	MDBR	16.0	15.4	15.2	15.2	15.2	15.1	16.5	14.7	15.4	16.1	16.8	15.4		
		MCDBR	22.3	17.1	12.9	13.2	13.1	13.3	16.3	13.6	15.6	14.5	19.5	21.9		
		MCWBR	14.4	13.3	10.5	12.6	12.9	13.9	17.0	10.9	13.5	12.5	14.8	16.5		
		MCWBR	15.2	12.3	10.7	13.2	13.0	15.5	17.2	11.5	13.6	11.9	15.2	17.0		
(40) Clear-Sky Solar Irradiance	taub	0.196	0.187	0.164	0.098	N/A	N/A	N/A	N/A	0.100	0.159	0.176	0.186	0.195		
		2.296	2.305	2.250	1.902	N/A	N/A	N/A	N/A	1.888	2.181	2.255	2.287	2.296		
	Ebn at Noon	332	313	276	154	0	0	0	0	142	272	316	335	338		
	Edh at Noon	31	25	16	4	0	0	0	0	4	17	26	31	33		
(44) All-Sky Solar Radiation	RadAvg	2690	1643	641	90	0	0	0	0	29	376	1236	2370	3059		
	RadStd	64	42	28	4	0	0	0	0	1	14	38	61	67		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page