

SKY-BLU, Antarctica

WMO: 892720

Lat: 74.792S

Lon: 71.490W

Elev: 1589

StdP: 83.64

Time Zone: -3.00 (W03)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -44.2	(c) -41.8	(d) -49.1	(e) 0.0	(f) -44.3	(g) -46.5	(h) 0.0	(i) -41.9	(j) 44.1	(k) -20.6	(l) 36.6	(m) -15.9	(n) 5.0	(o) 50	(p) 1.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 8.9	(c) -2.3	(d) -4.4	(e) -4.4	(f) -5.9	(g) -6.0	(h) -7.3	(i) -5.6	(j) -4.4	(k) -7.3	(l) -6.3	(m) -8.4	(n) -7.5	(o) 3.5	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
-7.4	2.4	-5.3	-9.0	2.1	-6.9	-10.1	1.9	-8.0	1.8	-4.5	-0.8	-6.1	-2.5	-7.4	5.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 30.3	(b) 25.3	(c) 21.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 30.3	(b) 25.3	(c) 21.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-20.2	-11.2	-14.7	-18.6	-22.3	-22.4	-25.3	-27.0	-26.2	-24.3	-21.2	-16.7	-11.8		
	DBStd	8.05	3.60	4.33	6.12	6.84	6.68	7.13	7.51	7.39	7.61	5.77	4.35	3.42		
	HDD10.0	11007	658	691	886	969	1003	1059	1146	1122	1028	968	802	675		
	HDD18.3	14048	917	924	1144	1219	1261	1309	1404	1380	1278	1226	1052	933		
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.2	5.9	7.0	7.6	8.1	9.4	8.4	10.7	8.9	10.0	8.4	7.1	6.5		
(15) Precipitation	PrecAvg	546	28	34	42	42	53	44	52	61	66	57	42	27		
	PrecMax	712	64	63	70	69	92	84	133	86	120	107	75	92		
	PrecMin	429	7	10	15	19	27	16	21	18	29	17	2	3		
	PrecStd	76	14	14	14	12	16	17	22	15	20	22	19	19		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.4	-3.2	-5.7	-8.1	-7.5	-9.5	-11.0	-11.1	-9.0	-8.3	-4.0	1.7		
		MCWB	0.7	-3.8	-6.0	-8.3	-7.7	-10.2	-11.2	-11.6	-9.7	-8.7	-5.5	0.8		
	2%	DB	-2.0	-5.5	-8.0	-9.9	-9.7	-11.2	-12.9	-12.7	-10.7	-9.6	-6.7	-2.3		
		MCWB	-4.2	-6.5	-8.8	-10.2	-10.1	-11.6	-13.3	-13.2	-11.1	-10.0	-7.8	-4.6		
	5%	DB	-4.0	-7.1	-9.3	-11.2	-11.3	-12.9	-14.3	-14.2	-12.0	-11.0	-8.4	-4.6		
		MCWB	-5.9	-7.8	-9.8	-11.7	-11.7	-13.1	-14.7	-14.6	-12.4	-11.5	-9.4	-6.4		
	10%	DB	-5.8	-8.5	-10.5	-12.7	-13.1	-15.1	-15.9	-15.7	-13.6	-12.7	-9.8	-6.4		
		MCWB	-7.3	-9.3	-11.0	-13.1	-13.5	-15.5	-16.3	-16.1	-14.0	-13.2	-10.7	-7.9		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	-5.6	-6.0	-8.4	-7.3	-10.9	-11.5	-11.8	-9.8	-8.5	-5.7	1.7		
		MCDB	1.1	-4.9	-5.6	-8.2	-7.2	-10.7	-11.3	-11.6	-9.5	-8.2	-4.7	3.0		
	2%	WB	-6.4	-7.6	-8.7	-10.6	-10.8	-12.0	-13.3	-12.9	-11.3	-10.1	-8.8	-5.5		
		MCDB	-5.1	-6.9	-8.2	-10.4	-10.5	-11.6	-13.0	-12.5	-11.1	-9.8	-7.9	-4.0		
	5%	WB	-7.8	-9.1	-9.8	-11.9	-12.6	-13.9	-14.7	-14.1	-12.3	-11.7	-10.1	-7.4		
		MCDB	-6.8	-8.5	-9.4	-11.4	-12.2	-13.6	-14.4	-13.8	-12.0	-11.3	-9.3	-6.0		
	10%	WB	-8.8	-10.1	-11.0	-13.5	-14.3	-16.0	-16.2	-15.4	-13.7	-13.5	-11.4	-8.7		
		MCDB	-7.9	-9.6	-10.5	-13.1	-14.0	-15.6	-15.9	-15.0	-13.3	-13.1	-10.7	-7.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	8.6	8.5	8.5	8.4	8.4	9.2	8.2	8.5	8.9	9.3	8.5		
		MCDBR	12.4	9.5	7.2	7.3	7.3	7.4	9.0	7.5	8.7	8.0	10.8	12.2		
		MCWBR	8.0	7.4	5.8	7.0	7.2	7.7	9.5	6.1	7.5	6.9	8.2	9.2		
		MCDBR	8.4	6.8	5.9	7.3	7.2	8.6	9.6	6.4	7.5	6.6	8.4	9.5		
	5% WB	MCWBR	7.5	6.5	5.9	7.4	7.2	8.5	9.6	6.4	7.6	6.7	7.9	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.196	0.187	0.164	0.098	N/A	N/A	N/A	0.100	0.159	0.176	0.186	0.195		
	taud		2.296	2.305	2.250	1.902	N/A	N/A	N/A	1.888	2.181	2.255	2.287	2.296		
	Ebn at Noon		1047	987	870	485	0	0	0	449	856	996	1056	1067		
	Edh at Noon		97	78	52	14	0	0	0	13	54	82	98	103		
(44) All-Sky Solar Radiation	RadAvg		8.48	5.18	2.02	0.28	0.00	0.00	0.00	0.09	1.19	3.90	7.47	9.64		
	RadStd		0.20	0.13	0.09	0.01	0.00	0.00	0.00	0.00	0.04	0.12	0.19	0.21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page