

NOVOLAZAREVSKAJA STATION, Antarctica

WMO: 895120

Lat: 70.777S

Lon: 11.821E

Elev: 390

StdP: 14.49

Time Zone: 0.00 (TRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-19.8	-16.6	-38.4	0.6	-15.6	-35.7	0.7	-14.3	117.2	12.3	94.3	9.9	3.5	80	1.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	38.6	31.3	37.0	30.3	35.8	29.3	32.0	37.6	30.7	36.1	29.7	35.0	14.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	20.2	32.9	24.3	18.7	32.0	22.8	17.4	31.6	11.9	37.8	11.4	36.5	11.0	35.3	39.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
93.6	75.9	62.9		-26.4	42.6	4.6	3.5	-29.7	45.1	-32.3	47.2	-34.9	49.1	-38.2	51.7	
			DB	-26.2	34.2	3.9	2.3	-29.1	35.8	-31.3	37.1	-33.5	38.4	-36.4	40.1	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	30.6	25.7	17.2	10.7	7.1	5.1	1.1	1.1	1.4	9.8	21.6	29.9	
	DBStd	12.85	3.42	4.14	5.58	7.58	7.97	8.66	9.33	9.30	8.26	7.63	5.58	3.66	
	HDD50	13362	600	680	1015	1180	1330	1348	1514	1516	1457	1246	853	623	
	HDD65	18837	1065	1100	1480	1630	1795	1798	1979	1981	1907	1711	1303	1088	
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	26.1	17.7	24.5	26.3	32.5	30.1	30.6	30.2	28.8	23.5	25.7	24.2	19.2	
Precipitation	PrecAvg	9.8	0.7	0.8	0.7	0.6	0.9	0.9	0.9	0.9	0.6	0.9	1.0	0.8	
	PrecMax	12.8	2.2	1.7	1.5	1.5	2.1	2.5	2.4	2.7	1.4	1.8	2.7	1.9	
	PrecMin	7.6	0.2	0.2	0.2	0.0	0.2	0.2	0.2	0.3	0.1	0.2	0.0	0.1	
	PrecStd	1.3	0.4	0.4	0.3	0.3	0.4	0.5	0.5	0.6	0.4	0.4	0.7	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	37.0	31.5	28.5	24.2	23.8	22.8	21.6	21.0	28.1	35.8	40.4	
		MCWB	33.6	30.2	25.8	24.0	19.3	19.9	18.3	17.7	16.6	22.9	28.9	32.4	
	2%	DB	39.1	35.0	29.1	25.0	22.0	20.7	18.5	18.0	18.3	25.1	33.3	38.4	
		MCWB	31.8	28.7	23.9	20.2	17.9	16.7	15.3	14.9	14.2	20.2	26.6	30.9	
	5%	DB	37.4	33.4	27.3	23.2	19.9	18.9	16.3	15.7	15.9	22.4	31.4	37.1	
		MCWB	30.7	27.5	22.5	18.9	16.3	15.4	13.6	13.0	12.2	17.9	25.2	30.1	
	10%	DB	36.1	31.9	25.3	21.1	17.9	16.9	13.8	13.3	13.2	20.3	29.4	35.8	
		MCWB	29.8	26.3	20.7	17.4	14.6	13.8	11.2	10.7	9.9	16.3	23.8	29.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.1	31.3	26.7	24.3	20.0	21.6	18.6	18.6	17.2	23.4	29.8	33.7
			MCDB	40.0	36.0	30.1	28.1	22.6	23.3	21.3	20.9	20.1	27.4	34.9	39.1
2%		WB	32.3	29.6	24.4	20.9	18.5	17.7	15.9	15.6	14.5	20.4	27.0	31.5	
		MCDB	38.1	34.2	28.6	24.2	21.5	20.1	17.8	17.6	18.0	24.3	32.6	37.2	
5%		WB	31.3	27.9	22.7	19.1	16.6	15.6	13.7	13.0	12.3	18.4	25.5	30.5	
		MCDB	36.7	32.7	26.9	22.7	19.6	18.4	16.2	15.3	15.8	22.1	30.8	36.1	
10%		WB	30.2	26.6	20.9	17.5	14.7	13.8	11.3	10.9	9.9	16.4	24.1	29.6	
		MCDB	35.4	31.4	25.2	21.0	17.6	16.9	13.8	13.3	13.2	20.2	28.9	35.1	
Mean Daily Temperature Range		5% DB	MDBR	6.5	6.2	6.5	7.0	7.4	7.6	7.9	8.2	8.5	7.6	6.8	6.7
			MCDBR	7.9	7.6	6.7	7.6	6.7	7.7	8.0	8.2	9.3	8.8	7.9	8.0
	MCWBR		5.7	6.1	5.8	6.2	5.7	6.7	6.7	7.1	7.9	7.4	6.0	5.5	
	5% WB	MCDBR	7.2	7.1	6.4	7.0	6.3	7.3	7.6	7.6	8.9	8.2	7.2	7.4	
		MCWBR	5.6	6.0	5.8	6.1	5.7	6.6	6.7	6.8	7.8	7.0	5.9	5.4	
Clear-Sky Solar Irradiance	taub	0.243	0.229	0.199	0.143	N/A	N/A	N/A	N/A	0.139	0.180	0.202	0.226	0.244	
	taud	2.194	2.220	2.219	2.016	N/A	N/A	N/A	N/A	1.976	2.158	2.171	2.173	2.163	
	Ebn at Noon	316	301	274	197	0	0	0	0	193	278	311	322	321	
	Edh at Noon	37	30	21	10	0	0	0	0	10	22	31	37	40	
All-Sky Solar Radiation	RadAvg	2712	1789	873	217	0	0	0	0	94	596	1457	2469	3064	
	RadStd	58	62	24	8	0	0	0	0	6	25	51	77	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page