

AMERY G3, Antarctica

WMO: 897670

Lat: 70.892S

Lon: 69.873E

Elev: 276

StdP: 14.55

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-44.4	-38.8	N/A	N/A	N/A	N/A	N/A	N/A	50.7	-20.8	48.3	-20.3	8.3	220	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.8	38.3	N/A	34.0	N/A	31.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
45.0	40.6	36.0	-45.7	43.5	6.1	5.7	-50.0	47.7	-53.6	51.0	-57.0	54.2	-61.5	58.4		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.2	21.3	10.8	-1.6	-10.8	-14.7	-15.1	-16.6	-16.7	-15.6	-10.5	2.3	17.4
	DBStd	15.66	7.05	6.70	7.70	7.72	9.41	7.67	9.46	8.23	6.27	8.68	8.01	9.62
	HDD50	19791	890	1098	1600	1824	2007	1953	2064	2069	1967	1876	1432	1011
	HDD65	25266	1355	1518	2065	2274	2472	2403	2529	2534	2417	2341	1882	1476
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.5	7.3	11.8	17.0	20.5	20.0	21.6	21.1	21.7	20.6	17.0	11.7	8.2
Precipitation	PrecAvg	6.9	0.6	0.5	0.5	0.4	0.5	0.6	0.8	0.6	0.6	0.5	0.7	0.5
	PrecMax	10.4	1.7	1.4	1.8	1.0	1.7	1.4	2.6	2.4	1.5	1.3	2.0	1.9
	PrecMin	2.0	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.0	0.4	0.3	0.3	0.2	0.4	0.3	0.6	0.5	0.4	0.4	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.6	29.9	17.4	7.8	13.9	5.7	18.6	13.0	2.9	17.3	29.1	42.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	39.9	26.3	13.6	5.1	4.2	-0.5	3.0	0.5	-0.6	9.1	23.3	37.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	36.3	23.7	10.3	0.8	0.3	-3.9	-4.7	-4.6	-4.9	5.9	19.4	33.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	32.7	20.9	8.0	-1.6	-4.1	-6.8	-8.0	-8.8	-8.6	1.8	15.1	31.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	15.8	12.1	8.1	6.6	6.0	5.1	4.7	4.8	4.7	7.6	9.7	12.3
		MCDBR	21.2	15.5	10.4	8.6	9.1	10.2	8.7	11.9	9.5	13.8	19.0	17.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.249	0.230	0.196	0.138	N/A	N/A	N/A	0.137	0.187	0.203	0.230	0.249
	taud		2.219	2.242	2.228	2.013	N/A	N/A	N/A	1.973	2.162	2.182	2.169	2.162
	Ebn at Noon		314	301	275	200	0	0	0	193	273	310	320	319
	Edh at Noon		36	30	21	10	0	0	0	10	22	31	38	40
All-Sky Solar Radiation	RadAvg		2746	1820	872	215	0	0	0	89	569	1492	2497	3080
	RadStd		51	41	23	8	0	0	0	5	24	32	57	70

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page