

LINDA, Antarctica

WMO: 897690

Lat: 78.394S

Lon: 168.446E

Elev: 41

StdP: 100.83

Time Zone: 12.00 (NZL)

Period: 96-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-51.1	-48.7	N/A	N/A	N/A	N/A	N/A	N/A	26.1	-22.8	23.1	-24.7	2.2	190	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.5	1.4	N/A	-0.4	N/A	-1.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	18.8	16.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-22.9	-6.5	-14.5	-24.5	-28.9	-31.0	-30.4	-32.2	-33.4	-30.8	-24.3	-12.6	-5.5
	DBStd	11.81	3.09	4.67	5.49	7.79	8.27	7.98	8.15	7.72	7.57	5.13	4.70	2.91
	HDD10.0	12018	510	686	1071	1168	1269	1212	1307	1347	1226	1064	679	479
	HDD18.3	15059	768	919	1329	1418	1528	1462	1566	1605	1476	1322	929	738
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.7	4.9	5.3	5.7	7.1	7.1	7.7	7.6	7.3	8.0	7.6	6.8	5.0
Precipitation	PrecAvg	155	16	16	14	12	12	13	11	14	13	11	11	13
	PrecMax	241	40	33	32	36	28	38	35	48	32	25	31	27
	PrecMin	52	3	4	3	5	1	3	1	1	1	1	2	1
	PrecStd	40	9	7	6	7	7	9	7	11	8	7	7	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.8	-2.5	-9.7	-7.4	-11.9	-11.5	-12.9	-12.1	-12.1	-10.7	-2.6	5.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	1.1	-4.5	-12.1	-13.3	-15.2	-13.3	-15.1	-15.2	-14.8	-12.9	-4.0	2.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-0.8	-6.3	-13.9	-15.9	-17.2	-15.6	-17.5	-18.1	-17.2	-15.0	-5.3	0.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-2.1	-7.9	-16.1	-18.3	-19.3	-18.7	-20.4	-21.5	-19.7	-16.9	-6.5	-1.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.6	7.9	8.6	9.0	9.3	8.9	9.8	9.3	9.0	7.2	7.5
		MCDBR	10.4	9.0	7.6	9.2	9.5	9.3	9.2	9.4	9.4	10.5	8.0	10.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.235	0.214	0.169	0.113	N/A	N/A	N/A	N/A	0.161	0.193	0.215	0.234
	taud		2.175	2.189	2.125	1.878	N/A	N/A	N/A	N/A	2.084	2.188	2.200	2.180
	Ebn at Noon		955	890	753	65	0	0	0	0	748	923	984	984
	Edh at Noon		104	79	46	2	0	0	0	0	46	79	101	110
All-Sky Solar Radiation	RadAvg		8.05	4.78	1.53	0.10	0.00	0.00	0.00	0.00	0.81	3.58	7.56	9.47
	RadStd		0.18	0.17	0.07	0.01	0.00	0.00	0.00	0.00	0.04	0.10	0.22	0.24

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	+0.80	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page