

SCHWERTDFEGER, Antarctica

WMO: 898680

Lat: 79.816S

Lon: 170.358E

Elev: 54

StdP: 100.68

Time Zone: 12.00 (NZL)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-56.9	-54.3	N/A	N/A	N/A	N/A	N/A	N/A	17.6	-31.1	15.1	-31.0	2.5	190	1.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.6	-1.0	N/A	-2.4	N/A	-3.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.2	10.6	DB	-59.0	4.0	3.1	1.8	-61.2	5.3	-63.0	6.3	-64.8	7.3	-67.0	8.6	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-26.5	-8.3	-17.9	-28.6	-32.0	-34.2	-34.9	-36.3	-39.1	-35.2	-27.8	-15.4	-7.5	(6)	
(7)		DBStd	12.66	3.16	5.05	5.98	7.07	8.58	8.35	8.87	7.82	7.72	5.84	4.99	3.02	(7)	
(8)		HDD10.0	13310	568	782	1197	1259	1370	1346	1435	1521	1357	1171	761	543	(8)	
(9)		HDD18.3	16352	826	1016	1456	1509	1628	1596	1693	1779	1607	1429	1011	802	(9)	
(10)		CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)	
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	4.6	3.3	3.5	4.3	4.8	5.1	5.1	5.5	5.1	5.7	5.2	4.6	3.2	(14)	
(15)	Precipitation	PrecAvg	171	16	17	18	14	15	15	12	16	14	11	10	13	(15)	
(16)		PrecMax	276	36	36	36	38	40	41	36	43	38	32	29	26	(16)	
(17)		PrecMin	79	4	3	2	3	1	3	2	1	1	2	1	2	(17)	
(18)		PrecStd	47	8	7	9	10	10	9	8	10	10	7	7	6	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.8	-3.9	-12.1	-8.3	-12.4	-12.4	-13.2	-15.9	-12.3	-13.1	-3.0	2.5	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	-1.4	-7.1	-15.2	-14.8	-16.6	-16.1	-17.0	-19.9	-15.9	-15.0	-4.9	-0.2	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	-2.6	-8.8	-17.4	-18.9	-19.7	-20.3	-21.0	-23.9	-20.2	-17.0	-6.6	-1.8	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	-3.5	-10.3	-19.6	-21.5	-22.4	-23.1	-24.0	-27.6	-24.4	-19.0	-8.3	-3.0	(25)	
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range			MDBR	6.9	9.1	8.9	9.3	9.5	9.7	9.4	10.1	9.9	9.6	8.2	7.6	(35)
(36)		5% DB	MCDBR	8.4	9.6	9.4	12.2	12.0	11.5	10.6	12.8	12.0	11.1	8.9	9.7	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
(38)			MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)		5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.233	0.211	0.163	N/A	N/A	N/A	N/A	N/A	0.155	0.192	0.212	0.231	(40)	
(41)		taud		2.182	2.191	2.100	N/A	N/A	N/A	N/A	N/A	2.056	2.182	2.204	2.187	(41)	
(42)		Ebn at Noon		948	877	717	0	0	0	0	0	712	907	976	977	(42)	
(43)		Edh at Noon		100	75	41	0	0	0	0	0	41	76	97	106	(43)	
(44)	All-Sky Solar Radiation	RadAvg		8.05	4.75	1.39	0.00	0.00	0.00	0.00	0.66	3.48	7.63	9.47	(44)		
(45)		RadStd		0.23	0.20	0.07	0.00	0.00	0.00	0.00	0.00	0.04	0.10	0.25	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page