

POSSESSION ISLAND, Antarctica

WMO: 898790

Lat: 71.891S

Lon: 171.210E

Elev: 98

StdP: 14.64

Time Zone: 12.00 (NZL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-23.1	-19.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	44.5	N/A	42.5	N/A	40.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-25.2	49.0	4.5	2.2	-28.4	50.6	-31.0	51.9	-33.5	53.1	-36.8	54.7
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	34.7	29.2	16.5	2.5	-0.2	-1.5	-4.5	-7.0	-1.7	8.5	23.3	33.8		
	DBStd	16.38	2.89	3.51	6.99	7.08	7.96	7.52	8.86	8.72	7.55	6.25	6.15	3.67		
	HDD50	14213	475	582	1038	1424	1556	1544	1688	1766	1551	1286	801	502		
	HDD65	19688	940	1002	1503	1874	2021	1994	2153	2231	2001	1751	1251	967		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	17.0	2.2	2.6	2.2	1.1	1.1	1.0	1.0	1.1	1.0	1.1	1.1	1.5		
Precipitation	PrecMax	23.8	3.3	5.4	3.7	2.1	3.0	2.1	2.0	2.0	2.0	2.9	2.4	3.0		
	PrecMin	11.1	0.4	0.9	1.0	0.3	0.3	0.2	0.3	0.4	0.2	0.4	0.4	0.6		
	PrecStd	2.7	0.6	0.9	0.7	0.5	0.7	0.4	0.4	0.5	0.5	0.6	0.5	0.6		
	PrecStd	2.7	0.6	0.9	0.7	0.5	0.7	0.4	0.4	0.5	0.5	0.6	0.5	0.6		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	43.3	31.1	26.3	23.1	21.0	22.7	21.7	20.7	28.8	42.1	48.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	44.7	39.5	28.3	18.5	18.7	17.1	15.1	13.8	16.5	23.6	38.0	44.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	42.7	36.5	26.7	15.1	14.2	13.4	11.3	8.9	12.4	20.1	34.9	42.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	40.5	33.9	25.0	12.0	10.0	9.2	7.9	4.9	8.8	17.2	32.2	40.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	8.8	7.1	6.0	6.7	7.1	7.3	7.6	7.7	9.3	10.7	11.1	10.5		
		MCDBR	14.5	13.2	8.0	9.5	10.5	10.7	10.0	11.5	13.2	16.1	15.5	15.2		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.265	0.260	0.225	0.137	N/A	N/A	N/A	0.132	0.191	0.215	0.234	0.255		
	taud		2.436	2.432	2.364	2.018	N/A	N/A	N/A	1.978	2.251	2.309	2.316	2.351		
	Ebn at Noon		309	288	259	185	0	0	0	180	269	304	318	317		
	Edh at Noon		29	24	18	8	0	0	0	8	19	27	32	33		
All-Sky Solar Radiation	RadAvg		2326	1433	671	165	0	0	0	67	524	1376	2372	2873		
	RadStd		76	64	40	11	0	0	0	4	22	37	75	84		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page