

GUAM INTL, Guam

WMO: 912120

Lat: 13.483N

Lon: 144.800E

Elev: 254

StdP: 14.56

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 41415

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	74.0	74.8	65.4	94.8	79.8	66.8	99.5	79.9	25.5	82.7	23.7	82.8	7.5	50	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	9.0	89.4	78.6	88.7	78.4	88.1	78.2	81.8	85.4	81.0	85.0	80.6	84.8	13.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.6	160.2	83.3	79.9	156.5	83.1	79.2	152.9	82.9	45.8	85.9	45.1	85.0	44.5	84.7	90.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.5	20.4	18.6	70.9	91.6	1.4	1.5	69.9	92.7	69.1	93.6	68.2	94.4	67.2	95.5		
			67.0	82.4	1.7	1.9	65.8	83.8	64.8	84.9	63.8	85.9	62.6	87.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	80.6	80.5	81.2	82.5	83.2	83.3	82.4	81.7	81.6	82.0	82.6	81.9
	DBStd	1.79	1.42	1.38	1.43	1.32	1.43	1.69	1.81	1.75	1.75	1.74	1.54	1.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11664	948	853	968	974	1029	999	1003	983	948	993	977	989
	CDD65	6189	483	433	503	524	564	549	538	518	498	528	527	524
	CDH74	65516	4466	3929	4939	5702	6483	6482	5976	5456	5168	5652	5796	5467
CDH80	19073	972	859	1268	1749	2215	2342	1889	1528	1420	1644	1760	1427	
Wind	WSAvg	9.7	11.6	12.1	11.8	11.4	9.7	9.0	7.4	6.8	6.5	7.7	10.6	12.0
Precipitation	PrecAvg	90.1	4.3	3.6	2.8	3.5	5.7	6.3	10.9	14.2	13.4	11.9	8.3	5.4
	PrecMax	131.7	18.1	13.9	9.3	15.3	24.1	13.3	29.8	37.3	24.3	25.2	20.3	15.9
	PrecMin	57.9	0.9	0.3	0.4	0.5	0.4	0.8	5.2	3.9	7.4	4.3	2.8	1.6
	PrecStd	18.9	3.6	3.0	2.0	3.2	5.1	3.1	4.7	6.6	4.6	4.3	3.6	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.3	87.3	88.2	89.1	89.8	90.0	89.9	89.4	89.4	89.4	89.1	88.2
		MCWB	76.2	75.8	75.6	77.0	77.9	78.4	79.1	79.9	79.8	79.5	78.9	78.2
	2%	DB	86.4	86.3	87.2	88.1	88.8	89.0	88.5	88.0	88.0	88.2	88.2	87.3
		MCWB	76.0	75.7	75.7	76.9	77.9	78.5	79.0	79.3	79.3	79.2	78.5	77.7
	5%	DB	85.6	85.6	86.4	87.4	88.0	88.2	87.6	87.1	87.0	87.3	87.5	86.5
		MCWB	75.9	75.6	75.6	76.8	77.9	78.4	78.9	79.2	79.2	79.1	78.4	77.5
	10%	DB	84.8	84.8	85.6	86.6	87.2	87.5	86.7	86.1	86.0	86.4	86.6	85.7
		MCWB	75.7	75.4	75.5	76.7	77.8	78.4	78.8	79.1	79.1	79.0	78.4	77.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	79.9	79.8	80.8	81.4	81.4	82.0	82.1	81.9	82.5	82.1	81.8
		MCDB	83.0	82.7	83.3	84.7	85.6	85.6	85.8	86.2	85.7	85.8	84.9	84.9
	2%	WB	78.8	78.6	78.5	79.6	80.4	80.6	81.0	80.9	81.0	81.4	81.0	80.6
		MCDB	82.7	82.2	82.8	84.4	85.0	85.4	84.9	85.2	85.1	85.2	84.7	83.8
	5%	WB	78.0	77.8	77.8	78.8	79.6	79.9	80.2	80.2	80.3	80.5	80.2	79.5
		MCDB	82.2	81.9	82.5	84.2	84.8	85.2	84.5	84.6	84.6	84.7	84.4	83.5
	10%	WB	77.3	77.1	77.1	78.2	78.9	79.2	79.6	79.5	79.6	79.7	79.4	78.6
		MCDB	81.7	81.7	82.2	83.6	84.5	85.0	84.4	84.1	84.1	84.2	84.0	83.2
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.4	9.7	9.6	9.2	9.0	9.1	9.3	9.4	9.2	8.9	8.7
		MCDBR	10.1	10.4	10.5	10.2	9.7	9.7	10.0	10.5	10.5	10.3	9.6	9.4
		MCWBR	4.2	4.2	3.9	3.6	3.5	3.6	4.2	4.6	4.6	4.5	4.1	4.0
	5% WB	MCDBR	8.7	9.1	9.2	9.2	9.1	9.0	9.3	9.7	9.7	9.4	8.8	8.5
		MCWBR	4.6	4.6	4.3	3.9	3.9	4.0	4.5	4.9	4.8	4.8	4.4	4.5
Clear-Sky Solar Irradiance	taub	0.412	0.413	0.412	0.412	0.412	0.409	0.404	0.408	0.395	0.421	0.437	0.427	
	taud	2.471	2.469	2.485	2.512	2.536	2.547	2.576	2.555	2.603	2.511	2.416	2.422	
	Ebn at Noon	281	286	287	285	280	278	280	282	288	280	272	273	
	Edh at Noon	35	36	36	35	33	33	32	33	31	34	36	36	
All-Sky Solar Radiation	RadAvg	1572	1789	2018	2164	2115	2025	1783	1638	1625	1601	1620	1553	
	RadStd	84	71	84	82	86	158	172	147	122	149	85	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.47	+0.38	N/A	+0.34	N/A	N/A	N/A	+149	+148
(47) Regional (1 neighbor)		+0.29	+0.25	N/A	+0.27	N/A	N/A	N/A	+110	+112

Nomenclature: See separate page