

ANDERSEN AFB, Guam

WMO: 912180

Lat: 13.583N

Lon: 144.917E

Elev: 612

StdP: 14.37

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 41414

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	73.1	73.9	62.9	87.7	77.9	65.5	96.4	77.6	29.1	78.5	26.9	78.4	11.8	60	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.3	87.9	78.9	87.2	78.7	86.3	78.4	81.1	84.4	80.5	84.2	79.9	83.8	12.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	163.0	82.9	79.2	155.2	82.3	78.9	153.7	82.1	45.7	83.7	44.7	84.8	44.0	84.3	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	22.1	20.3	69.9	90.4	2.8	2.7	67.9	92.3	66.2	93.9	64.6	95.4	62.6	97.3		
(5)			65.3	83.3	4.1	1.7	62.3	84.6	59.9	85.6	57.6	86.5	54.6	87.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	79.1	79.0	79.6	80.8	81.7	82.0	81.3	80.9	80.8	80.9	81.0	80.3	(6)
(7)		DBStd	1.72	1.41	1.50	1.54	1.28	1.19	1.44	1.61	1.69	1.67	1.69	1.22	1.26	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11184	903	813	918	925	984	960	971	959	923	957	930	941	(10)
(11)		CDD65	5709	438	393	453	475	519	510	506	494	473	492	480	476	(11)
(12)		CDH74	54526	3462	3038	3819	4528	5421	5523	5225	4861	4579	4871	4792	4407	(12)
(13)		CDH80	11552	415	393	609	943	1377	1533	1315	1178	1057	1083	947	702	(13)
(14)	Wind	WSAvg	11.7	14.1	14.7	14.2	13.0	11.4	10.6	9.0	8.8	8.5	9.6	12.7	14.3	(14)
(15)	Precipitation	PrecAvg	92.7	5.3	4.4	3.8	4.3	4.9	6.1	10.7	15.2	12.4	11.6	9.8	6.2	(15)
(16)		PrecMax	122.8	16.2	12.4	14.6	14.5	17.5	17.8	19.1	32.9	26.0	28.9	19.1	17.0	(16)
(17)		PrecMin	56.5	1.1	0.7	0.9	0.6	0.7	0.5	5.5	5.0	3.3	4.0	2.4	1.1	(17)
(18)		PrecStd	16.6	3.9	3.4	3.5	3.5	4.3	3.7	3.2	6.7	5.7	5.2	4.6	3.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.5	85.9	86.3	87.7	88.2	88.2	88.2	88.1	87.7	86.4	86.1	(19)	
(20)			MCWB	77.2	76.1	75.9	77.6	78.9	78.8	79.1	79.7	79.5	79.8	78.6	77.9	(20)
(21)		2%	DB	84.3	84.4	84.6	86.2	87.1	87.6	87.2	86.9	86.6	86.3	85.8	84.6	(21)
(22)			MCWB	76.3	75.8	75.6	77.0	78.2	78.8	78.9	79.2	79.0	79.1	78.5	77.1	(22)
(23)		5%	DB	83.3	83.5	84.2	85.4	86.2	86.4	86.2	86.1	86.0	85.8	84.7	84.3	(23)
(24)			MCWB	75.8	75.5	75.5	76.9	77.9	78.4	78.8	78.9	78.8	78.8	78.0	76.9	(24)
(25)		10%	DB	82.4	82.5	83.3	84.4	85.5	86.0	85.5	85.2	84.8	84.5	84.2	83.7	(25)
(26)			MCWB	75.3	75.1	75.2	76.7	77.8	78.3	78.6	78.6	78.6	78.4	77.9	76.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	79.2	79.1	80.8	81.0	80.9	81.7	81.9	82.5	81.6	80.9	80.0	(27)
(28)			MADB	82.2	81.3	81.6	83.1	84.7	85.5	85.0	85.4	84.6	84.4	83.7	83.0	(28)
(29)		2%	WB	78.2	78.1	78.0	79.1	79.7	79.9	80.3	80.5	80.8	80.5	79.9	79.0	(29)
(30)			MADB	81.4	80.9	81.4	82.8	84.1	84.9	84.6	84.5	83.9	83.9	83.1	82.3	(30)
(31)		5%	WB	77.4	77.2	77.1	78.3	79.0	79.2	79.6	79.7	79.8	79.7	79.2	78.3	(31)
(32)			MADB	80.9	80.7	81.3	82.5	83.8	84.2	84.0	83.8	83.4	83.3	82.6	81.8	(32)
(33)		10%	WB	76.6	76.5	76.4	77.8	78.3	78.8	79.0	79.0	79.1	79.0	78.7	77.9	(33)
(34)			MADB	80.3	80.3	80.9	82.1	83.2	83.8	83.4	83.2	83.0	82.8	82.2	81.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.2	7.6	7.9	8.0	8.0	8.3	8.5	8.8	8.8	8.1	7.1	7.0	(35)
(36)			MCDBR	8.1	8.5	8.4	8.8	8.7	8.9	9.2	9.8	9.6	8.7	7.5	7.5	(36)
(37)			MCWBR	4.7	4.7	4.8	4.5	4.1	4.3	4.9	5.3	5.1	4.7	4.4	4.3	(37)
(38)		5% WB	MCDBR	7.4	7.7	7.7	8.1	8.2	8.6	8.7	9.2	9.0	8.2	7.1	7.1	(38)
(39)			MCWBR	4.9	4.9	4.8	4.8	4.3	4.5	5.3	5.5	5.5	5.1	4.6	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.404	0.405	0.404	0.405	0.405	0.403	0.398	0.403	0.390	0.415	0.429	0.419	(40)	
(41)		taud	2.490	2.486	2.502	2.528	2.550	2.560	2.587	2.567	2.614	2.524	2.436	2.442	(41)	
(42)		Ebn at Noon	284	288	290	287	282	279	281	283	289	281	274	276	(42)	
(43)		Edh at Noon	34	35	35	34	33	32	31	33	31	33	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1571	1791	2019	2162	2121	2030	1791	1640	1628	1601	1621	1554	(44)	
(45)		RadStd	84	71	84	83	85	156	172	147	120	149	86	60	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.22	N/A	N/A	+0.25	N/A	N/A	N/A	N/A	+124	+124

Nomenclature: See separate page