

WENO CHUUK, Micronesia, Federated States ofWMO: **913340**Lat: **7.454N**Lon: **151.843E**Elev: **3**StdP: **101.28**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **40505****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.1	24.5	20.9	15.5	27.7	21.5	16.1	27.7	10.3	27.0	9.3	27.3	3.1	60	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	4.2	32.1	27.4	31.6	27.2	31.2	27.0	29.0	31.1	28.3	30.6	27.8	30.3	4.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.5	24.8	30.7	27.7	23.7	30.2	27.1	22.8	29.8	94.5	31.1	91.3	30.7	89.1	30.4	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.8	7.1	DB	23.0	34.4	0.4	2.4	22.7	36.1	22.5	37.5	22.3	38.9	22.0	40.6	(4)
(5)			WB	21.0	29.2	0.9	1.1	20.3	30.0	19.8	30.6	19.3	31.2	18.7	32.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	28.1	28.0	28.2	28.4	28.3	28.2	28.0	28.0	28.1	28.2	28.2	(6)	
(7)		DBStd	0.89	0.85	0.86	0.89	0.92	0.91	0.91	0.90	0.93	0.93	0.84	0.84	0.80	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6626	561	504	564	551	568	545	559	557	541	563	547	564	(10)
(11)		CDD18.3	3584	303	271	306	301	310	295	301	299	291	304	297	306	(11)
(12)		CDH23.3	40902	3438	3033	3473	3501	3602	3381	3401	3331	3271	3464	3446	3563	(12)
(13)		CDH26.7	13204	1039	892	1088	1178	1226	1111	1090	1051	1054	1157	1154	1164	(13)
(14)	Wind	WSAvg	3.9	4.8	5.0	4.7	4.2	3.7	3.4	3.2	3.3	3.4	3.2	3.5	4.3	(14)
(15)	Precipitation	PrecAvg	3557	232	192	245	293	328	318	348	345	337	325	285	289	(15)
(16)		PrecMax	4550	487	907	610	778	721	646	872	659	603	628	663	623	(16)
(17)		PrecMin	2203	31	14	20	43	97	145	67	81	133	106	48	73	(17)
(18)		PrecStd	494	107	139	132	141	112	98	147	118	110	119	126	123	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	31.8	32.4	32.2	32.0	31.9	32.1	32.2	32.2	32.1	32.0	31.8	(19)
(20)			MCWB	26.4	26.2	26.2	26.9	27.5	27.6	27.7	27.8	27.8	28.0	27.7	27.3	(20)
(21)		2%	DB	30.8	30.8	31.2	31.2	31.3	31.2	31.4	31.5	31.5	31.5	31.2	30.9	(21)
(22)			MCWB	26.3	26.2	26.4	26.8	27.2	27.1	27.1	27.3	27.3	27.4	27.0	26.7	(22)
(23)		5%	DB	30.2	30.2	30.6	30.8	30.9	30.9	30.9	30.9	31.0	31.0	30.8	30.5	(23)
(24)			MCWB	26.0	25.9	26.2	26.6	27.0	26.9	26.9	26.9	27.0	27.0	26.8	26.5	(24)
(25)		10%	DB	29.8	29.8	30.1	30.3	30.4	30.4	30.4	30.4	30.4	30.5	30.3	30.0	(25)
(26)			MCWB	25.8	25.7	26.0	26.5	26.8	26.7	26.7	26.6	26.7	26.7	26.6	26.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.5	28.4	28.5	28.8	29.4	29.2	29.1	29.1	29.3	29.4	29.0	28.5	(27)
(28)			MCD B	30.3	30.1	30.3	30.9	31.2	31.1	31.2	31.5	31.4	31.5	31.1	30.6	(28)
(29)		2%	WB	27.2	27.2	27.4	27.7	28.0	27.9	27.7	27.9	28.2	28.1	27.8	27.5	(29)
(30)			MCD B	29.6	29.5	29.8	30.1	30.5	30.4	30.4	30.7	30.7	30.8	30.4	29.9	(30)
(31)		5%	WB	26.6	26.6	26.8	27.2	27.4	27.3	27.2	27.3	27.5	27.5	27.2	27.0	(31)
(32)			MCD B	29.1	29.1	29.5	29.8	30.0	29.9	30.1	30.1	30.1	30.2	29.9	29.5	(32)
(33)		10%	WB	26.2	26.1	26.4	26.7	27.0	26.9	26.8	26.8	26.9	27.0	26.8	26.6	(33)
(34)			MCD B	28.8	28.8	29.1	29.4	29.7	29.6	29.6	29.6	29.7	29.7	29.5	29.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.8	3.9	4.1	4.2	4.5	4.6	4.9	5.0	5.0	5.1	4.6	4.0	(35)
(36)			MCDBR	4.2	4.3	4.6	4.5	4.8	5.0	5.5	5.6	5.6	5.5	5.0	4.5	(36)
(37)			MCWBR	2.7	2.7	2.8	2.8	2.9	3.0	3.1	3.1	3.2	3.1	2.9	2.7	(37)
(38)		5% WB	MCDBR	4.0	4.2	4.4	4.4	4.7	4.9	5.2	5.4	5.4	5.3	4.9	4.4	(38)
(39)			MCWBR	2.9	3.0	3.1	3.0	3.2	3.2	3.2	3.3	3.5	3.4	3.0	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.452	0.454	0.452	0.441	0.419	0.401	0.387	0.381	0.379	0.392	0.423	0.465	(40)	
(41)		taud	2.370	2.358	2.393	2.456	2.543	2.602	2.651	2.667	2.680	2.608	2.511	2.327	(41)	
(42)		Ebn at Noon	865	873	875	870	872	878	893	912	928	919	887	844	(42)	
(43)		Edh at Noon	124	129	125	116	104	96	92	93	93	99	107	128	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.95	5.38	5.70	5.61	5.37	5.17	5.29	5.28	5.31	5.28	4.94	4.79	(44)	
(45)		RadStd	0.31	0.52	0.30	0.40	0.33	0.39	0.43	0.49	0.35	0.29	0.36	0.32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	+0.41	+0.38	+0.51	+0.70	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page