

POHNPEI, Micronesia, Federated States of

WMO: 913481

Lat: 6.960N

Lon: 158.210E

Elev: 128

StdP: 14.63

Time Zone: 11.00 (E11)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 10	(b) 73.2	(c) 73.6	(d) 69.6	(e) 109.3	(f) 80.9	(g) 70.6	(h) 113.3	(i) 80.5	(j) 12.9	(k) 82.8	(l) 11.8	(m) 83.2	(n) 4.7	(o) 130	(p) 0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.9	90.4	80.7	89.6	80.5	88.8	80.2	82.1	87.9	81.4	87.3	80.9	86.7	6.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	159.9	86.5	79.8	155.4	85.6	79.2	152.0	85.0	46.2	88.0	45.3	88.2	44.7	87.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.0	(b) 12.3	(c) 11.6	(e) 71.6	(f) 93.2	(g) 0.9	(h) 2.1	(i) 70.9	(j) 94.7	(k) 70.3	(l) 95.9	(m) 69.8	(n) 97.0	(o) 69.1	(p) 98.5		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			71.6	93.2	0.9	2.1	70.9	94.7	70.3	95.9	69.8	97.0	69.1	98.5		
			69.6	85.4	0.7	1.2	69.1	86.3	68.7	87.0	68.3	87.6	67.8	88.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	82.0	82.0	81.9	82.2	82.0	82.0	81.6	81.7	81.7	81.7	81.8	81.9
	DBStd	1.63	1.53	1.65	1.77	1.67	1.87	1.61	1.43	1.42	1.53	1.59	1.65	1.69
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11635	993	896	989	967	992	959	979	982	951	982	955	990
	CDD65	6160	528	476	524	517	527	509	514	517	501	517	505	525
	CDH74	63050	5747	5086	5528	5585	5523	5326	5035	4887	4780	4855	5088	5610
(13)	CDH80	19651	1604	1423	1609	1728	1724	1707	1608	1670	1632	1659	1628	1659
(14)	Wind	WSAvg	5.9	7.7	7.5	6.8	6.5	5.8	5.5	4.8	4.7	4.8	5.3	6.7
(15) Precipitation	PrecAvg	183.3	12.5	10.6	13.7	16.5	18.1	16.1	16.5	15.3	15.1	15.1	15.1	15.2
	PrecMax	236.3	26.7	20.9	35.7	31.9	38.4	28.0	37.2	32.8	38.8	28.3	28.4	33.3
	PrecMin	124.0	0.7	1.1	1.5	2.0	2.2	2.2	7.8	1.0	4.9	7.6	4.6	3.4
	PrecStd	24.7	5.9	5.5	6.9	6.5	6.9	4.7	6.1	5.5	6.2	4.3	5.0	5.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	88.2	89.3	89.6	89.7	89.8	90.0	91.4	91.5	91.8	90.8	89.1
		MCWB	79.4	79.3	79.8	80.3	80.5	80.6	80.6	81.1	80.9	81.2	80.9	80.3
	2%	DB	87.4	87.6	87.9	88.0	88.2	88.2	88.9	89.7	89.8	89.9	89.2	87.8
		MCWB	79.0	79.1	79.5	79.7	80.1	80.3	80.3	80.5	80.5	80.5	80.6	79.8
	5%	DB	86.2	86.3	86.9	87.4	87.6	87.7	87.9	88.4	88.6	89.0	87.9	86.7
		MCWB	78.4	78.3	79.0	79.5	80.0	80.1	80.0	80.1	80.2	80.3	80.2	79.3
	10%	DB	85.4	85.7	85.9	86.1	86.3	86.6	86.8	87.5	87.6	87.6	86.8	85.8
		MCWB	78.1	78.0	78.5	79.0	79.5	79.7	79.6	79.8	79.9	79.9	79.7	78.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.9	81.5	81.6	82.0	81.9	82.2	82.5	82.4	82.6	82.6	81.7
		MCDB	85.6	86.3	86.5	86.9	87.3	87.3	87.7	88.8	88.8	89.3	87.9	86.8
	2%	WB	80.0	79.9	80.3	80.6	80.9	80.9	81.0	81.3	81.2	81.4	81.3	80.5
		MCDB	84.7	85.1	85.5	86.1	86.5	86.5	86.8	87.8	87.7	88.1	86.9	85.4
	5%	WB	79.2	79.1	79.6	79.9	80.1	80.4	80.2	80.5	80.5	80.6	80.5	79.9
		MCDB	83.7	84.2	84.7	85.1	85.5	85.8	86.0	86.9	87.0	87.2	86.2	84.5
	10%	WB	78.9	78.5	79.0	79.2	79.6	79.8	79.7	79.8	79.9	79.9	79.9	79.2
		MCDB	83.3	83.5	83.9	84.1	84.6	84.9	85.0	85.7	85.8	85.8	85.0	83.7
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.3	8.8	8.9	9.6	10.3	11.7	12.9	12.7	12.8	10.9	8.7
		MCDBR	8.4	9.1	10.1	10.0	10.6	11.3	13.1	14.1	14.2	14.8	12.4	9.8
		MCWBR	5.2	5.4	5.5	5.4	5.6	5.7	6.5	7.0	7.0	7.3	6.4	5.5
	5% WB	MCDBR	7.9	8.7	9.4	9.5	10.1	10.7	12.2	13.4	13.2	13.6	11.6	9.1
		MCWBR	5.1	5.4	5.5	5.4	5.5	5.8	6.4	6.9	6.8	7.1	6.3	5.4
(40) Clear-Sky Solar Irradiance	taub		0.454	0.454	0.452	0.445	0.418	0.406	0.388	0.376	0.376	0.385	0.418	0.462
	taud		2.356	2.354	2.386	2.443	2.544	2.578	2.639	2.685	2.686	2.635	2.524	2.333
	Ebn at Noon		274	277	277	275	277	277	283	291	295	294	283	269
	Edh at Noon		40	41	40	37	33	31	30	29	29	30	34	40
(44) All-Sky Solar Radiation	RadAvg		1566	1719	1762	1729	1651	1650	1671	1774	1734	1645	1533	1479
	RadStd		99	140	144	127	146	122	103	138	117	117	120	97

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+0.99	+0.70	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page