

POHNPEI, Micronesia, Federated States of

WMO: 913481

Lat: 6.960N

Lon: 158.210E

Elev: 39

StdP: 100.86

Time Zone: 11.00 (E11)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 10	(b) 22.9	(c) 23.1	(d) 20.9	(e) 15.6	(f) 27.2	(g) 21.5	(h) 16.2	(i) 26.9	(j) 5.8	(k) 28.2	(l) 5.3	(m) 28.5	(n) 2.1	(o) 130	(p) 0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.0	32.4	27.0	32.0	26.9	31.6	26.8	27.8	31.1	27.5	30.7	27.2	30.4	2.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	30.3	26.6	22.2	29.8	26.2	21.7	29.4	89.6	31.1	87.5	31.2	86.2	30.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 6.3	(b) 5.5	(c) 5.2	(e) 22.0	(f) 34.0	(g) 0.5	(h) 1.1	(i) 21.6	(j) 34.8	(k) 21.3	(l) 35.5	(m) 21.0	(n) 36.1	(o) 20.6	(p) 37.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			20.9	29.7	0.4	0.7	20.6	30.1	20.4	30.5	20.1	30.9	19.9	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	27.8	27.8	27.7	27.9	27.8	27.8	27.5	27.6	27.6	27.6	27.7	27.7
	DBStd	0.91	0.85	0.92	0.99	0.93	1.04	0.90	0.79	0.79	0.85	0.88	0.92	0.94
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6464	552	498	549	537	551	533	544	546	528	546	531	550
	CDD18.3	3422	293	264	291	287	293	283	286	287	278	287	281	292
	CDH23.3	35028	3193	2826	3071	3103	3068	2959	2797	2715	2656	2697	2827	3117
	CDH26.7	10917	891	791	894	960	958	948	893	928	907	922	904	922
(14) Wind	WSAvg	2.6	3.4	3.4	3.0	2.9	2.6	2.5	2.2	2.1	2.1	2.1	2.4	3.0
(15) Precipitation	PrecAvg	4657	317	269	349	418	461	409	420	389	384	383	383	385
	PrecMax	6002	677	532	906	809	976	710	945	832	986	718	721	847
	PrecMin	3150	17	27	39	52	56	55	199	25	124	194	116	86
	PrecStd	628	149	140	176	164	175	119	156	139	157	109	128	148
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.2	31.9	32.0	32.1	32.1	32.2	33.0	33.1	33.2	32.6	31.7
		MCWB	26.3	26.3	26.6	26.8	26.9	27.0	27.0	27.3	27.2	27.3	27.2	26.8
	2%	DB	30.8	30.9	31.1	31.1	31.2	31.2	31.6	32.1	32.1	32.2	31.8	31.0
		MCWB	26.1	26.1	26.4	26.5	26.7	26.8	26.8	26.9	26.9	27.0	27.0	26.6
	5%	DB	30.1	30.2	30.5	30.8	30.9	31.0	31.1	31.3	31.5	31.7	31.1	30.4
		MCWB	25.8	25.7	26.1	26.4	26.7	26.7	26.6	26.7	26.8	26.8	26.8	26.3
	10%	DB	29.7	29.8	30.0	30.1	30.2	30.3	30.5	30.9	30.9	30.9	30.4	29.9
		MCWB	25.6	25.6	25.8	26.1	26.4	26.5	26.4	26.5	26.6	26.6	26.5	26.0
	0.4%	WB	27.2	27.2	27.5	27.5	27.8	27.7	27.9	28.0	28.0	28.1	28.1	27.6
		MCDB	29.8	30.2	30.3	30.5	30.7	30.7	30.9	31.5	31.6	31.8	31.1	30.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.7	26.6	26.8	27.0	27.1	27.2	27.2	27.4	27.3	27.5	27.4	27.0
		MCDB	29.3	29.5	29.7	30.0	30.3	30.3	30.4	31.0	30.9	31.2	30.5	29.6
	5%	WB	26.2	26.2	26.5	26.6	26.7	26.9	26.8	26.9	27.0	27.0	27.0	26.6
		MCDB	28.7	29.0	29.3	29.5	29.7	29.9	30.0	30.5	30.6	30.7	30.1	29.2
	10%	WB	26.0	25.9	26.1	26.2	26.4	26.5	26.5	26.5	26.6	26.6	26.6	26.2
		MCDB	28.5	28.6	28.8	29.0	29.2	29.4	29.5	29.8	29.9	29.9	29.5	28.7
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.6	4.9	5.0	5.4	5.7	6.5	7.1	7.0	7.1	6.1	4.8
		MCDBR	4.7	5.0	5.6	5.6	5.9	6.3	7.3	7.9	7.9	8.2	6.9	5.4
		MCWBR	2.9	3.0	3.1	3.0	3.1	3.2	3.6	3.9	3.9	4.1	3.6	3.0
	5% WB	MCDBR	4.4	4.8	5.2	5.3	5.6	5.9	6.8	7.4	7.3	7.6	6.4	5.1
		MCWBR	2.8	3.0	3.1	3.0	3.1	3.2	3.5	3.8	3.8	3.9	3.5	3.0
(40) Clear-Sky Solar Irradiance	taub		0.454	0.454	0.452	0.445	0.418	0.406	0.388	0.376	0.376	0.385	0.418	0.462
	taud		2.356	2.354	2.386	2.443	2.544	2.578	2.639	2.685	2.686	2.635	2.524	2.333
	Ebn at Noon		864	874	874	867	873	872	892	917	930	927	893	848
	Edh at Noon		126	129	126	118	103	99	93	91	92	96	106	127
(44) All-Sky Solar Radiation	RadAvg		4.94	5.42	5.55	5.45	5.21	5.20	5.27	5.59	5.46	5.18	4.83	4.66
	RadStd		0.31	0.44	0.45	0.40	0.46	0.38	0.32	0.44	0.37	0.37	0.38	0.31

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+0.55	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page