

MAJURO ATOLL, Marshall Islands

WMO: 913760

Lat: 7.068N

Lon: 171.294E

Elev: 15

StdP: 14.69

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 00492

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	76.7	77.6	70.8	113.6	81.5	71.7	117.0	81.7	25.5	83.0	23.9	83.3	9.9	70	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	88.2	79.8	87.9	79.7	87.5	79.6	80.9	86.4	80.5	85.9	80.1	85.4	11.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	151.4	85.0	78.9	150.2	84.7	78.5	148.2	84.4	44.6	87.4	44.2	86.5	43.8	85.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	21.9	20.4	74.3	91.2	1.8	3.7	73.1	93.9	72.0	96.0	71.0	98.1	69.7	100.9		
(5)			71.1	82.2	2.1	1.2	69.6	83.1	68.4	83.8	67.2	84.4	65.6	85.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	82.8	82.8	82.8	82.8	83.1	83.0	83.0	83.2	83.1	83.1	82.9	83.1	(6)
(7)		DBStd	1.48	1.33	1.23	1.48	1.48	1.28	1.49	1.40	1.53	1.53	1.65	1.81	1.40	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12035	1018	917	1016	983	1026	990	1022	1031	994	1026	987	1025	(10)
(11)		CDD65	6560	553	497	551	533	561	540	557	566	544	561	537	560	(11)
(12)		CDH74	75552	6275	5633	6214	6069	6472	6245	6418	6635	6402	6571	6150	6468	(12)
(13)		CDH80	23914	1888	1677	1846	1829	2056	2003	2032	2234	2134	2174	1961	2080	(13)
(14)	Wind	WSAvg	11.5	13.7	14.3	13.4	13.4	12.3	11.7	10.1	8.4	9.0	8.6	10.6	13.2	(14)
(15)	Precipitation	PrecAvg	126.1	7.5	7.4	7.6	10.6	10.7	10.4	11.6	11.5	12.4	12.9	13.1	10.6	(15)
(16)		PrecMax	175.6	23.5	20.7	22.2	23.2	21.3	21.1	22.9	24.2	20.9	20.8	20.6	19.1	(16)
(17)		PrecMin	87.8	0.9	0.2	0.1	0.4	2.4	3.8	5.9	6.4	4.4	5.8	5.2	3.5	(17)
(18)		PrecStd	19.3	4.3	5.0	5.6	6.1	4.5	3.8	3.4	3.5	4.4	4.2	4.0	3.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.0	87.9	88.0	88.1	88.1	88.2	88.1	88.5	88.8	88.6	89.3	88.1	(19)
MCWB			79.2	79.4	79.4	79.4	79.4	79.5	79.7	79.5	80.0	80.2	80.2	79.6	79.5	(20)
2%		DB	86.8	86.4	86.8	87.2	87.2	87.4	87.5	87.8	87.8	87.8	87.8	87.8	87.3	(21)
		MCWB	78.8	78.7	79.0	79.0	79.4	79.8	79.7	80.0	79.9	79.8	79.8	79.8	79.4	(22)
5%		DB	86.1	86.1	86.2	86.2	86.3	86.3	86.4	86.9	86.9	86.8	86.8	86.7	86.3	(23)
		MCWB	78.4	78.5	78.8	78.7	79.1	79.4	79.2	79.5	79.4	79.3	79.3	79.3	78.9	(24)
10%		DB	85.5	85.5	85.6	85.6	85.7	85.7	85.9	86.1	86.1	86.0	85.9	85.7	85.7	(25)
		MCWB	78.1	78.2	78.5	78.5	78.9	79.1	79.0	79.0	79.0	78.9	79.0	78.6	78.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.5	80.6	80.6	80.6	80.7	81.0	81.0	81.0	81.0	81.0	81.0	80.9	(27)
MCDWB			85.6	85.8	85.8	85.4	85.8	86.2	86.3	87.0	86.6	86.9	86.3	86.0	(28)	
2%		WB	79.8	79.7	79.8	79.9	80.0	80.3	80.2	80.3	80.4	80.3	80.3	80.3	80.1	(29)
		MCDWB	84.9	84.9	85.1	84.8	85.1	85.4	85.4	86.2	85.9	85.9	85.9	85.9	85.3	(30)
5%		WB	79.2	79.1	79.2	79.2	79.6	79.9	79.8	79.9	79.9	79.9	79.9	79.8	79.5	(31)
		MCDWB	84.3	84.3	84.5	84.3	84.6	84.9	85.0	85.5	85.3	85.3	85.3	85.2	84.7	(32)
10%		WB	78.8	78.8	78.9	79.0	79.2	79.3	79.2	79.3	79.4	79.3	79.3	79.2	79.1	(33)
		MCDWB	83.9	84.0	84.2	84.0	84.2	84.3	84.3	84.8	84.7	84.6	84.6	84.5	84.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.6	5.7	5.9	5.8	5.7	5.8	6.0	6.2	5.9	5.9	6.2	5.6	(35)
MCDBR			6.2	6.2	6.6	6.4	6.3	6.4	6.6	7.0	6.7	6.8	7.0	6.3	(36)	
MCWBR			3.5	3.7	3.5	3.2	3.0	3.2	3.3	3.4	3.4	3.6	3.5	3.5	(37)	
5% WB		MCDBR	6.0	5.9	6.3	5.9	6.0	6.0	6.3	6.5	6.2	6.3	6.5	5.8	(38)	
		MCWBR	3.6	3.7	3.5	3.3	3.1	3.4	3.4	3.5	3.4	3.6	3.5	3.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.462	0.464	0.459	0.464	0.439	0.428	0.412	0.390	0.393	0.392	0.432	0.471	(40)	
taud		2.323	2.321	2.365	2.369	2.467	2.504	2.562	2.633	2.618	2.617	2.482	2.296	(41)		
Ebn at Noon		272	274	276	270	271	271	276	287	290	292	279	266	(42)		
Edh at Noon		41	43	41	40	36	34	32	30	31	31	35	42	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1607	1752	1811	1762	1749	1675	1697	1744	1715	1627	1503	1500	(44)	
(45)		RadStd	87	85	149	130	122	91	87	116	99	106	126	106	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page