

MAJURO ATOLL, Marshall Islands

WMO: 913760

Lat: 7.068N

Lon: 171.294E

Elev: 5

StdP: 101.27

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 00492

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	24.8	25.3	21.6	16.2	27.5	22.0	16.7	27.6	11.4	28.3	10.7	28.5	4.4	70	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	31.2	26.5	31.1	26.5	30.8	26.4	27.2	30.2	27.0	30.0	26.7	29.7	4.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.4	26.1	21.5	29.3	25.8	21.2	29.1	85.9	30.8	84.9	30.3	83.9	30.0	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.8	9.1	23.5	32.9	1.0	2.1	22.8	34.4	22.2	35.6	21.7	36.7	21.0	38.3		
(5)			21.7	27.9	1.2	0.7	20.9	28.4	20.2	28.8	19.5	29.1	18.7	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	28.2	28.2	28.2	28.2	28.4	28.3	28.3	28.5	28.4	28.4	28.3	28.4
	DBStd	0.82	0.74	0.68	0.82	0.82	0.71	0.83	0.78	0.85	0.85	0.92	1.00	0.78
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6686	566	509	564	546	570	550	568	573	552	570	548	569
	CDD18.3	3644	307	276	306	296	312	300	309	314	302	312	298	311
	CDH23.3	41973	3486	3129	3452	3372	3596	3469	3566	3686	3557	3651	3417	3593
	CDH26.7	13286	1049	932	1026	1016	1142	1113	1129	1241	1186	1208	1089	1156
Wind	WSAvg	5.2	6.1	6.4	6.0	6.0	5.5	5.2	4.5	3.8	4.0	3.8	4.8	5.9
Precipitation	PrecAvg	3204	191	188	192	268	271	264	294	292	316	328	332	269
	PrecMax	4459	598	525	565	590	542	536	581	614	532	528	524	484
	PrecMin	2231	22	5	3	9	62	96	149	162	113	147	132	88
	PrecStd	489	109	126	142	155	114	96	87	89	112	106	101	100
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.0	31.1	31.2	31.2	31.2	31.2	31.4	31.5	31.4	31.8	31.2
		MCWB	26.2	26.3	26.3	26.3	26.4	26.5	26.4	26.7	26.8	26.8	26.4	26.4
	2%	DB	30.5	30.2	30.5	30.7	30.7	30.8	30.8	31.0	31.0	31.0	31.0	30.7
		MCWB	26.0	25.9	26.1	26.1	26.3	26.6	26.5	26.6	26.6	26.6	26.5	26.3
	5%	DB	30.1	30.0	30.1	30.1	30.2	30.2	30.2	30.5	30.5	30.5	30.4	30.2
		MCWB	25.8	25.8	26.0	26.0	26.1	26.3	26.2	26.4	26.4	26.3	26.3	26.0
	10%	DB	29.7	29.7	29.8	29.8	29.8	29.9	29.9	30.1	30.0	30.0	29.9	29.8
		MCWB	25.6	25.7	25.9	25.9	26.0	26.2	26.1	26.1	26.1	26.0	26.1	25.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	27.0	27.0	27.0	27.1	27.2	27.2	27.2	27.2	27.2	27.2	27.1
		MCDB	29.8	29.9	29.9	29.7	29.9	30.1	30.2	30.5	30.3	30.5	30.2	30.0
	2%	WB	26.5	26.5	26.6	26.6	26.7	26.8	26.8	26.9	26.9	26.8	26.9	26.7
		MCDB	29.4	29.4	29.5	29.3	29.5	29.7	29.7	30.1	30.0	30.0	29.9	29.6
	5%	WB	26.2	26.2	26.2	26.2	26.4	26.6	26.6	26.6	26.6	26.6	26.6	26.4
		MCDB	29.1	29.1	29.2	29.0	29.2	29.4	29.4	29.7	29.6	29.6	29.6	29.3
	10%	WB	26.0	26.0	26.1	26.1	26.2	26.3	26.2	26.3	26.3	26.3	26.2	26.2
		MCDB	28.9	28.9	29.0	28.9	29.0	29.0	29.0	29.3	29.3	29.2	29.2	29.0
Mean Daily Temperature Range	5% DB	MDBR	3.1	3.1	3.3	3.2	3.2	3.2	3.3	3.4	3.3	3.3	3.4	3.1
		MCDBR	3.5	3.5	3.6	3.6	3.5	3.6	3.7	3.9	3.7	3.8	3.9	3.5
		MCWBR	1.9	2.0	1.9	1.8	1.7	1.8	1.8	1.9	1.9	2.0	1.9	1.9
	5% WB	MCDBR	3.3	3.3	3.5	3.3	3.3	3.3	3.5	3.6	3.4	3.5	3.6	3.2
		MCWBR	2.0	2.1	2.0	1.8	1.7	1.9	1.9	2.0	1.9	2.0	1.9	2.0
Clear-Sky Solar Irradiance	taub	0.462	0.464	0.459	0.464	0.439	0.428	0.412	0.390	0.393	0.392	0.432	0.471	
	taud	2.323	2.321	2.365	2.369	2.467	2.504	2.562	2.633	2.618	2.617	2.482	2.296	
	Ebn at Noon	856	865	869	851	854	853	871	904	914	920	879	838	
	Edh at Noon	130	134	129	127	112	106	101	96	99	98	110	132	
All-Sky Solar Radiation	RadAvg	5.07	5.52	5.71	5.56	5.51	5.28	5.35	5.50	5.41	5.13	4.74	4.73	
	RadStd	0.28	0.27	0.47	0.41	0.39	0.29	0.27	0.37	0.31	0.33	0.40	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page