

KOROR, Palau

WMO: 914080

Lat: 7.3366N

Lon: 134.4770E

Elev: 176

StdP: 14.60

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 40310

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	74.8	75.1	70.0	110.9	81.2	71.2	115.9	80.9	18.8	83.3	17.9	83.5	4.9	30	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.0	89.8	80.0	89.1	79.8	88.5	79.6	81.6	86.9	80.9	86.7	80.6	86.5	8.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	158.2	84.6	79.2	152.6	84.0	79.0	151.5	83.8	45.6	87.4	44.8	87.2	44.5	87.0	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.6	15.5	13.7	DB	72.7	91.9	1.1	2.4	71.9	93.6	71.3	95.0	70.7	96.4	69.9	98.2
			WB	69.9	84.5	1.1	1.7	69.1	85.7	68.4	86.7	67.8	87.7	67.0	89.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	82.0	81.8	82.2	82.8	82.7	82.2	81.8	82.0	82.1	82.5	82.7	82.3	(6)
	DBStd	1.63	1.47	1.61	1.55	1.42	1.57	1.67	1.68	1.76	1.65	1.61	1.44	1.63	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11777	993	891	998	984	1013	966	985	991	964	1008	982	1002	(10)
	CDD65	6302	528	471	533	534	548	516	520	526	514	543	532	537	(11)
	CDH74	67512	5447	4766	5550	5887	6041	5503	5537	5677	5643	5991	5784	5686	(12)
	CDH80	20249	1503	1298	1650	1902	1933	1635	1582	1670	1712	1904	1813	1647	(13)
(14) Wind	WSAvg	6.1	6.8	7.1	6.5	6.2	5.2	5.2	6.0	6.4	6.5	5.7	5.5	6.1	(14)
(15) Precipitation	PrecAvg	145.8	10.9	9.4	7.8	8.8	12.4	16.5	17.1	13.9	12.8	12.9	11.1	12.1	(15)
	PrecMax	185.0	28.1	25.0	22.0	27.7	20.2	33.8	34.8	33.1	23.7	22.5	20.7	21.1	(16)
	PrecMin	96.6	2.1	0.6	0.2	2.3	4.0	5.9	3.7	4.0	1.0	5.9	3.6	1.5	(17)
	PrecStd	20.7	5.7	5.5	4.2	5.0	3.8	5.6	7.5	5.0	5.0	3.9	3.8	4.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	89.1	89.9	90.0	90.0	89.9	89.2	89.3	89.5	89.8	90.0	89.8	(19)
		MCWB	79.4	78.9	78.7	79.7	80.4	80.6	79.9	79.8	79.9	80.3	80.3	80.1	(20)
	2%	DB	88.1	88.1	88.5	89.0	89.1	88.7	88.1	88.1	88.2	88.6	89.0	88.5	(21)
		MCWB	79.1	78.8	78.6	79.6	80.1	80.1	79.6	79.4	79.5	79.9	80.0	79.8	(22)
	5%	DB	87.4	87.3	87.8	88.1	88.2	87.8	87.3	87.3	87.6	87.9	88.0	87.8	(23)
		MCWB	78.9	78.6	78.6	79.4	80.0	79.9	79.4	79.2	79.4	79.7	79.8	79.7	(24)
	10%	DB	86.3	86.2	86.8	87.5	87.4	86.6	86.2	86.2	86.4	87.0	87.3	86.6	(25)
		MCWB	78.7	78.3	78.4	79.2	79.8	79.5	79.0	78.9	79.0	79.3	79.6	79.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.8	80.9	81.5	82.1	82.0	81.7	81.7	81.2	81.5	81.7	81.6	(27)
		MCDB	86.4	86.8	87.0	87.1	88.0	87.3	85.9	85.4	86.9	87.4	87.2	86.9	(28)
	2%	WB	80.1	79.9	80.0	80.6	81.0	80.9	80.5	80.4	80.1	80.6	80.8	80.7	(29)
		MCDB	85.7	85.6	86.0	86.8	86.9	86.6	86.1	85.8	85.9	86.7	86.7	86.4	(30)
	5%	WB	79.6	79.2	79.4	80.0	80.4	80.1	79.8	79.7	79.6	80.0	80.2	80.0	(31)
		MCDB	84.9	84.6	85.0	85.7	86.1	85.5	85.0	84.9	85.1	85.6	85.7	85.3	(32)
	10%	WB	79.0	78.8	78.9	79.4	79.9	79.7	79.2	79.1	79.1	79.4	79.7	79.5	(33)
		MCDB	84.0	84.0	84.4	84.8	85.0	84.6	84.0	84.1	84.3	84.6	84.9	84.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.6	10.1	10.0	10.0	9.8	9.3	9.0	9.2	9.7	9.9	9.6	(35)
		MCDDBR	10.7	10.8	11.0	10.8	11.1	11.0	10.4	10.1	10.2	10.5	10.8	10.5	(36)
	5% WB	MCWBR	5.0	4.9	4.9	4.9	5.0	4.9	4.9	4.8	4.9	4.7	4.8	4.9	(37)
		MCDWBR	10.0	9.9	10.2	10.2	10.3	10.3	9.8	9.5	9.6	9.9	10.2	10.0	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.440	0.433	0.427	0.417	0.399	0.389	0.397	0.405	0.399	0.416	0.408	0.430	(40)
		taud	2.434	2.448	2.486	2.530	2.600	2.630	2.600	2.557	2.576	2.510	2.555	2.477	(41)
	Ebn at Noon	Ebn at Noon	278	283	285	283	282	282	281	282	288	285	286	279	(42)
		Edh at Noon	37	37	36	34	31	30	31	33	33	35	33	35	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1584	1711	1867	1918	1736	1597	1539	1628	1666	1695	1592	1498	(44)
	RadStd	RadStd	112	160	129	132	121	98	171	110	172	122	134	118	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	-0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page