

HONIARA, Solomon Islands

WMO: 915170

Lat: 9.435S

Lon: 159.954E

Elev: 184

StdP: 14.60

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	72.6	73.4	67.2	100.7	75.9	68.5	105.4	76.7	15.7	80.9	13.6	83.8	6.9	180	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.6	90.9	80.1	90.2	79.8	89.7	79.6	81.8	88.9	81.2	88.4	80.8	88.0	6.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.9	156.3	86.9	79.2	152.3	86.2	78.7	149.7	85.8	45.8	89.2	45.1	88.6	44.6	88.2	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.2	9.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.5	81.9	81.7	81.7	81.9	81.8	81.2	80.6	80.7	81.1	81.4	81.8	82.1
	DBStd	1.57	1.79	1.44	1.67	1.39	1.38	1.57	1.55	1.57	1.39	1.32	1.23	1.53
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11491	989	888	981	956	986	936	947	951	933	973	954	997
	CDD65	6016	524	468	516	506	521	486	482	486	483	508	504	532
	CDH74	56751	5162	4535	4870	4838	4933	4378	4038	4213	4475	4858	5055	5396
	CDH80	18760	1690	1464	1587	1619	1638	1402	1224	1355	1496	1636	1759	1890
(14) Wind	WSAvg	4.9	4.5	4.5	4.7	5.0	5.0	4.9	4.9	5.0	5.0	5.2	5.4	5.1
(15) Precipitation	PrecAvg	110.7	11.7	12.1	11.1	8.9	8.9	8.9	9.6	8.6	7.6	7.7	7.4	8.3
	PrecMax	136.5	21.8	19.8	20.2	20.2	16.8	15.4	18.4	16.0	14.1	12.4	14.5	15.7
	PrecMin	80.4	4.6	4.8	4.4	4.3	3.9	3.4	3.2	4.4	4.1	1.7	2.1	2.5
	PrecStd	12.6	4.3	3.6	3.7	3.3	2.6	2.5	3.0	2.7	2.4	2.3	2.7	3.3
	PrecStd	12.6	4.3	3.6	3.7	3.3	2.6	2.5	3.0	2.7	2.4	2.3	2.7	3.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	91.5	91.0	90.7	90.8	90.0	89.7	90.2	90.7	90.6	91.0	91.7
		MCWB	80.6	80.3	80.5	80.6	80.1	79.5	78.7	78.0	79.2	79.0	79.9	80.9
	2%	DB	90.1	89.9	89.9	89.7	89.6	89.1	88.6	88.8	89.3	89.4	89.9	90.4
		MCWB	80.1	79.7	80.0	80.2	79.7	79.2	78.5	78.1	78.8	79.0	79.5	80.4
	5%	DB	89.2	88.8	88.9	88.8	88.7	88.2	87.6	87.9	88.2	88.4	88.9	89.4
		MCWB	79.8	79.3	79.7	79.8	79.5	78.9	78.2	78.1	78.6	78.8	79.2	80.0
	10%	DB	87.9	87.5	87.7	87.8	87.7	87.1	86.5	86.9	87.3	87.4	87.8	88.2
		MCWB	79.5	79.0	79.3	79.5	79.3	78.5	77.9	77.8	78.3	78.5	78.9	79.5
	0.4%	WB	82.4	82.5	82.1	81.8	81.8	81.1	80.7	80.9	81.0	81.4	81.5	82.6
		MCDB	89.6	89.5	88.9	89.1	88.7	88.2	87.5	87.7	88.3	88.3	89.3	89.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	81.3	81.0	81.0	80.9	80.8	80.2	79.7	79.7	80.0	80.2	80.5	81.2
		MCDB	88.4	87.8	88.1	88.2	88.0	87.4	86.8	87.1	87.7	87.8	88.2	88.8
	5%	WB	80.6	80.2	80.4	80.4	80.1	79.5	79.0	78.9	79.3	79.5	79.8	80.5
		MCDB	87.6	86.8	87.4	87.5	87.3	86.6	86.2	86.6	87.1	87.0	87.4	88.2
	10%	WB	79.9	79.5	79.7	79.7	79.5	78.9	78.2	78.1	78.7	78.8	79.2	79.8
		MCDB	86.3	85.8	86.3	86.5	86.5	86.0	85.1	85.4	86.4	86.4	86.5	86.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.7	11.9	12.1	12.0	11.9	11.8	12.3	12.7	12.5	12.7	12.6
		MCDBR	13.8	13.8	13.8	13.5	13.4	13.4	13.6	13.9	14.0	13.8	14.0	14.3
		MCWBR	6.5	6.7	6.9	6.8	6.5	6.4	6.6	6.7	6.9	7.0	6.7	6.9
	5% WB	MCDBR	12.7	12.4	13.0	12.8	12.7	12.5	12.6	13.2	13.3	13.1	13.2	13.5
		MCWBR	6.5	6.6	6.9	6.7	6.7	6.5	6.6	7.0	7.0	7.2	6.9	7.0
(40) Clear-Sky Solar Irradiance	taub		0.421	0.415	0.409	0.403	0.406	0.419	0.440	0.435	0.430	0.429	0.427	0.423
	taud		2.452	2.462	2.495	2.523	2.517	2.489	2.409	2.421	2.442	2.425	2.422	2.435
	Ebn at Noon		292	293	290	282	272	263	259	269	279	285	288	291
	Edh at Noon		38	38	36	33	32	32	35	36	37	39	39	39
	RadAvg		1660	1701	1663	1590	1436	1289	1274	1458	1654	1748	1800	1748
(45) All-Sky Solar Radiation	RadStd		214	146	141	138	97	115	80	88	108	119	100	106

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page