

HONIARA, Solomon Islands

WMO: 915170

Lat: 9.435S

Lon: 159.954E

Elev: 56

StdP: 100.65

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	23.0	19.6	14.4	24.4	20.3	15.1	24.8	7.0	27.1	6.1	28.8	3.1	180	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.0	32.7	26.7	32.4	26.6	32.0	26.4	27.7	31.6	27.3	31.3	27.1	31.1	2.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.3	30.5	26.2	21.8	30.1	25.9	21.4	29.9	88.7	31.8	87.1	31.4	85.8	31.2	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	5.0	4.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.7	27.6	27.6	27.7	27.7	27.3	27.0	27.0	27.3	27.4	27.7	27.9
	DBStd	0.87	0.99	0.80	0.93	0.77	0.77	0.87	0.86	0.87	0.77	0.73	0.68	0.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6384	549	493	545	531	548	520	526	528	518	541	530	554
	CDD18.3	3342	291	260	287	281	289	270	268	270	268	282	280	296
	CDH23.3	31528	2868	2519	2706	2688	2741	2432	2243	2341	2486	2699	2808	2998
	CDH26.7	10422	939	813	882	899	910	779	680	753	831	909	977	1050
(14) Wind	WSAvg	2.2	2.0	2.0	2.1	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.4	2.3
(15) Precipitation	PrecAvg	2813	297	307	283	227	226	226	243	218	192	196	188	211
	PrecMax	3468	553	504	513	514	427	392	468	407	358	314	369	400
	PrecMin	2043	117	123	113	109	100	86	81	111	103	42	53	63
	PrecStd	319	110	91	95	83	66	64	75	68	62	59	68	85
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.0	32.8	32.6	32.6	32.2	32.1	32.4	32.6	32.6	32.8	33.2
		MCWB	27.0	26.8	27.0	27.0	26.7	26.4	25.9	25.6	26.2	26.1	26.6	27.2
	2%	DB	32.3	32.2	32.2	32.0	32.0	31.7	31.4	31.6	31.9	31.9	32.2	32.4
		MCWB	26.7	26.5	26.7	26.8	26.5	26.2	25.8	25.6	26.0	26.1	26.4	26.9
	5%	DB	31.8	31.6	31.6	31.6	31.5	31.2	30.9	31.0	31.2	31.4	31.6	31.9
		MCWB	26.6	26.3	26.5	26.6	26.4	26.0	25.7	25.6	25.9	26.0	26.2	26.7
	10%	DB	31.1	30.9	30.9	31.0	30.9	30.6	30.3	30.5	30.7	30.8	31.0	31.2
		MCWB	26.4	26.1	26.3	26.4	26.3	25.9	25.5	25.5	25.7	25.9	26.1	26.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.1	27.8	27.7	27.6	27.3	27.1	27.2	27.2	27.5	27.5	28.1
		MCDB	32.0	31.9	31.6	31.7	31.5	31.2	30.9	31.0	31.3	31.3	31.8	32.2
	2%	WB	27.4	27.2	27.2	27.2	27.1	26.8	26.5	26.5	26.7	26.8	26.9	27.3
		MCDB	31.3	31.0	31.1	31.2	31.1	30.8	30.4	30.6	30.9	31.0	31.2	31.6
	5%	WB	27.0	26.8	26.9	26.9	26.7	26.4	26.1	26.0	26.3	26.4	26.6	27.0
		MCDB	30.9	30.5	30.8	30.8	30.7	30.4	30.1	30.3	30.6	30.6	30.8	31.2
	10%	WB	26.6	26.4	26.5	26.5	26.4	26.0	25.7	25.6	25.9	26.0	26.2	26.5
		MCDB	30.2	29.9	30.1	30.3	30.3	30.0	29.5	29.7	30.2	30.2	30.3	30.5
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.5	6.6	6.7	6.7	6.6	6.6	6.8	7.1	7.0	7.0	7.0
		MCDBR	7.7	7.7	7.7	7.5	7.5	7.4	7.6	7.7	7.8	7.7	7.8	7.9
	5% WB	MCWBR	3.6	3.7	3.8	3.8	3.6	3.6	3.7	3.7	3.8	3.9	3.7	3.9
		MCWBR	7.1	6.9	7.2	7.1	7.1	6.9	7.0	7.3	7.4	7.3	7.3	7.5
(40) Clear-Sky Solar Irradiance	taub		0.421	0.415	0.409	0.403	0.406	0.419	0.440	0.435	0.430	0.429	0.427	0.423
		taud	2.452	2.462	2.495	2.523	2.517	2.489	2.409	2.421	2.442	2.425	2.422	2.435
	Ebn at Noon		921	923	913	889	856	828	817	847	880	899	909	916
		Edh at Noon	120	119	113	105	101	101	111	115	117	122	123	122
(44) All-Sky Solar Radiation	RadAvg		5.23	5.36	5.24	5.01	4.53	4.06	4.01	4.60	5.21	5.51	5.68	5.51
	RadStd		0.67	0.46	0.45	0.44	0.31	0.36	0.25	0.28	0.34	0.38	0.31	0.33

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page