

HONIARA INTL, Solomon Islands

WMO: 915200

Lat: 9.4294S

Lon: 160.0469E

Elev: 9

StdP: 101.22

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	21.6	19.5	14.3	23.9	20.1	14.8	24.0	8.6	30.5	8.1	30.4	0.7	160	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	32.5	26.3	32.1	26.3	31.9	26.2	27.7	30.9	27.2	30.7	27.0	30.6	5.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.4	29.9	26.2	21.7	29.4	26.1	21.5	29.3	88.1	31.0	86.5	31.2	85.5	30.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.6	5.6	19.2	34.5	1.0	2.1	18.5	36.0	17.9	37.2	17.4	38.4	16.7	39.9		
(5)			18.6	29.3	1.1	0.9	17.8	30.0	17.2	30.5	16.6	31.0	15.8	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	27.4	27.3	27.2	27.1	27.0	26.7	26.4	26.4	26.7	26.8	27.0	27.3		
	DBStd	0.84	0.78	0.79	0.74	0.73	0.77	0.81	0.81	0.86	0.85	0.79	0.76	0.64		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6182	538	483	533	514	528	501	510	508	500	519	511	536		
	CDD18.3	3140	280	250	274	264	270	251	252	249	250	261	261	278		
	CDH23.3	28875	2756	2391	2560	2450	2474	2151	2084	2076	2267	2411	2517	2739		
	CDH26.7	10106	931	796	848	842	892	756	721	717	824	873	914	992		
(14) Wind	WSAvg	1.8	1.6	1.8	1.5	1.5	1.7	1.9	2.0	2.0	2.2	1.9	1.6	1.6		
(15) Precipitation	PrecAvg	2004	251	308	306	182	126	88	108	97	104	126	148	184		
	PrecMax	2898	832	614	645	346	405	272	311	176	247	383	398	454		
	PrecMin	1271	33	82	54	31	24	16	16	25	26	7	13	52		
	PrecStd	413	161	148	155	84	86	55	59	34	56	83	92	92		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	32.9	32.4	32.2	32.5	32.2	32.2	32.2	32.7	32.9	32.3	32.5		
		MCWB	26.5	25.7	26.6	26.6	26.6	26.3	25.9	25.6	25.9	26.1	26.0	26.5		
	2%	DB	32.0	31.8	31.9	31.8	31.9	31.8	31.5	31.5	31.9	32.0	31.8	32.0		
		MCWB	26.6	26.2	26.5	26.6	26.4	26.2	25.7	25.6	25.7	26.1	26.1	26.5		
	5%	DB	31.2	31.1	31.2	31.1	31.2	31.1	30.9	30.9	31.2	31.2	31.2	31.2		
		MCWB	26.5	26.3	26.4	26.5	26.3	26.0	25.6	25.6	25.8	26.0	26.1	26.4		
	10%	DB	30.9	30.7	30.7	30.7	30.8	30.5	30.2	30.2	30.7	30.6	30.8	30.9		
		MCWB	26.4	26.2	26.3	26.3	26.2	25.8	25.4	25.3	25.7	25.8	26.0	26.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.0	27.7	27.7	27.7	27.7	27.1	27.2	27.1	27.3	27.4	27.7		
		MCDB	31.0	30.3	31.0	30.9	31.3	30.8	30.7	30.9	31.0	31.2	31.2	31.1		
	2%	WB	27.3	27.2	27.2	27.1	27.1	26.9	26.5	26.5	26.6	26.7	26.8	27.2		
		MCDB	30.7	30.3	30.6	30.7	30.9	30.7	30.2	30.4	30.6	30.7	30.6	30.8		
	5%	WB	26.9	26.8	26.8	26.7	26.7	26.4	26.1	26.0	26.2	26.3	26.5	26.9		
		MCDB	30.4	30.0	30.2	30.2	30.4	30.1	29.8	29.9	30.2	30.2	30.2	30.4		
	10%	WB	26.6	26.4	26.5	26.4	26.3	26.0	25.7	25.6	25.8	26.0	26.1	26.5		
		MCDB	29.8	29.5	29.7	29.8	29.9	29.6	29.3	29.3	29.7	29.9	29.8	29.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	6.8	6.9	7.1	7.5	7.7	7.8	8.0	8.1	8.0	7.7	7.4		
		MCDBR	7.9	7.8	7.9	7.9	8.3	8.7	9.0	9.1	9.0	8.9	8.4	8.1		
		MCWBR	3.7	3.6	3.7	3.8	3.9	4.2	4.0	4.2	4.1	4.2	3.9	3.9		
	5% WB	MCDBR	7.4	7.0	7.2	7.5	7.9	8.1	8.1	8.2	8.3	8.3	7.9	7.7		
		MCWBR	3.7	3.7	3.6	3.8	4.0	4.2	4.0	4.1	4.1	4.2	3.9	4.0		
(40) Clear-Sky Solar Irradiance	taub		0.425	0.419	0.412	0.407	0.410	0.424	0.446	0.441	0.435	0.434	0.432	0.428		
	taud		2.440	2.451	2.485	2.513	2.506	2.474	2.389	2.403	2.427	2.413	2.409	2.423		
	Ebn at Noon		917	919	909	886	853	824	811	842	875	894	904	912		
	Edh at Noon		122	120	114	106	102	102	113	117	119	124	125	123		
(44) All-Sky Solar Radiation	RadAvg		5.22	5.35	5.23	5.00	4.51	4.04	3.99	4.56	5.18	5.47	5.64	5.49		
	RadStd		0.66	0.45	0.45	0.44	0.30	0.36	0.25	0.27	0.35	0.38	0.32	0.33		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page