

WHITE GRASS TANNA ISLAND, Vanuatu

WMO: 915650

Lat: 19.455S

Lon: 169.224E

Elev: 19

StdP: 14.69

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	60.7	62.1	54.1	62.2	65.7	55.9	66.6	66.5	21.1	75.7	20.1	75.7	1.6	120	0.270

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.9	88.5	80.1	87.7	79.7	86.5	79.0	82.5	86.8	81.4	85.9	80.5	85.3	9.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.2	86.0	80.1	156.3	85.2	79.0	150.7	84.2	46.4	87.2	45.2	86.2	44.2	85.3	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
19.9	18.1	15.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.9	79.4	80.6	80.0	78.1	75.1	72.9	71.5	71.2	72.7	74.6	76.4	78.6
	DBStd	4.10	1.95	1.87	1.75	2.40	2.62	3.08	2.68	3.09	2.76	2.66	2.51	2.30
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9454	913	856	930	842	780	686	667	657	680	763	792	888
	CDD65	3979	448	436	465	392	315	236	202	192	230	298	342	423
	CDH74	29879	4238	4352	4453	3157	1808	1023	668	690	1159	1949	2571	3811
	CDH80	6842	1185	1369	1330	706	207	75	36	33	111	285	481	1024
(14) Wind	WSAvg	5.8	5.9	5.6	4.9	5.0	5.1	5.6	5.7	6.5	6.5	6.7	6.3	6.3
(15) Precipitation	PrecAvg	79.8	10.4	8.7	10.9	10.6	7.6	3.9	4.2	4.3	3.8	4.5	4.9	6.7
	PrecMax	115.5	23.1	22.6	23.9	21.9	16.3	9.6	9.1	10.1	12.2	12.8	12.6	13.0
	PrecMin	55.5	3.7	2.3	4.7	5.6	3.6	1.2	1.8	2.3	1.3	1.9	2.2	3.3
	PrecStd	14.6	5.1	4.7	4.7	4.6	3.4	2.4	1.9	2.0	2.9	2.4	2.5	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	90.0	90.0	88.2	84.8	84.0	83.0	82.7	85.0	86.4	87.1	88.2
		MCWB	79.8	81.7	80.9	80.1	78.1	76.4	75.8	74.1	74.5	76.5	77.6	78.5
	2%	DB	87.7	88.6	88.1	86.4	83.8	82.2	80.9	80.6	82.8	84.5	85.8	87.2
		MCWB	78.8	80.9	80.7	79.4	77.3	74.9	73.8	72.5	74.0	75.2	76.7	78.1
	5%	DB	86.3	87.6	86.8	85.4	82.4	80.6	79.2	79.0	81.2	82.8	84.4	86.1
		MCWB	78.1	80.4	80.2	78.8	76.1	73.7	72.5	71.5	72.9	74.2	75.8	77.8
	10%	DB	85.4	86.3	85.9	84.1	80.9	79.1	77.5	77.7	79.8	81.4	83.0	85.0
		MCWB	77.6	79.5	79.7	78.0	74.9	72.9	71.1	70.7	71.9	73.4	75.1	77.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	84.7	84.1	82.1	80.1	77.9	77.7	76.7	77.2	78.7	80.3	81.0
		MCDB	87.5	88.8	87.6	86.1	83.7	82.2	81.4	80.8	82.3	84.1	84.9	85.8
	2%	WB	80.5	82.6	82.5	80.8	78.6	76.5	75.3	74.7	75.5	76.8	78.7	79.9
		MCDB	85.9	87.1	86.5	85.2	82.2	80.6	79.8	79.1	81.2	82.3	83.7	85.1
	5%	WB	79.6	81.4	81.3	79.8	77.3	75.2	73.8	73.2	74.4	75.6	77.4	79.0
		MCDB	84.8	86.2	85.6	84.2	81.2	79.1	78.2	77.9	79.9	81.5	82.6	84.5
	10%	WB	78.8	80.4	80.3	78.8	76.2	74.1	72.5	71.7	73.1	74.5	76.4	78.3
		MCDB	83.9	85.3	84.8	83.2	80.1	78.3	76.7	76.5	78.3	80.4	81.6	83.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.9	11.8	11.4	11.6	11.6	12.3	12.7	13.4	14.1	12.9	12.2
		MCDBR	13.7	13.2	13.7	13.3	12.3	12.6	13.8	14.0	15.0	15.2	13.8	13.5
	5% WB	MCWBR	7.3	7.6	8.3	7.8	7.6	7.3	8.5	8.0	8.6	8.8	7.5	7.4
		MCWBR	12.3	12.7	12.7	12.2	11.4	10.8	12.6	12.2	13.4	14.0	12.3	12.3
(40) Clear-Sky Solar Irradiance	taub	taub	0.401	0.393	0.390	0.384	0.390	0.375	0.355	0.363	0.372	0.384	0.387	0.385
		taud	2.553	2.581	2.601	2.608	2.546	2.586	2.621	2.590	2.546	2.534	2.551	2.583
	Ebn at Noon	Ebn at Noon	300	298	292	281	267	266	276	284	293	298	302	305
		Edh at Noon	35	33	32	29	29	27	27	30	33	35	35	34
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2086	2020	1763	1481	1254	1132	1209	1426	1737	1932	2039	2148
	RadStd	RadStd	148	135	112	128	102	96	75	80	154	135	142	139

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page