

ANEITYUM ISLAND, Vanuatu

WMO: 915680

Lat: 20.233S

Lon: 169.767E

Elev: 7

StdP: 101.24

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 15.4	(c) 16.4	(d) 12.0	(e) 8.7	(f) 20.3	(g) 13.0	(h) 9.3	(i) 20.5	(j) 11.2	(k) 22.5	(l) 9.8	(m) 22.7	(n) 0.7	(o) 10	(p) 0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 5.8	(c) 31.2	(d) 26.9	(e) 30.6	(f) 26.5	(g) 30.0	(h) 26.1	(i) 27.6	(j) 30.4	(k) 27.1	(l) 29.9	(m) 26.7	(n) 29.3	(o) 3.3	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.3	29.6	26.3	21.7	29.1	25.9	21.3	28.7	87.8	30.5	85.7	29.9	83.9	29.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.8	(b) 8.7	(c) 7.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 9.8	(b) 8.7	(c) 7.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.3	26.6	26.9	26.7	25.7	23.8	22.7	21.7	21.6	22.3	23.4	24.4	25.7	
	DBStd	2.33	1.20	1.20	0.98	1.14	1.40	1.43	1.61	1.64	1.58	1.38	1.32	1.32	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDD10.0	5211	515	472	517	469	428	381	363	361	368	417	433	487	
	CDD18.3	2169	257	239	258	219	170	131	105	102	118	158	183	229	
	CDH23.3	15307	2559	2462	2490	1740	863	363	224	259	432	783	1154	1976	
	CDH26.7	2943	636	714	589	249	62	17	7	12	27	67	123	439	
Wind	WSAvg	3.2	3.5	3.2	3.0	3.1	3.1	3.4	3.1	3.1	3.2	3.6	3.7	2.9	
Precipitation	PrecAvg	2261	250	261	349	280	202	142	125	97	97	122	130	206	
	PrecMax	3396	663	816	815	742	640	387	234	234	444	415	379	673	
	PrecMin	1469	46	58	91	77	56	41	31	21	9	7	25	24	
	PrecStd	499	160	166	169	167	146	80	56	54	103	100	99	139	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	32.6	31.8	30.7	29.2	28.5	27.5	28.1	28.7	29.3	30.1	31.2	
		MCWB	27.2	27.7	27.2	26.4	25.0	24.8	23.7	23.7	24.2	24.6	25.4	26.5	
	2%	DB	30.7	31.5	30.7	29.6	28.1	26.9	26.2	26.5	27.4	28.1	29.0	30.3	
		MCWB	26.7	27.2	26.6	26.0	24.6	23.3	22.8	22.6	23.1	23.7	24.9	26.0	
	5%	DB	30.0	30.6	30.0	28.9	27.2	25.9	25.4	25.6	26.5	27.2	28.1	29.7	
		MCWB	26.3	26.6	26.3	25.6	23.8	22.5	22.1	21.8	22.4	23.1	24.1	25.5	
	10%	DB	29.4	29.9	29.3	28.2	26.5	25.2	24.6	24.8	25.6	26.5	27.4	29.0	
		MCWB	25.8	26.2	25.9	25.1	23.3	22.0	21.3	21.1	21.7	22.6	23.5	25.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	28.7	27.7	27.1	26.0	25.4	24.6	24.6	25.1	25.7	26.4	27.3
			MCDB	30.7	31.7	30.6	29.6	28.2	27.7	26.5	27.4	27.9	28.6	29.2	30.5
2%		WB	27.4	27.8	27.2	26.6	25.2	24.3	23.7	23.5	24.1	24.6	25.6	26.7	
		MCDB	30.0	30.7	29.9	28.9	27.2	26.1	25.7	25.8	26.6	27.1	28.2	29.7	
5%		WB	26.9	27.2	26.7	26.1	24.7	23.5	22.8	22.6	23.3	23.9	24.9	26.1	
		MCDB	29.4	30.0	29.3	28.3	26.6	25.3	24.8	25.0	25.6	26.4	27.4	28.9	
10%		WB	26.4	26.6	26.4	25.6	24.2	22.7	22.0	21.8	22.5	23.3	24.3	25.6	
		MCDB	28.8	29.3	28.8	27.6	26.0	24.7	24.0	24.3	24.9	25.8	26.6	28.3	
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.8	5.1	4.7	5.3	4.7	5.5	6.1	6.3	5.9	5.5	6.0	
		MCDBR	6.4	7.1	6.5	6.2	6.6	6.2	6.8	7.2	7.8	7.4	6.8	7.3	
		MCWBR	3.7	3.9	3.6	3.3	3.8	3.5	4.2	4.3	4.6	4.3	3.8	4.0	
	5% WB	MCDBR	6.1	6.5	6.1	5.4	5.7	5.6	6.2	6.5	6.8	6.6	6.0	6.5	
		MCWBR	3.7	3.8	3.6	3.3	3.6	3.7	4.3	4.7	4.7	4.3	3.7	4.0	
Clear-Sky Solar Irradiance	taub	0.392	0.384	0.387	0.377	0.376	0.364	0.343	0.351	0.361	0.374	0.380	0.376		
	taud	2.582	2.613	2.616	2.632	2.589	2.615	2.658	2.626	2.575	2.560	2.568	2.614		
	Ebn at Noon	953	949	922	893	854	847	881	905	932	947	958	969		
	Edh at Noon	107	102	98	90	87	82	80	89	100	106	107	103		
All-Sky Solar Radiation	RadAvg	6.71	6.50	5.62	4.65	3.90	3.52	3.77	4.52	5.51	6.18	6.57	6.91		
	RadStd	0.45	0.42	0.32	0.41	0.32	0.28	0.24	0.26	0.48	0.37	0.46	0.42		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page