

ILE ART, New Caledonia

WMO: 915730

Lat: 19.721S

Lon: 163.660E

Elev: 84

StdP: 100.32

Time Zone: 11.00 (E11)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	18.4	2.1	4.5	23.1	10.2	7.8	20.4	10.4	22.2	9.3	22.4	2.4	120	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.6	30.4	25.9	29.9	25.5	29.5	25.2	27.2	29.1	26.7	28.7	26.2	28.3	5.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.5	28.2	26.1	21.8	28.0	25.6	21.1	27.7	86.6	29.2	84.4	28.9	82.3	28.5	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.5	8.3	16.4	31.2	1.0	0.5	15.7	31.6	15.1	31.9	14.6	32.2	13.9	32.6		
(5)			12.3	27.5	1.7	0.9	11.1	28.1	10.2	28.7	9.2	29.2	8.0	29.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	26.8	27.2	26.5	25.5	23.7	22.8	21.5	21.8	22.6	23.9	25.0	26.1	(6)
(7)		DBStd	2.21	1.05	0.91	0.95	1.04	1.12	1.24	1.10	1.33	1.26	1.22	1.09	0.99	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5264	521	481	511	463	426	384	357	364	378	430	449	499	(10)
(11)		CDD18.3	2222	263	247	253	213	167	134	99	106	128	172	199	241	(11)
(12)		CDH23.3	13616	2421	2429	2206	1446	569	256	68	132	301	698	1170	1920	(12)
(13)		CDH26.7	2135	537	580	348	119	13	3	0	1	7	43	133	349	(13)
(14)	Wind	WSAvg	4.8	4.9	4.6	5.1	4.8	4.8	4.4	4.5	4.6	5.1	5.3	5.0	(14)	
(15)	Precipitation	PrecAvg	1571	190	219	242	195	145	97	81	69	61	56	99	119	(15)
(16)		PrecMax	2541	341	465	576	525	374	186	417	198	156	248	260	320	(16)
(17)		PrecMin	1040	25	53	32	23	31	18	15	6	2	3	0	24	(17)
(18)		PrecStd	435	99	135	138	126	85	44	89	53	47	56	71	73	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.3	30.2	29.5	27.9	27.0	25.4	26.4	27.7	28.5	29.6	30.5	(19)
(20)			MCWB	26.2	26.1	26.1	25.5	23.8	21.7	21.5	22.3	23.3	23.5	25.2	25.7	(20)
(21)		2%	DB	30.3	30.5	29.7	28.6	27.0	26.0	24.7	25.4	26.4	27.7	28.7	29.7	(21)
(22)			MCWB	25.7	26.0	25.7	24.7	22.8	20.8	21.3	22.0	22.8	23.9	25.1	(22)	
(23)		5%	DB	29.7	30.0	29.1	27.9	26.3	25.4	24.1	24.7	25.7	27.1	28.1	29.2	(23)
(24)			MCWB	25.3	25.7	25.5	24.1	22.2	21.6	20.1	20.7	21.2	22.3	23.1	24.7	(24)
(25)		10%	DB	29.2	29.5	28.5	27.3	25.7	24.7	23.5	24.0	25.0	26.4	27.4	28.6	(25)
(26)			MCWB	24.9	25.3	25.1	23.8	21.8	21.2	19.7	20.2	20.7	21.8	22.6	24.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.6	28.5	26.2	25.0	24.6	23.1	23.7	24.2	24.7	26.1	26.7	(27)
(28)			MCDWB	29.6	30.0	28.9	28.3	26.8	26.0	24.5	25.1	26.6	27.3	28.3	29.3	(28)
(29)		2%	WB	27.0	27.1	27.3	25.6	24.2	23.8	22.1	22.6	23.2	23.8	25.2	26.1	(29)
(30)			MCDWB	29.2	29.5	28.4	27.6	26.0	25.1	23.7	24.4	25.5	26.5	27.4	28.7	(30)
(31)		5%	WB	26.5	26.6	26.6	25.2	23.6	23.1	21.4	21.8	22.4	23.3	24.7	25.5	(31)
(32)			MCDWB	28.6	28.9	28.0	27.0	25.6	24.6	23.5	23.9	24.8	26.0	26.9	28.1	(32)
(33)		10%	WB	26.0	26.1	26.0	24.7	23.1	22.4	20.7	21.1	21.6	22.7	24.0	25.1	(33)
(34)			MCDWB	28.0	28.4	27.5	26.6	25.2	24.2	23.0	23.3	24.1	25.5	26.4	27.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	4.6	3.8	3.7	3.8	3.5	4.0	4.3	4.7	4.9	4.8	4.8	(35)
(36)			MCDBR	5.2	5.0	4.6	4.2	4.3	3.9	4.5	4.8	5.1	5.5	5.3	5.5	(36)
(37)			MCWBR	2.4	2.4	2.4	2.3	2.6	2.5	2.7	2.7	2.6	2.6	2.5	2.5	(37)
(38)		5% WB	MCDWB	4.8	4.5	4.2	3.8	3.7	3.2	3.6	4.2	4.7	5.0	4.6	4.8	(38)
(39)			MCWBR	2.7	2.4	2.8	2.2	2.5	2.5	2.7	2.6	2.6	2.6	2.5	2.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.383	0.381	0.381	0.369	0.358	0.354	0.337	0.340	0.355	0.365	0.378	0.375	(40)	
(41)		taud	2.608	2.628	2.636	2.648	2.635	2.638	2.662	2.652	2.574	2.580	2.565	2.611	(41)	
(42)		Ebn at Noon	961	952	929	902	875	860	889	918	938	956	960	970	(42)	
(43)		Edh at Noon	104	100	96	89	84	80	87	100	104	108	104	104	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.80	6.49	5.55	4.86	4.08	3.72	4.04	4.81	5.93	6.56	6.77	7.03	(44)	
(45)		RadStd	0.55	0.52	0.48	0.44	0.32	0.21	0.26	0.32	0.33	0.41	0.44	0.44	0.57	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page