

KOUMAC, New Caledonia

WMO: 915770

Lat: 20.559S

Lon: 164.284E

Elev: 19

StdP: 101.10

Time Zone: 11.00 (E11)

Period: 95-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.9	15.7	9.9	7.6	18.1	10.8	8.1	18.6	10.5	22.0	9.9	22.3	1.8	40	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.1	31.3	25.2	30.6	25.0	30.0	24.8	26.5	29.7	26.1	29.2	25.7	28.7	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	20.8	28.4	25.1	20.3	28.0	24.7	19.8	27.7	82.9	29.8	81.0	29.3	79.4	28.8	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.2	8.2	DB	13.1	33.2	1.6	0.8	12.0	33.8	11.1	34.3	10.2	34.8	9.0	35.4	(4)
(5)			WB	11.2	27.1	1.0	0.6	10.5	27.6	10.0	27.9	9.4	28.2	8.7	28.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	26.4	26.9	26.3	24.9	23.1	21.7	20.6	20.5	21.5	22.8	24.2	25.7	(6)	
	DBStd	2.60	1.17	1.09	1.09	1.30	1.47	1.44	1.38	1.57	1.37	1.37	1.27	1.10	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0	(9)	
	CDD10.0	4998	509	473	505	448	407	352	328	324	344	396	426	486	(10)	
	CDD18.3	1958	251	240	247	198	148	102	70	67	94	138	176	228	(11)	
	CDH23.3	13769	2399	2376	2176	1332	666	285	125	145	326	723	1235	1981	(12)	
	CDH26.7	2907	659	692	517	218	53	14	4	4	14	66	183	483	(13)	
(14) Wind	WSAvg	3.3	3.4	3.1	3.1	3.2	3.0	2.9	3.2	3.4	3.4	3.8	3.7	3.5	(14)	
(15) Precipitation	PrecAvg	1021	163	161	145	81	75	73	51	43	33	29	51	89	(15)	
	PrecMax	1882	578	473	400	341	485	248	221	194	185	177	177	489	(16)	
	PrecMin	457	0	29	11	1	1	3	0	3	0	0	0	2	(17)	
	PrecStd	324	127	115	95	73	79	56	48	40	41	39	45	86	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.5	31.6	31.0	29.3	28.2	27.1	27.3	28.2	29.7	30.5	31.4	(19)	
		MCWB	25.0	25.7	25.7	24.7	23.0	22.8	20.9	21.3	21.5	22.1	23.9	24.7	(20)	
	2%	DB	30.9	31.4	30.5	29.5	28.0	26.7	25.6	26.0	26.8	28.2	29.2	30.2	(21)	
		MCWB	25.1	25.7	25.4	24.4	23.0	21.8	20.6	21.1	21.0	22.3	23.3	24.3	(22)	
	5%	DB	30.2	30.6	29.8	28.7	27.1	25.8	24.6	24.9	25.9	27.3	28.4	29.6	(23)	
		MCWB	24.7	25.5	25.1	24.1	22.5	21.3	19.8	20.2	20.7	21.8	22.8	24.1	(24)	
	10%	DB	29.6	29.9	29.2	28.0	26.3	24.9	23.8	24.0	25.1	26.6	27.7	29.0	(25)	
		MCWB	24.4	25.2	24.7	23.7	22.0	20.5	19.1	19.2	20.1	21.2	22.3	23.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.1	26.9	26.0	24.9	23.9	22.7	23.0	23.1	24.0	25.1	26.1	(27)	
		MCDB	29.9	30.4	29.9	29.2	27.1	26.6	25.2	25.0	26.0	27.5	28.7	29.6	(28)	
	2%	WB	26.2	26.6	26.2	25.4	24.1	23.0	21.7	21.9	22.3	23.1	24.3	25.4	(29)	
		MCDB	29.3	29.9	29.3	28.3	26.4	25.6	24.4	24.7	25.3	26.9	27.6	29.0	(30)	
	5%	WB	25.7	26.1	25.8	24.9	23.5	22.3	20.8	21.1	21.6	22.5	23.6	24.8	(31)	
		MCDB	28.8	29.4	28.8	27.6	25.9	24.8	23.4	23.9	24.8	26.3	27.1	28.5	(32)	
	10%	WB	25.2	25.7	25.3	24.4	22.9	21.4	20.1	20.3	20.9	21.9	23.1	24.3	(33)	
		MCDB	28.3	28.8	28.2	27.0	25.4	24.1	22.9	23.2	24.1	25.7	26.8	28.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	5.8	6.2	6.6	6.6	6.8	7.1	7.5	7.3	6.9	6.6	(35)	
		MCDBR	6.9	6.8	6.4	6.8	7.0	7.3	7.6	7.6	7.9	7.9	7.4	7.3	(36)	
	5% WB	MCWBR	3.1	3.2	3.0	3.3	3.5	3.8	3.9	4.1	4.2	3.9	3.7	3.4	(37)	
		MCWBR	5.9	6.1	5.8	5.9	5.8	6.3	6.4	6.3	6.8	7.0	6.7	6.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.382	0.380	0.376	0.363	0.347	0.348	0.328	0.333	0.350	0.364	0.369	0.374	(40)	
		taud	2.602	2.618	2.644	2.655	2.662	2.638	2.677	2.664	2.573	2.559	2.575	2.601	(41)	
	Ebn at Noon		963	952	933	906	884	863	895	923	942	957	968	971	(42)	
		Edh at Noon	105	101	95	88	81	80	78	85	100	106	107	105	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.59	6.19	5.40	4.73	3.97	3.61	3.98	4.66	5.81	6.40	6.56	6.80	(44)	
	RadStd		0.50	0.51	0.45	0.40	0.29	0.20	0.23	0.31	0.28	0.38	0.47	0.52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page