

OUVEA, New Caledonia

WMO: 915790

Lat: 20.639S

Lon: 166.571E

Elev: 30

StdP: 14.68

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	56.0	59.2	50.9	55.4	65.7	52.8	59.4	66.9	22.0	70.9	20.6	71.2	1.3	190	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.1	87.9	78.7	86.8	78.0	85.9	77.4	80.7	85.5	79.8	84.5	79.1	83.6	10.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	151.9	83.5	78.4	147.8	82.8	77.7	144.3	82.3	44.4	85.9	43.5	84.6	42.7	83.8	88.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	19.3	18.1	51.2	89.8	2.5	1.3	49.4	90.7	47.9	91.5	46.5	92.2	44.6	93.2		
(5)			50.3	82.3	2.1	2.0	48.7	83.7	47.5	84.9	46.3	86.0	44.8	87.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	80.4	81.2	80.4	78.5	75.3	72.7	70.6	70.7	72.3	74.4	76.7	79.0	(6)
(7)		DBStd	4.44	1.95	1.82	1.79	2.18	2.66	2.80	3.04	3.25	2.87	2.35	2.20	1.91	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	5	0	0	0	0	0	0	2	3	0	0	0	0	(9)
(10)		CDD50	9487	941	873	942	856	784	681	640	642	670	757	801	900	(10)
(11)		CDD65	4020	476	453	477	406	319	232	177	181	221	292	351	435	(11)
(12)		CDH74	27684	4612	4665	4541	3166	1526	617	290	356	713	1344	2194	3660	(12)
(13)		CDH80	5155	1168	1269	1018	469	78	11	1	3	28	81	286	743	(13)
(14)	Wind	WSAvg	10.3	10.1	9.9	10.1	10.9	10.2	10.3	9.6	9.7	10.0	10.9	11.0	10.5	(14)
(15)	Precipitation	PrecAvg	45.4	5.9	5.3	6.9	3.5	3.1	3.8	3.6	2.4	1.7	2.4	3.4	3.4	(15)
(16)		PrecMax	84.9	25.0	19.6	25.0	12.3	9.1	9.0	11.8	10.2	7.8	9.3	11.4	9.3	(16)
(17)		PrecMin	26.2	1.3	1.1	0.9	0.0	0.2	0.0	0.1	0.0	0.0	0.2	0.0	0.0	(17)
(18)		PrecStd	16.2	5.3	4.5	5.2	3.1	2.7	2.3	3.2	2.2	1.8	2.2	2.9	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.9	89.8	88.3	86.9	83.4	81.6	79.7	80.3	83.2	83.4	85.5	88.2	(19)
(20)			MCWB	78.5	79.9	79.6	78.9	75.4	74.4	71.7	72.1	73.4	73.1	75.6	77.5	(20)
(21)		2%	DB	87.3	88.0	86.9	85.1	82.0	79.7	77.9	78.6	80.5	81.9	84.0	86.3	(21)
(22)			MCWB	77.9	79.0	78.6	77.3	74.3	72.7	70.0	71.0	71.3	72.1	74.4	76.7	(22)
(23)		5%	DB	86.2	86.9	85.8	83.8	80.8	78.5	76.7	77.2	79.0	80.9	82.8	85.0	(23)
(24)			MCWB	77.2	78.3	77.8	76.1	73.2	71.3	68.8	69.4	69.7	71.4	73.3	75.8	(24)
(25)		10%	DB	85.1	85.8	84.7	82.7	79.7	77.3	75.7	76.0	77.8	79.8	81.7	83.8	(25)
(26)			MCWB	76.6	77.7	77.1	75.3	72.5	70.6	68.0	68.2	68.7	70.7	72.4	74.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	82.0	81.5	80.7	77.6	76.9	74.7	75.2	75.9	76.1	78.3	79.5	(27)
(28)			MCDWB	85.8	87.3	86.1	85.2	80.8	80.0	76.8	77.6	79.6	80.6	83.0	84.9	(28)
(29)		2%	WB	80.1	80.7	80.1	79.1	76.4	75.3	73.1	73.3	74.1	74.5	76.6	78.5	(29)
(30)			MCDWB	84.9	85.6	84.9	83.2	79.5	77.8	76.0	76.5	77.8	79.3	81.1	83.9	(30)
(31)		5%	WB	79.1	79.9	79.3	78.0	75.5	74.1	71.7	71.9	72.7	73.5	75.5	77.6	(31)
(32)			MCDWB	83.9	84.6	83.7	81.9	78.7	76.7	74.8	75.5	76.5	78.4	80.5	82.7	(32)
(33)		10%	WB	78.2	79.1	78.6	77.0	74.5	72.6	70.4	70.6	71.2	72.5	74.4	76.7	(33)
(34)			MCDWB	83.0	83.7	82.8	80.8	78.1	75.8	73.9	74.4	75.7	77.7	79.6	81.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.1	8.6	8.4	8.8	9.1	10.5	10.6	11.1	10.6	10.0	9.6	(35)
(36)			MCDBR	11.1	10.8	10.4	9.9	9.9	10.8	12.0	11.8	12.7	12.4	11.5	11.4	(36)
(37)			MCWBR	5.2	4.8	5.2	5.1	5.3	6.3	6.8	6.7	6.8	6.0	5.2	4.9	(37)
(38)		5% WB	MCDBR	9.6	9.5	9.5	9.4	8.4	8.6	9.0	9.9	10.7	11.0	10.1	10.0	(38)
(39)			MCWBR	5.2	4.9	5.3	5.5	4.9	6.0	6.4	6.5	6.9	6.3	5.0	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.389	0.386	0.384	0.378	0.363	0.356	0.339	0.344	0.358	0.372	0.373	0.379	(40)	
(41)		taud	2.590	2.607	2.623	2.616	2.622	2.629	2.651	2.636	2.572	2.553	2.581	2.595	(41)	
(42)		Ebn at Noon	303	300	293	283	275	271	280	289	297	301	306	306	(42)	
(43)		Edh at Noon	34	32	31	29	27	25	26	28	32	34	34	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2137	2030	1734	1484	1231	1129	1226	1466	1808	2037	2128	2214	(44)	
(45)		RadStd	167	173	122	132	100	79	84	93	127	120	124	154	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (5 neighbors)		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A

Nomenclature: See separate page